IEEE Std C37.122-1993(R2002)
(Revision of IEEE Std C37.122-1983,
includes IEEE Std C37.122a-1991)

IEEE Standard for Gas-Insulated Substations

Sponsor

Substations Committee
of the
IEEE Power Engineering Society

Reaffirmed June 12, 2002
Approved December 2, 1993

IEEE Standards Board

Abstract: The technical requirements for the design, fabrication, testing, and installation of a gas-insulated substation (GIS) are covered. The parameters to be supplied by the purchaser are set, and the technical requirements for the design, fabrication, testing, and installation to be furnished by the manufacturer are established.
Keywords: gas-insulated substation, GIS, GIS design, GIS equipment, GIS installation, GIS testing, SF_6, sulfur hexafluoride

---

The Institute of Electrical and Electronics Engineers, Inc.
345 East 47th Street, New York, NY 10017-2394, USA.

Copyright © 1994 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 1994. Printed in the United States of America.

ISBN 1-55937-397-0

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

--``,,-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS

Not for Resale

IEEE Standards documents are developed within the Technical Committees of the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Board. Members of the committees serve voluntarily and without compensation. They are not necessarily members of the Institute. The standards developed within IEEE represent a consensus of the broad expertise on the subject within the Institute as well as those activities outside of IEEE that have expressed an interest in participating in the development of the standard.

Use of an IEEE Standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of all concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason IEEE and the members of its technical committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE Standards Board
445 Hoes Lane
P.O. Box 1331
Piscataway, NJ 08855-1331
USA

IEEE standards documents may involve the use of patented technology. Their approval by the Institute of Electrical and Electronics Engineers does not mean that using such technology for the purpose of conforming to such standards is authorized by the patent owner. It is the obligation of the user of such technology to obtain all necessary permissions.

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Introduction

(This introduction is not a part of IEEE Std C37.122-1993, IEEE Standard for Gas-Insulated Substations.)

IEEE Std C37.122-1983 was initiated in the early 1970s when the first gas-insulated substations (GIS) were introduced. Approved in 1983, it contains standards, recommended practices, and guides. Circumstances beyond the control of the responsible Technical Committees delayed its availability to users until late 1988. Simultaneous to its publication, the Gas-Insulated Substations Subcommittee of the IEEE Power Engineering Society (PES) Substations Committee began work on the necessary update, revision, and expansion of the document.

The reliability of GIS has improved greatly since the first installation in the late 1960s. Utilities have taken advantage of the greater flexibility offered by GIS to locate substations closer to load centers with considerable savings in subtransmission systems. In addition, GIS typically offers 20 years or more of operation before major overhaul is required.

During the Working Group and Subcommittee deliberations on the update, it was recognized that users would be better served if the original document were divided in two, becoming IEEE Std C37.122-1993 (a standard) and IEEE Std C37.122.1-1993 (a guide). The two documents can be referred to individually or jointly depending on the purpose of the referral.

An extensive bibliography on gas-insulated substations, consolidating published and updated entries, is provided for the convenience of the user in obtaining detailed information on the subjects covered in this standard.

IEEE Std C37.122a-1991, Supplement to IEEE Std C37.122-1983, IEEE Standard Gas-Insulated Substations, Section 2.2.2: Pressurized Enclosures, has also been included in this standard.

Although all Working Groups of the Gas-Insulated Substations Subcommittee contributed to this revision, the prime responsibility belonged to Working Group K2, Revision of IEEE Std C37.122-1983, which approved this standard. At the time this standard was approved, Working Group K2 had the following membership:

A. A. Leibold, *Chair*

B. Becer	J. E. Holladay	P R. Nannery
H. D. Bennett	C. Hurty	J. Nash
S. Boggs	R. A. Jones	K. Pettersson
P. C. Bolin	E. B. Khalafalla	J. F. Quinata
R. E. Carberry	L. M. Laskowski	J. Sabath
D. Charbonnet	R. Matulic	B. Sojka
J. M. Delcoustal	A. Mickevicius	H. Thakar
E. I. Hahn	K. B. Miners	N. G. Trinh

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

The Gas-Insulated Substations Subcommittee of the IEEE PES Substations Committee that reviewed and approved this standard had the following membership:

R. Matulic, *Chair*
J. F. Quinata, *Vice Chair*

A. Arora
B. Becer
H. D. Bennett
S. Boggs
P. C. Bolin
J. Buchsbaum
R. E. Carberry
D. Charbonnet
J. L. Charney
F. Y. Chu
T. F. Clark
J. M. Delcoustal
H. R. Gilden
J. Grzan
E. I. Hahn
J. E. Holladay
C. Hurty
G. M. Ihle
R. Jones
E. B. Khalafalla
L. M. Laskowski
A. A. Leibold
K. E. Lewis
J. Luiz
A. Mickevicius
C. S. Miller
K. B. Miners
P. R. Nannery
J. Nash
E. V. Olavarria
K. Pettersson
D. J. Poole
M. W. Randall
J. Sabath
B. Sojka
R. C. St. Clair
H. Thakar
N. G. Trinh
R. Verma
J. A. Yoder

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

The following persons were on the Substations Committee of the IEEE Power Engineering Society that approved this standard for submission to the IEEE Standards Board:

M. L. Holm, *Chair*
J. B. Cannon, *Vice Chair*
A. E. Kollar, *Secretary*

W. J. Ackerman
B. Y. Afshar
S. J. Arnot
A. C. Baker
N. Barbeito
G. J. Bartok
B. Becer
K. M. Bevins
M. J. Bio
K. L. Black
C. J. Blattner
W. R. Block
S. Boggs
P. C. Bolin
S. D. Brown
J. C. Burke
R. E. Carberry
D. Charbonnet
F. Y. Chu
J. R. Clayton
R. G. Cottrell
E. F. Counsel
W. K. Daily
F. A. Denbrock
C. C. Diemond
W. B. Dietzman
T. L. Doern
C. Durand
L. N. Ferguson
G. G. Flaig
D. L. Garrett
J. Grzan
D. L. Harris
J. E. Holladay
Z. Kapelina
R. P. Keil
F. F. Kluge
D. F. Koenig
T. J. Kolenda
T. L. Krummrey
L. W. Kurtz, Jr.
D. N. Laird
L. M. Laskowski
A. A. Leibold
C. T. Lindeberg
H. P. Lips
R. Matulic
J. D. McDonald
T. S. McLenahan
A. P. S. Meliopoulos
P. R. Nannery
R. S. Nowell
E. V. Olavarria
J. T. Orrell
J. Oswald
S. G. Patel
R. J. Perina
K. Pettersson
J. F Quinata
D. G. Rishworth
B. D. Russell
J. Sabath
F. C. Shainauskas
B. Sojka
R. C. St. Clair
W. K. Switzer
E. R. Taylor
H. Thakar
C. F. Todd
D. R. Torgerson
L. F. Volf
R. J. Wehling
R. M. Youngs

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

The accredited Standards Committee on Power Switchgear, C37, that reviewed and approved this standard had the following members at the time of approval:

E. Byron, *Chair*
M. Williams, *Secretary*
M. Calwise *(Program Administrator)*
A. K. McCabe *(Executive Vice-Chair of High-Voltage Switchgear Standards)*
(vacant) *(Executive Vice-Chair of Low-Voltage Switchgear Standards)*
D. L. Swindler *(Executive Vice-Chair of IEC Activities)*

Organization Represented	***Name of Representative***
Association of Iron and Steel Engineers	(vacant)
Electric Light and Power Group	M. C. Mingoia D. J. Borchart T. E. Bruck J. H. Provanzana J. D. Stewart G. R. Brandenberger (*Alt.*) A. K. McCabe (*Alt.*)
Institute of Electrical and Electronics Engineers	D. F. Peelo L. B. Beard H. L. Bowles P. W. Dwyer D. Signon S. C. Atkinson (*Alt.*) D. G. Kumbera (*Alt.*) L. V. McCall (*Alt.*)
Laubach Associates	W. Laubach
National Electrical Manufacturers Association	R. Garzon G. Haynes W. Kracht H. L. Miller T. Olson E. Byron (*Alt.*) G. T. Jones (*Alt.*) G. Sakats (*Alt.*) S. Stone (*Alt.*) D. L. Swindler (*Alt.*)
Tennessee Valley Authority	D. N. Reynolds
Testing Laboratory Group	L. Frier W. T. O'Grady
U.S. Department of the Army, Office of the Chief of Engineers	J. A. Gilson
U.S. Department of the Interior, Bureau of Reclamation	R. Arnold
U.S. Department of the Navy, Naval Construction Battalion Center	R. L. Clark
Western Area Power Administration	G. D. Birney

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

The following persons were on the balloting committee:

A. Arora
B. Becer
M. D. Bennett
S. A. Boggs
P. C. Bolin
J. A. Buchsbaum
J. C. Burke
R. E. Carberry
D. Charbonnet
F. Y. Chu
T. F. Clark
R. Cottrell
W. B. Dietzman
H. R. Gilden
J. Grzan
E. I. Hahn
J. E. Holladay
C. Hurty
R. Janezic
R. Jones
Z. Kapelina
E. B. Khalafalla
L. M. Laskowski
A. A. Leibold
K. E. Lewis
H. P. Lips
J. Luiz
R. Matulic
T. S. McLenahan
A. Mickevicius
C. S. Miller
K. B. Miners
P. R. Nannery
J. Nash
E. V. Olavarria
K. G. Petterson
D. J. Poole
J. Quinata
M. W. Randall
J. Sabath
B. Sojka
R. C. St. Clair
H. Thakar
N. G. Trinh
R. J. Wehling
J. A. Yoder

When the IEEE Standards Board approved this standard on December 2, 1993, it had the following membership:

Wallace S. Read, *Chair*
Donald C. Loughry, *Vice Chair*
Andrew G. Salem, *Secretary*

Gilles A. Baril
José A. Berrios de la Paz
Clyde R. Camp
Donald C. Fleckenstein
Jay Forster*
David F. Franklin
Ramiro Garcia
Donald N. Heirman
Jim Isaak
Ben C. Johnson
Walter J. Karplus
Lorraine C. Kevra
E. G. "Al" Kiener
Ivor N. Knight
Joseph L. Koepfinger*
D. N. "Jim" Logothetis
Don T. Michael*
Marco W. Migliaro
L. John Rankine
Arthur K. Reilly
Ronald H. Reimer
Gary S. Robinson
Leonard L. Tripp
Donald W. Zipsc

*Member Emeritus

Also included are the following nonvoting IEEE Standards Board liaisons:

Satish K. Aggarwal
James Beall
Richard B. Engelman
David E. Soffrin
Stanley I. Warshaw

Valerie E. Zelenty
IEEE Standards Project Editor

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

CLAUSE PAGE

1. Overview 1

2. References 1

3. Definitions 3

4. Service conditions 4

4.1 Normal service conditions 4
4.2 Special service conditions 5
4.3 Other conditions that may affect design and application 5

5. Ratings and requirements 5

5.1 Equipment ratings 5
5.2 Pressurized bus enclosures and expansion joints 7
5.3 Cable terminations and future expansion facilities 9
5.4 Gas system 10
5.5 Leakage rate 11
5.6 Grounding 11
5.7 Seismic requirements 11
5.8 Type and routine testing 11
5.9 Field testing 15
5.10 Shipment and storage 16
5.11 Installation 16
5.12 GIS nameplates 16

6. Bibliography 18

6.1 Dielectric 20
6.2 Equipment 52
6.3 General 92
6.4 Index of authors 108

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

IEEE Standard for Gas-Insulated Substations

1. Overview

This standard establishes ratings and requirements for planning, design, testing, installation, and operation of gas-insulated substations (GIS) for alternating-current applications for voltages from 72.5 to 800 kV. Typical installations are assemblies of specialized devices such as circuit breakers, switches, bushings, buses, instrumentation, and the gas-insulating system. It does not include certain items that may be directly connected to gas-insulated substations, such as power transformers and protective relaying.

2. References

The following publications shall be used in conjunction with this standard:

Accredited Standards Committee C2-1993, National Electrical Safety Code (ANSI).[1]

ANSI C37.06-1987 American National Standard Switchgear—AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis—Preferred Ratings and Related Required Capabilities.[2]

ANSI C63.2-1987 American National Standard Specifications for Electromagnetic Noise and Field-Strength Instrumentation, 10 kHz to 40 GHz.

ANSI MC96.1-1982, American National Standard Temperature Measurement Thermocouples.[3]

ANSI/ASME 1992 Boiler and Pressure Vessel Code—Section VIII: Pressure Vessels, Division 1.

ANSI/ASME B31.1-1992, Power Piping.

[1]The NESC is available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331, USA.
[2]ANSI publications are available from the Sales Department, American National Standards Institute, 11 West 42nd Street, 13th Floor, New York, NY 10036, USA.
[3]ANSI MC96.1-1982 has been withdrawn; however, copies can be obtained from Global Engineering, 1990 M Street NW, Suite 400, Washington, DC, 20036, USA.

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

ASTM D2472-92 , Specification for Sulfur Hexafluoride.[4]

CENELEC EN 50 052-1988, Specification for Cast Aluminum Alloy Enclosures for Gas-Filled High-Voltage Switchgear and Controlgear.[5]

CENELEC EN 50 064-1990, Specification for Wrought Aluminum and Aluminum-Alloy Enclosures for Gas-Filled High-Voltage Switchgear and Controlgear.

CENELEC EN 50 069-1991, Specification for Welded Composite Enclosures of Cast and Wrought Aluminum Alloys for Gas-Filled High-Voltage Switchgear and Controlgear.

CENELEC EN 50 089-1992, Specification for Cast Resin Partitions for Metal-Enclosed Gas-Filled High-Voltage Switchgear and Controlgear.

IEC 517: 1990 Gas-insulated metal-enclosed switchgear for rated voltages of 72.5 kV and above (3d ed.).[6]

IEEE Std 24-1984 IEEE Standard Performance Characteristics and Dimensions for Outdoor Apparatus Bushings (ANSI).[7]

IEEE Std 48-1990 IEEE Standard Test Procedures and Requirements for High-Voltage Alternating-Current Cable Terminations (ANSI).

IEEE Std 80-1986 (Reaff 1991) IEEE Guide for Safety in AC Substation Grounding (ANSI).

IEEE Std 100-1992 The New IEEE Standard Dictionary of Electrical and Electronics Terms (ANSI).

IEEE Std 119-1974 IEEE Recommended Practice for General Principles of Temperature Measurement as Applied to Electrical Apparatus.[8]

IEEE Std 315-1975 (Reaff 1989) IEEE Standard Graphic Symbols for Electrical and Electronics Diagrams (ANSI).

IEEE Std 367-1987 IEEE Recommended Practice for Determining the Electric Power Station Ground Potential Rise and Induced Voltage from a Power Fault (ANSI).

IEEE Std 693-1984 (Reaff 1991) IEEE Recommended Practices for Seismic Design of Substations (ANSI).

IEEE Std C37.010-1979 (Reaff 1988) IEEE Application Guide for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis (ANSI).

IEEE Std C37.04-1979 (Reaff 1988) IEEE Standard Rating Structure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis (ANSI).

IEEE Std C37.09-1979 (Reaff 1988) IEEE Standard Test Procedure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis (ANSI).

---

[4]ASTM publications are available from the Customer Service Department, American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103, USA.

[5]CENELEC publications are available from the Sales Department, American National Standards Institute, 11 West 42nd Street, 13th Floor, New York, NY 10036, USA.

[6]IEC publications are available from IEC Sales Department, Case Postale 131, 3 rue de Varembé, CH-1211, Genève 20, Switzerland/Suisse. IEC publications are also available in the United States from the Sales Department, American National Standards Institute, 11 West 42nd Street, 13th Floor, New York, NY 10036, USA.

[7]IEEE publications are available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331, USA.

[8]IEEE Std 119-1974 has been withdrawn; however, copies can be obtained from the IEEE Standards Department, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331, USA.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

IEEE Std C37.24-1986 (Reaff 1991) IEEE Guide for Evaluating the Effect of Solar Radiation on Outdoor Metal-Enclosed Switchgear (ANSI).

IEEE Std C37.30-1992 IEEE Standard Definitions and Requirements for High-Voltage Air Switches (ANSI).

IEEE Std C37.38-1989 IEEE Standard for Gas-Insulated Metal-Enclosed Disconnecting, Interrupter, and Grounding Switches (ANSI).

IEEE Std C62.11-1987 IEEE Standard for Metal-Oxide Surge Arresters for AC Power Circuits (ANSI).

3. Definitions

The definitions in this clause are applicable only to the subject treated in this standard. At the time this standard was approved there were no corresponding definitions in IEEE Std 100-1992. [9]

3.1 assembly (GIS): A collection of GIS components which are interconnected and ready for insertion as a subassembly in a GIS, such as a breaker bay shipping assembly. The term is also used to describe a complete GIS.

3.2 auxiliary circuits: All control, indicating, and measuring circuits.

3.3 compartment (GIS): Any gas section of the gas-insulated substation assembly that provides gas isolation.

3.4 continuous enclosure: A bus enclosure in which the consecutive sections of the enclosure are electrically bonded together to provide a continuous current path through the entire enclosure length.

3.5 continuous monitoring: The process of sampling the state of some phenomenon at a time interval shorter than the time constant of the phenomenon.

3.6 gas barrier insulator: An insulating support specifically designed to prevent passage of gas from one gas compartment to another.

3.7 gas density, minimum: The minimum (below normal) operating gas density at which the gas-insulated substation and its components are certified to meet their assigned electrical ratings.

3.8 gas density, normal: The manufacturer's recommended operating gas density (usually expressed as a pressure at 20 °C.

3.9 gas-insulated substation (GIS): A compact, multicomponent assembly, enclosed in a grounded metallic housing in which the primary insulating medium is a compressed gas, and which normally consists of buses, switchgear, and associated equipment.

3.10 gas-insulated surge arrester: A metal-enclosed surge arrester specifically designed for use in a gas-insulated substation.

3.11 gas leakage: Loss of insulating gas from the pressurized compartment.

3.12 metallic enclosure: A grounded, leak-tight enclosure that contains the compressed insulating gas and associated electrical equipment.

3.13 non-continuous enclosure: A bus enclosure in which the consecutive sections of the enclosure are electrically insulated from each other, although each section is connected to ground.

NOTE — This construction prevents longitudinal currents from flowing beyond each enclosure section. This design is no longer in common usage.

3.14 spacer (insulator): An insulator used to support the inner conductor in the enclosure.

[9]Information on references can be found in clause 2..

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

3.15 transition compartment: A compartment specifically designed for joining gas-insulated substation equipment of different design or manufacture. The compartment provides the necessary transition for the current-carrying conductor and the enclosure.

3.16 type tests: Tests made on representative samples that are intended to be used as a part of routine production. The applicable portions of these type tests may also be used to evaluate modifications of a previous design and to ensure that performance has not been adversely affected.

3.17 water vapor (moisture) content: The amount of water in parts per million by volume (ppmv) that is in the gaseous state and mixed with the insulating gas.

4. Service conditions

4.1 Normal service conditions

Devices conforming to this standard shall meet the electrical, mechanical, thermal, and other requirements of the gas-insulated substation on which it is used and be capable of operation under the following conditions:

4.1.1 Temperature range

The normal ambient temperature range shall be –30 °C to +40 7°C.

4.1.2 Heat absorption due to solar radiation

Solar radiation shall be considered in the design of GIS. IEEE Std C37.24-1986 provides guidance in evaluation of the effects of solar radiation on outdoor apparatus.

4.1.3 Internal pressure

The internal pressure range shall be from 10 Pa to the maximum operating pressure specified by the manufacturer.

4.1.4 Wind and ice

Wind and ice conditions shall correspond to conditions included in Accredited Standards Committee C2-1993 (NESC) for heavy loading on structures.

4.1.5 Electromagnetic interference

The equipment shall not operate falsely or fail to operate because of induced transient or steady-state electromagnetic fields generated during normal service or test conditions.

4.1.6 Power frequency

The standard power frequency shall be 50 Hz or 60 Hz.

4.1.7 Vibration and shock

The equipment shall withstand for its service life the vibration of any directly connected equipment, such as transformers, and the shock caused by the operation or maintenance of the equipment.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

4.1.8 Altitude

The normal installation altitude shall not exceed 1000 m (3300 ft). At any altitude, the dielectric characteristics of the internal insulation are identical to those measured at sea level. For installation above 1000 m (3300 ft), only adjustments of air-insulated connections (bushings) and overpressure protective devices are required.

4.2 Special service conditions

Special service conditions are those in which the equipment is used under other than the normal service conditions. Standard assemblies may be applied at special service conditions, but performance may be affected, and special considerations shall be given to these applications.

4.3 Other conditions that may affect design and application

Where other conditions exist, they shall be brought to the attention of the manufacturer. Among such conditions are:

a) Exposure to damaging fumes or vapors, steam, salt air, oil vapors, hot humid climate, excessive dust, abrasive dust, dripping water, falling dirt, explosive mixtures of dust or gases, or extreme high or low temperatures.

b) Unusual location requirements, space or ventilation limits, special duty, frequency or other operating requirements, difficulty of maintenance, non-standard or unstable control voltage, or abnormal vibration.

c) Portions of a single GIS with different environments (such as a portion of the GIS installed partially indoors and partially outdoors).

5. Ratings and requirements

5.1 Equipment ratings

5.1.1 Temperature ratings

The general ratings that all components of the station shall meet or exceed are as follows:

Maximum allowable total temperature:

Main conductor joints = 105 °C

External surfaces = 70 °C

All other conditions regarding temperature limitations are as noted in IEEE Std C37.010-1979 and IEEE Std C37.30-1992 .

5.1.2 Voltage ratings

Required voltage ratings are listed in table 1.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Table 1— Voltage ratings

System voltage	Type test voltages		
Rated max voltage phase-to-phase kV rms	**Rated BIL kV crest**	**Low frequency phase-to-ground withstand kV rms**	**Switching impulse withstand kV crest**
72.5	350	160	
121	550	215	
145	650	310	
169	750	365	
242	900	425	
362	1050	500	825
550	1550	740	1175
800	2100	960	1550

NOTES:
1 — Routine power-frequency (50 Hz or 60 Hz) I min withstand tests shall be conducted prior to shipment from the factory at low-frequency withstand voltages.
2 — Disconnect switch open-gap withstand shall be 10% higher than substation type test values.

5.1.3 Continuous current (A rms) rating at ambient temperature

The value of rated continuous current shall be selected from the following:

Rated continuous current (Arms)
2000
2500
3150
4000
5000
6300

5.1.4 Load current-carrying capability under various conditions of ambient temperature

The variation of rated continuous current with ambient temperature shall be as specified in IEEE Std C37.010-1979 and IEEE Std C37.30-1992.

5.1.5 Short-time load current capability

The short-time load current capability shall be as specified in IEEE Std C37.010-1979.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

5.1.6 Rated close and latch current

The rms and peak value of the rated momentary current shall be 1.6 and 2.7 (respectively) times the rated short-time current-carrying capability.

5.1.7 Short-time current-carrying capability

The value for the short-time current-carrying capability shall be selected from the following table:

Short-time current-carrying capability (kA rms)	
20	50
25	63
31.5	80
40	100

The standard durations for the short-time current shall be 1 s or 3 s.

5.2 Pressurized bus enclosures and expansion joints

High-voltage, gas-insulated substations consist basically of grounded, pressurized metal enclosures containing energized high-voltage conductors) and other substation components. Under certain conditions, both conductors and enclosures must carry rated load and short-circuit currents.

Components having pressurized enclosures other than metal, such as gas-insulated to atmospheric air bushings, shall conform to the applicable clause of the latest revision of IEEE Std C37.04-1979 .

GIS enclosures shall be filled with dry compressed gas, such as sulfur hexafluoride (SF_6), which is inert and non-corrosive. To protect the electrical integrity of the equipment, enclosures must be kept closed to preclude the entrance of moisture and foreign particles. Periodic internal inspections are undesirable and not required.

Gas-insulated substations are installed in areas with admission to authorized personnel only, and operated by trained personnel.

5.2.1 Criteria for enclosure design

5.2.1.1 Temperatures

Based on criteria in 4.1.1, the maximum design temperature for purposes of calculating the design pressure of the gas shall be the average of the upper limits of the enclosure and conductor temperatures at rated load current, unless the design pressure can be established from existing temperature-rise test data.

5.2.1.2 Thermal cycling, vibration, shock and seismic

Enclosures shall be designed to withstand all mechanical stresses normally encountered, including thermal cycling, vibration, and shock associated with operation, They shall be designed for seismic loading, if specified.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

5.2.1.3 Design pressure

Design pressure is defined as the maximum steady-state gas pressure to which a gas-insulated substation enclosure is subjected under normal operating conditions. It is one factor used in calculations that establish the thickness of the enclosure and the materials and design of associated components.

When designing an enclosure, the following shall be considered:

a) The possible evacuation of the enclosure as part of the filling process (normal)

b) The full differential pressure possible across the enclosure wall or partition (normal)

c) In the case of adjacent gas compartments having different operating pressures, the resulting pressure in the event of a leak between the gas compartments (abnormal)

d) The possibility of an internal fault (abnormal)

5.2.1.4 Calculation methods

Methods for calculating the thickness and construction of the enclosures may be chosen from established pressure vessel codes (see CENELEC EN 50 052-1988, CENELEC EN 50-064-1990, CENELEC EN 50 069-1991, ANSI/ASME 1992 Boiler and Pressure Vessel Code, and ANSI/ASME B31.1-1992). Other equivalent national standards may be used by agreement between the manufacturer and the user. Conformance to local or state codes may also be required and shall be agreed to between the manufacturer and the user.

5.2.1.5 Effects of internal phase-to-ground arc on enclosure

The wall thickness of the enclosure shall be based on the design pressure as well as the following minimum withstand durations without burn-through, unless otherwise specified by the user:

a) 0.1 s for currents of 40 kA and above
b) 0.2 s for lower currents

5.2.1.6 Stress under abnormal pressure

Enclosures shall withstand any increase in pressure due to internal arcs which create an abnormal pressure. The abnormal pressure to be withstood is defined as the pressure caused by an internal arc of current magnitude equal to the rated short-circuit current for a minimum duration of 0.33 s or the fault-clearing time as specified by the user.

Calculation of stress or type tests shall indicate that a rupture shall not occur under abnormal pressure. The rupture pressure shall be equal to or greater than 3.5 times the design pressure for cast and cast-welded enclosures and 2.3 times the design pressure for welded enclosures. The operation of a pressure-relief device or burn-through of the enclosure shall not be considered a rupture.

5.2.1.7 Routine pressure tests

Pressure tests shall be made on all enclosures after manufacture. Standard test pressure shall be at least 1.3 times the design pressure for welded enclosures and 1.5 times the design pressure for cast enclosures.

Alternative non-destructive tests may be agreed upon between the manufacturer and the user.

5.2.1.8 Pressure-relief devices

Pressure-relief devices to relieve abnormal pressure shall be set to operate at a pressure not exceeding 87.5% of the routine test pressure. Especially for indoor installations, a pressure-relief setting shall be chosen so that circuit

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

breakers may clear an internal fault prior to pressure-relief device operation in order to prevent release of arced gases indoors. Pressure-relief devices shall direct the escaping gases away from the normal path of personnel and shall not vent into control cabinets.

5.2.1.9 Tests after erection on site

No pressure tests are prescribed after erection on site.

5.2.2 Supporting structures and platforms

Most bus systems are of the continuous enclosure design, which provides adequate shielding to eliminate induced magnetic heating and to pen-nit grounding as necessary (see 5.6.1 regarding grounding of enclosures). For high-current, non-continuous enclosure designs, consideration shall be given to induced magnetic heating and induced circulating current in nearby metallic members such as support beams, reinforcing rods, and transformer tanks. Suitable insulated gaps in the metallic framework to eliminate closed loops and amortisseur bands around steel members, etc., may be used to eliminate circulating current. The structure shall be designed so that the temperature rise in any of its members or in any adjacent members does not exceed the limits specified in 5.1.1.

Safe access for personnel is required to all viewports, locations from which operation is initiated through automatic or manual means, and other indicators such as pressure gauges. Climbing on the apparatus is not permitted.

5.2.3 Bus expansion joints

Expansion and installation alignment shall be considered in the design of the bus and the enclosure, and expansion joints shall be provided, if required. When bellows are provided in the enclosure for installation alignment, means shall be provided to prevent movement after alignment is complete. Bellows provided to permit movement caused by expansion and contraction or foundation settlement shall have specially designed means to preserve the mechanical strength of the bus and the enclosure as well as contact alignment and penetration. Joints provided for direct connection to transformers shall be designed to inhibit transfer of vibration from the transformer to the bus and the bus enclosure.

5.3 Cable terminations and future expansion facilities

5.3.1 Cable terminations

The following subclauses cover cable terminations for use with gas-insulated substations. Typical uses are for separation of the cable-insulating medium from the gas insulation (oil-gas, gas-gas, solid insulation-gas).

5.3.1.1 Ratings

The ratings of cable terminations shall be compatible with the ratings specified in table 1 and shall include the following information:

a) Rated maximum voltage

b) Rated lightning impulse withstand voltage (BIL)

c) Rated switching impulse withstand voltage (SIWL)

d) Rated gas density (the minimum at which full performance is ensured, stated as pressure at a specified temperature)

e) Rated pressure internal and external

f) Rated continuous and short-circuit currents shall be compatible with the ampacity of the connected cable

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

g) Power frequency withstand voltage

h) Information necessary to determine overload capability vs. ambient temperature

i) Maximum and minimum cable conductor size

j) Maximum and minimum cable insulation diameter

5.3.1.2 Electrical requirements

The electrical characteristics for cable terminations are as specified in IEEE Std 48-1990 and IEEE Std 24-1984 except as modified under equipment ratings in 5.1.

Isolation insulation shall be incorporated in the cable terminations to prevent circulating currents and to pen-nit cathodic protection of the cable system.

5.3.1.3 Mechanical requirements

Cable terminations shall meet the following requirements:

a) Pressure test as per 5.2 and IEEE Std 48-1990
b) Seismic considerations (if required) as per 5.7
c) Gas leakage requirements as per 5.5
d) Materials used in fabrication shall be compatible with the insulating medium
e) Gas segregation as per 5.3.1

5.3.2 Future expansion facilities

GIS can be expanded, rearranged, or added to equipment not originally furnished without technical difficulties. It is recommended for future expansion of GIS that the user clearly indicate all locations where the future equipment might be joined to the existing GIS.

To provide for efficient planning, the manufacturer shall provide, for each identified location where future expansion might occur, shop drawings showing all pertinent dimensions, tolerances, material and hardware used, gas seals, gas system, pressure, and any other information that will ensure fabrication and installation of future transition compartments with the least labor and outage time. These drawings must be submitted for approval.

5.4 Gas system

Sulfur hexafluoride (SF_6) for use as an electrical insulation material shall conform to the requirements prescribed in ASTM D2472-92.

5.4.1 Gas density

The gas density in each compartment shall be continuously monitored. The monitoring device shall be capable of operating a relay contact upon descending gas density at each of two different density levels. Gas density level settings and functional operating requirements (alarm, trip, etc.) at each level below normal shall be agreed upon between the manufacturer and the user. If the device has a visual indicator, it shall be readable from the ground.

5.4.2 Contacts

Gas density monitors shall have at least two electrically separate contacts, convertible from a to b, at each specified density level. Contact voltage and current rating shall be specified by the user. The manufacturer shall supply contact resetting data (i.e., differential levels at which contacts will return to normal position on increasing gas density). Double-throw break-make contacts (form c) may be used in lieu of convertible contacts.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

5.4.3 Calibration

Gas density monitors shall be capable of being calibrated with the monitored equipment in service.

5.4.4 Piping

If gas piping and connections can be disturbed during normal operation or maintenance, they shall be provided with mechanical protection.

5.5 Leakage rate

The leakage rate from any single gas compartment shall not exceed 1% per year. Leakage across the gas barrier insulator shall not prevent vacuum tests on one side with the other side at full pressure.

5.6 Grounding

5.6.1 Grounding of enclosures

The metallic enclosure shall be equipped with standard-type ground pads providing for connections to the ground grid, sized for the short-circuit current at each location which corresponds to the current specified for the installation. All metal parts except those at high voltage must be grounded. For the interconnection of enclosures, frames, etc., bolting or welding is acceptable to provide electrical continuity. Connections must meet the requirements of IEEE Std 80-1986 and IEEE Std 367-1987. The continuity of the grounding circuits shall be ensured, taking into account the thermal and electrical stresses caused by the current they may carry. The grounding system shall prevent excessive step and touch potential.

5.6.2 Grounding of high-voltage circuit

To ensure safety during maintenance work, all high-voltage parts where access is required or provided shall be capable of being grounded.

5.7 Seismic requirements

The two seismic ground motion levels are 0.5 g peak or 0.2 g peak acceleration, and for those areas where seismic considerations are not necessary, there are no specifications for a seismic requirement (see IEEE Std 693-1984).

5.8 Type and routine testing

The following subclauses establish the requirements for testing the GIS components.

Test requirements for gas-insulated circuit breakers, disconnect and grounding switches, instrument transformers, surge arresters, and bushings that may be an integral part of a GIS are specified in IEEE Std C37.30-1992, IEEE Std 48-1990, IEEE Std 24-1984, IEEE Std C37.38-1989, and IEEE Std C62.11-1987.

The purpose of the test procedures is to verify that all GIS components can perform satisfactorily, both electrically and mechanically, at the ratings assigned and to establish that production sections, after assembly, are free of defects and can perform satisfactorily.

5.8.1 Type tests

Type tests provide a method of demonstrating that the apparatus meets the specifications.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

5.8.1.1 Rated continuous current

Type tests shall demonstrate that the gas-insulated substation components can carry rated continuous current at rated frequency without exceeding any of the temperature limitations in 5.1.1. The effect of solar radiation shall be considered in assigning the temperature rise to the equipment. IEEE Std C37.24-1986 governs how this factor is to be applied.

5.8.1.2 Conditions of test

Required conditions are as follows:

a) The equipment shall be in a new condition.

b) Temperature-rise tests shall be conducted three-phase if three phases are enclosed within one enclosure. For a single-phase design, single-phase tests shall be made and the current in the enclosure shall represent the most severe service condition.

c) Allowances shall be made for the heating effect of neighboring or adjacent assemblies by means of heaters or insulation.

5.8.1.3 Duration of rated continuous current tests

The rated continuous current test shall be continued until the temperatures of all components that carry continuous current in normal operation are substantially constant, as indicated by three successive readings at 30 min intervals.

5.8.1.4 Temperature measurements

Temperatures shall be measured by the methods described in IEEE Std 119-1974 and ANSI MC96.1-1982. The measuring device shall be located at the hottest spot. Measurements shall be made at junction points of insulation and conducting parts to ensure against exceeding temperature limits of the insulation. The sensor of the temperature-measuring device used for measuring apparatus temperatures shall be in intimate contact with the apparatus, and so insulated that it is not affected by ambient temperatures.

5.8.1.5 Ambient temperature

The ambient temperature shall be taken as that of the surrounding air. The ambient shall be between 10 °C and 40 °C, inclusive, so that no correction factors need be applied. The ambient temperature shall be determined by taking the average of the readings of three thermometers placed in locations unaffected by drafts, horizontally 305 mm (12 in) from the periphery of the enclosure, and approximately on a vertical line as follows:

a) One approximately level with the enclosure
b) One approximately 305 mm (12 in) above the enclosure
c) One approximately 305 mm (12 in) below the enclosure

5.8.1.6 Short-circuit current rating

The values shall be as described in 5.1.7.

Tests to demonstrate the required capabilities shall be made in accordance with the conditions specified in IEEE Std C37.09-1979 and ANSI C37.06-1987.

Three-phase enclosure designs shall be tested three phase. Single-phase enclosures shall be tested single phase unless otherwise agreed to by the manufacturer and the user.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

These tests shall be made on single shipping sections and various other configurations of bolted, welded, plug-in, or otherwise jointed sections to verify the integrity of the GIS components as joined together. Tests shall be made on configurations providing the most onerous conditions.

Assemblies shall be tested such that specimens of all components and subassemblies of the design are subjected to the test.

5.8.1.7 Dielectric withstand tests

Three-phase enclosure designs shall be tested for each phase, with the other two phases and the enclosure grounded.

5.8.1.7.1 Power frequency

Power frequency voltage at the rated power-frequency withstand values shall be applied for 1 min between the main bus and ground and across all isolating gaps. All tests shall be made with high voltages in accordance with table 1, at minimum-rated gas density specified by the manufacturer.

5.8.1.7.2 Lightning impulse

Lightning impulse voltage at the rated BIL value (table 1) shall be applied between the main bus and ground and across all isolating gaps. The lightning impulse-type test circuit shall contain a spark gap between the high-voltage terminal of the impulse generator and the high-voltage terminal of the test piece. The spark-gap breakdown voltage shall be no greater than 25 kV and no less than 5 kV A resistor shall be connected from the high-voltage terminal of the test piece to ground. The discharge time constant of the test piece through this resistor shall be no greater than 0.1 s. At least 2 min shall separate each impulse application during the lightning impulse-type test using the above circuit. Otherwise, the test shall be conducted in accordance with IEEE Std C37.09-1979.

The purpose of the above test circuit is to ensure that the impulse generator does not impose small voltages on the test piece during charging of the impulse generator. Such voltages cause depletion of the negative SF_6 ions which are the primary source of initiatory electrons for SF_6 breakdown. The purpose of the waiting time of 2 min between impulse applications is to allow the ion concentration to approach equilibrium after being depleted by the electric field imposed during an impulse withstand or being enhanced by the breakdown processes which occur during an impulse breakdown. The time constant for approach to equilibrium is approximately 2 min.

5.8.1.7.3 Switching surge

Switching surge impulse voltage at the rated withstand value shall be applied between the main bus and ground and across all isolating gaps. Both positive and negative 250 by 2500 μs impulses are to be used. See IEEE Std C37.09-1979, ANSI C37.06-1987, and IEC 517 : 1990.

5.8.1.7.4 Partial discharge

All internal portions of the gas-insulated system shall be tested for partial discharge at 150% of rated maximum phase-to-ground voltage on the downward excursion of voltage from the power frequency withstand voltage. Extinction of the partial discharge must occur above the 150% point. Partial discharge tests shall be made using PD test apparatus with a sensitivity of 5 pC or better.

5.8.1.8 Electrical and mechanical life tests

Mechanical endurance tests shall be made on all circuit breakers, disconnects, and ground switches, in accordance with IEEE Std C37.30-1992 and IEEE Std C37.09-1979. This does not apply to fault-making ground switches.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Additional electrical and mechanical life tests shall be made to demonstrate life performance of bellows, elbows, or expansion joints used to compensate for thermally-induced movements, and to sliding electrical contacts used to tie electrically floating components to the conductor or enclosure.

Tests must ensure that all sliding contacts, sliding joints, bellows, and elbows with angular displacement or other means of compensating for thermally induced movements be tested such that electrical current, mechanical forces and movement, and temperature cycles over the extreme conditions are adequately simulated over the life of the equipment.

The tests and criteria of acceptance shall be subject to agreement between the user and the manufacturer.

Tests to demonstrate the switching capability of the circuit breakers, disconnect switches, and ground switches shall be made in accordance with IEEE Std C37.30–1992 and IEEE Std C37.09–1979. All switching devices fitted with mechanical interlocks shall be subjected to 50 cycles of mechanical operation to check the effectiveness of the interlocks. All interlocks shall be set to prevent operation of the switching device. One attempt shall be made to operate the switching device applying only normal operating forces and without adjusting the switching device or interlock.

5.8.1.9 Pressure tests

Pressure tests shall be performed on one sample of each component or assembly making up the substation in accordance with 5.2.1.7.

5.8.1.10 Weatherproof tests

If the equipment is to be installed outdoors, the design shall be subjected to weatherproof tests. Tests shall be agreed to between the user and the manufacturer, and shall simulate rain, ice, wind-driven snow, humidity, and other conditions as applicable.

5.8.1.11 Shipping tests

Subject to agreement between the manufacturer and the user, the manufacturer shall demonstrate that the equipment can be shipped from the factory to the site without being damaged. Methods of demonstration may include previous experience with similar equipment shipped by similar modes of transportation, shipping tests in which representative equipment is shipped, loaded, and unloaded, vibration tests to simulate shipping conditions, and weatherproof tests to check the adequacy of packing.

5.8.1.12 Internal arcing tests

Subject to agreement between the user and the manufacturer, tests shall be made to demonstrate that the equipment can safely withstand the effects of an internal arcing fault. Such tests shall demonstrate that the compartment that has the least likelihood of withstanding the pressure and temperature rise in the event of arcing shall be contained or safely vented (see 5.2). See IEC 517 : 1990.

5.8.1.13 Insulator tests

The thermal performance of each spacer insulator design shall be verified by subjecting five insulators to ten thermal cycles each. A thermal cycle is defined as the following:

a) 4 h at an ambient temperature of –40 °C
b) 2 h at room temperature
c) 4 h at an ambient temperature of +105 °C
d) 2 h at room temperature

 Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

After the test sequence, all spacer insulators shall meet all of the requirements of 5.2 and 5.8.2 item b) and shall have no visible cracks (see CENELEC EN 50 089–1992).

5.8.2 Routine tests

The following routine tests shall be performed at the factory on every unit following its manufacture:

a) Pressure test of cast and fabricated enclosures.

b) Gas leakage tests shall confirm the guaranteed leakage rates, including leakage tests across the gas barriers, if applicable.

c) Dielectric tests of auxiliary circuits.

d) Measurement of the resistance of the main circuit.

e) Tests for continuity of auxiliary circuits.

f) Tests on the resistors, heaters, coils, and interlocks in the control mechanism.

g) Operating tests on the auxiliary electrical, pneumatic, and hydraulic devices, at the limits of range of operating values, on all devices.

h) Timing tests on operating assemblies.

i) Stored energy system tests.

j) A power frequency withstand test shall be performed on each shipping section at the rated withstand voltage for 1 min (see table 1). A partial-discharge test shall be made in accordance with 5.8.1.7.4. Power frequency withstand and partial-discharge tests shall be performed after the section has undergone all indicated mechanical tests.

k) Tests on the gas density relay settings.

5.9 Field testing

5.9.1 Mechanical tests—Leakage

All compartments shall be filled with SF_6 to the normal pressure and leak tested to ensure compliance with the specified leak rate.

All field-assembled joints and interconnecting gas piping shall also be checked for leaks.

5.9.2 Operational tests

All operating mechanisms for the circuit breaker, disconnecting switches, grounding switches, and load break switches shall be checked for proper contact rod alignment and contact travel. All mechanical interlocks shall be tested.

All exterior mechanical position indicators shall be checked for proper adjustment and indication.

The sealed assembly shall be tested to ensure that the moisture content of the SF_6 gas is below the level specified by the manufacturer.

5.9.3 Electrical tests

The GIS grounding connections shall be tested for electrical continuity.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Resistance measurements shall be performed on all the bus connecting joints, circuit breakers, disconnecting switches, grounding switches, and load break switch contacts to verify proper contact alignment.

Because of the inaccessibility to live parts, it is not possible to measure the resistance of individual components. The resistance readings may be for several components in series. The vendor shall supply factory resistance values of the accessible components in series as a base for progressive testing in the field.

5.9.3.1 Dielectric tests

The minimum test procedure shall be a low-frequency (45–200 Hz) conditioning test at voltage levels specified by the manufacturer. The conditioning test shall be followed by a 1 min low-frequency withstand test at 80% of the rated low-frequency withstand of table 1. Other tests can be performed subject to user-manufacturer agreements.

5.9.3.2 Test conditions

Tests shall be made on each phase-to-ground. A three-phase enclosure design shall be tested with the enclosure and the other two phases grounded. Before dielectric tests are initiated, all power transformers, surge arresters, and voltage transformers (if applicable) shall be disconnected. The voltage shall be applied in steps and gradually raised as specified by the manufacturer to the full field test voltage level (see 5.9.3.1).

Occasional flashovers may occur during the conditioning. The acceptability of flashovers during conditioning depends on whether the flashover may have caused damage to an insulator. The likelihood of such damage is dependent on the voltage level, the length of bus duct connected to the voltage source, and the particular design characteristics of the insulator. If the equipment successfully withstands full field test voltage after a conditioning breakdown has occurred, it can generally be expected that no reduction in dielectric strength will occur in service.

Due to the restrictions of the test facilities, it may be necessary to isolate sections of the equipment and test each section separately. To do this may require that portions of the equipment are subjected to more than one test procedure. When the equipment being tested is connected to equipment which is in service, isolation and grounding shall be provided to ensure that the test voltage cannot cause service disruptions.

5.10 Shipment and storage

Each shipping unit shall be provided with impact devices, when applicable. Equipment shall be sealed and protected for outdoor storage.

5.11 Installation

Manufacturers shall provide detailed and specific installation instructions and drawings, and shall have experienced field service personnel available as agreed to between the user and the manufacturer.

5.12 GIS nameplates

Symbols on GIS nameplates shall be in accordance with IEEE Std 315-1975.

Nameplates of the following types shall be furnished in a convenient, central location to provide information for operation and maintenance:

a) One-line diagram nameplate
b) GIS ratings nameplate
c) Equipment nameplate
d) Nameplates for high-voltage cable terminations
e) Gas system nameplate

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

5.12.1 One-line diagram

The one-line diagram nameplate shall show the following:

a) A one-line diagram of the GIS
b) GIS nomenclature
c) Power transformers
d) Circuit breakers
e) Disconnecting switches
f) Interrupter switches (distinguished by interrupting capability)
g) Grounding switches (distinguished by fault closing capability)
h) Surge arresters
i) Voltage transformers
j) Current transformers
k) Cable terminations
l) Air bushings
m) Gas-oil bushings
n) Gas barriers
o) Manufacturer's type and serial number
p) Year of manufacture

When the installation is an expansion of an existing substation, the one-line diagram shall show and identify the existing equipment and the new equipment as specified by the user.

5.12.2 Ratings

The GIS ratings nameplate shall show the following ratings:

a) Maximum continuous voltage

b) System frequency

c) Maximum and minimum ambient temperature

d) Maximum continuous currents (at 40 °C ambient temperature) of equipment for which ratings are not shown on the nameplate described in 5.12.1 (if needed for clarification, current ratings shall be shown on the one-line diagram nameplate)

e) Rated lightning impulse level (BIL)

f) Power frequency for 1 min (factory test)

g) Switching surge (if applicable)

h) Short-circuit currents
   1) Symmetrical interrupting (rms)
   2) Short time (rms)
   3) Close and latch (rms and peak)

i) Total weight of gas at rated density

j) Nominal gas pressure at 20 °C (filling)

k) Recommended minimum operating gas pressure at 20 °C

l) Maximum acceptable gas pressure at 20 °C

m) Recommended moisture limits of gas insulation (ppmv)

n) Auxiliary voltages

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

o) Contract orders

p) Total weight of equipment

q) Alarm and trip pressures

r) Curves for SF_6 showing nominal alarm and filling pressures vs. temperatures

The ratings nameplate shall state to which of the GIS equipment the ratings apply.

5.12.3 Equipment nameplates

Serial numbers and other data that are not common to all units of a category of equipment shall be shown on the nameplates mounted on the equipment itself.

5.12.4 Nameplate for high-voltage cable terminations

The nameplate shall be mounted in a conspicuous location and the following information shall appear on the nameplate, as appropriate:

a) Manufacturer's name, type, and designation number
b) Insulation class (rated maximum voltage)
c) Rated lightning impulse level (BIL)
d) Rated cable fluid pressure
e) Maximum and minimum cable conductor size
f) Maximum and minimum cable insulation diameter
g) Rated switching impulse level (SIVVL)
h) Rated internal (SF_6) gas density (stated in pressure and temperature)
i) Maximum allowable force applied in any direction at the external terminal
j) Voltage tap, capacitance C1 and C2

5.12.5 Insulating gas system

The insulating gas system nameplate shall show the following:

a) Complete gas system
b) Gas density monitors
c) Pressure gauges
d) Interconnections between gas compartments
e) Valves on exterior piping

6. Bibliography

This bibliography consolidates all previous information and updates the entries to early 1993, inclusive. Earlier bibliographies can be found in the following publications:

IEEE Transactions on Power Apparatus and Systems (PA&S), vol. 101, no. 11, Nov. 1982, pp. 4289–4315.

IEEE Transactions on Power Delivery (PWRD), vol. 4, no. 2, Apr. 1989, pp 1003–1020.

IEEE Transactions on PWRD, vol. 8, no. 1, Jan. 1993, pp. 73–82.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Table of Contents

		[B] Entry No.
6.1 Dielectric		1–562
6.1.1	AC, impulse, and time/voltage characteristics	1–47
6.1.2	Basic physics	48–151
6.1.3	Corona and breakdown	152–346
6.1.4	Effects of particles and surface roughness	347–404
6.1.5	Gas decomposition and aging	405–465
6.1.6	Gaseous dielectrics	466–562
6.2 Equipment		563–1249
6.2.1	Station design	563–670
6.2.2	Station installation and operation	671–752
6.2.3	Transmission line design	753–857
6.2.4	Transmission line installation and operation	858–898
6.2.5	Bus/conductor and enclosure	899–914
6.2.6	Circuit breaker	915–1044
6.2.7	Instrument transformers	1045–1053
6.2.8	Insulators and barriers	1054–1116
6.2.9	Isolating and grounding devices	1117–1152
6.2.10	Power transformers, capacitors, and reactors	1153–1175
6.2.11	Surge arresters	1176–1188
6.2.12	Terminations	1189–1199
6.2.13	Equipment design	1200–1237
6.2.14	Bushings	1238–1249
6.3 General		1250–1518
6.3.1	Direct current application	1250–1280
6.3.2	Insulation coordination and surge protection	1281–1346
6.3.3	Gas handling and monitoring	1347–1382
6.3.4	Grounding	1383–1394
6.3.5	Reliability and safety	1395–1423
6.3.6	Testing and maintenance	1424–1518
6.4 Index of authors		pages 115–148

Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

6.1 Dielectric

6.1.1 AC, impulse, and time/voltage characteristics

[B1] Airey, D. R., and Abbott, P. M., "A direct comparison of the interrupter and arc properties of SF_6 and N_2," *IEE Third International Conference on Gas Discharges*, no. 118, pp. 512–516, Sept. 1974.

[B2] Akiyama, H., et al., "Voltage-current characteristics of high-current pulsed discharges in SF_6," *Electrical Engineering in Japan*, vol. 111, no. 3, pp. 29–36, 1991.

[B3] Baron, B., and Gacek, Z., "Computation of electric field distribution inside high voltage metalclad SF_6 buses," *Seventh International Symposium on High Voltage Engineering*, vol. 1, pp. 89–91, 1991.

[B4] Boggs, S. A., and Fujimoto, N., "Techniques and instrumentation for measurement of transients in gas-insulated switchgear," *IEEE Transactions on Electrical Installation*, vol. ET-19, no. 2, pp. 87–92, Apr. 1984.

[B5] Borin, V. N., "Voltage-time characteristics of compressed sulfur hexafluoride discharge," *IEEE Second International Conference on Gas Discharges*, no. 90, pp. 329–331, 1972.

[B6] Borin, V. N., et al., "Characteristics of SF_6 insulation under operating conditions in high-voltage apparatus," *CIGRE*, Paper 15–06, 8 pages, Aug. 1978.

[B7] Chu, F. Y.; Boggs, S. A.; and Law, C. K.; "Studies of power arc faults in SF_6 insulated equipment," *IEEE Power Engineering Society Winter Meeting*, Paper F80 225–3, 7 pages, Feb. 1980.

[B8] Chu, F. Y.; Law, C. K.; and Boggs, S. A.; "Dynamics of power arcs in co-axial electrode geometry," *Second International Symposium on Gaseous Dielectrics*, pp. 418–428, Mar. 1980.

[B9] Cohen, E. H., "The electric strength of highly compressed gases," *Proceedings, IEE*, vol. 103, pt. A, pp.57–68, 1956.

[B10] Cookson, A. H., and Pedersen, B. O., "Thermal measurements in a 1200 kV compressed gas insulated transmission line," *Seventh IEEE Power Engineering Society Transmission and Distribution Conference and Exposition*, Atlanta, Ga., pp. 163–167, Apr. 1979.

[B11] Coufal, O.; Fidler, A.; and Stevanova, M.; "Composition of SF_6 for temperatures up to 6000K and pressures from 0 to 1 MPa," *ACTA Technica, Ceskoslovensk Akademie Ved*. (Czechoslovakia), vol. 30, no. 5, pp.575–584, 1985.

[B12] Cronin, J. C., "Insulation problems in high-voltage gas-insulated apparatus," *IEEE Power Engineering Society Transmission and Distribution Underground Conference*, no. 72-CHO-608-0-PWR (suppl.), pp. 323–325, Jan. 1973.

[B13] Dale, S. J., and Wagenaar L. B., "Voltage-time characteristics of breakdown in SF_6," *Proceedings of the Third International Symposium on Gaseous Dielectrics*, Knoxville, Tenn., pp. 259–266, Mar. 1982.

[B14] Diessner, A. "Studies on Compressed Gas Insulation." Master's thesis, Massachusetts Institute of Technology, 1969.

[B15] Dincer, M. S., and Gokmen, A., "Electrical field breakdown of SF_6 in crossed magnetic fields," *Journal of Physics D: Applied Physics*, vol. 25, no. 6, pp. 942–944, June 14, 1992.

[B16] Dubanton, C., et al., "Performance of metal-clad SF_6 insulated substations under various dielectric stresses," *CIGRE*, Paper 33–08, 11 pages, Aug. 1976.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B17] EPRI, "Study of Gas Dielectrics for Cable Insulation," *EPRI*,Project 7802 and ERDA E(49–18)–1556, Final Report, 153 pages, Oct. 1977.

[B18] Graaf, H. P., et al., "Axially-blown SF_6 arcs around current zero," *Applied Physics B*., vol. B36, no. 1, pp. 33–40, Jan. 1985.

[B19] Hampton, B. F., "SF_6 gas—The new insulator," *Engineering*, pp. 116–118, Feb. 1977.

[B20] Hayashi, H., et al., "Flashover characteristics of SF_6 gas under interphase switching impulse voltages of opposite polarities," *Electrical Engineering in Japan*, vol. 94, no. 1, pp. 72–79, 1974.

[B21] Hidaka, K.; Matsumoto, S.; and Kouno, T.; "Cryoresistive gas insulated line," *Cryogenics*, vol. 30, no. 1, pp. 72–74, Jan. 1990.

[B22] Hirooka, K., and Shirai, M., "Thermal characteristics of SF_6," *Journal Chem. Soc*. (Japan), vol. 2, pp. 165–169,1980.

[B23] Ibuki, K.; Sakuma, S.; and Araki, H.; "Dynamic characteristics of inductive current chopping by SF_6 arc," Proceedings of the Tenth International Conference on Gas Discharges and Their Applications, pp. 184–187,1992.

[B24] Kanno, Y., et al., "The short-circuit electromagnetic force of the three-phase encapsulated gas-insulated bus bar," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 6, pp. 1386–1396, June 1984.

[B25] Kobayashi, S., et al., "Nonuniform electric field flashover characteristics of GIS against very fast transient overvoltages," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 17–20, 1991.

[B26] Murase, H., et al., "Disconnect switch operation," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-104, no. 1, pp. 157–165, Jan. 1985.

[B27] Nitta, T.; Shibuya, Y.; and Fujiwara, Y.; "Voltage-time characteristics of electrical breakdown in SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 94, no. 1, pp. 108–115, Jan./Feb. 1975.

[B28] Noeske, H. O., "Arc thermal recovery speed for various gases and gas mixtures," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 46B–4621, Nov. 1981.

[B29] Pack, S., and Gorablenkow, J., "Measurements on very fast transients propagation in GIS-components," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 51–54, 1991.

[B30] Perkins, J. F., and Frost, L. S., "Dielectric recovery and predicted ac performance of blown SF_6 arcs," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 2, pp. 368–375, Mar./Apr. 1972.

[B31] Perkins, J. F., and Frost, L. S., "Magnetic pumping effect on dielectric recovery of blown SF_6 arcs," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 2, pp. 376–380, Mar./Apr. 1972.

[B32] Pfeiffer, W.; Zimmer, V.; and Zipfl, P.; "Predischarge development and dielectric strength of N_2, SF_6 and SF_6N_2-mixtures in strong non-uniform electrical fields," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 103–106, 1991.

[B33] Rizk, F. A. M., et al., "SF_6 and SF_6-N_2 coaxial cylinder gaps—Impulse breakdown voltage-line curves," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 4460–4471, Dec. 1982.

[B34] Roth, A. W., and Owens, J. B., "Dielectric investigations of components for gas insulated switching stations and conductor systems for extra high voltages," *CIGRE*, Paper 23–03, p. 7, Aug. 1970.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

[B35] Schmidt, W., and Szente-Varga, H. P., "Effects of humidity on the electrical strength of SF_6 gas insulated H. V. equipment," *Canadian Communication and Power Conference*, 2 pages, Nov. 1974.

[B36] Skipper, D. J., and McNeall, P. I., "Impulse-strength measurements on compressed gas insulation for EHV power cables," *Proceedings, IEE*, vol. 112, no. 1, pp. 103–105, Jan. 1965.

[B37] Sudhakar, C. E., and Srivastava, K. D., "Electric field computation from probe measurements of charge on spacers subjected to impulse voltages," *Proceedings of the Fifth International Symposium on High Voltage Engineering*, Braunschweig, West Germany, *IEEE/CIGRE*, vol. 2, p. 33.14/1–4, Aug. 1987.

[B38] Sudhakar, C. E., and Srivastava, K. D., "Surface charge accumulation on spacers in SF_6 insulated systems under switching impulses," *Conference Record of IEEE International Symposium on Electrical Insulation*, Washington, D.C., pp. 221–224, June 1986.

[B39] Takagi, T., et al., "Dielectric strength of SF_6 gas and three-core type CGI cables under inter-phase switching impulse voltages," *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 1, pp. 354–359, Jan./Feb. 1974.

[B40] Takuma, T., and Watanabe, T., "Impulse coronas in long gaps in high-pressure SF_6 gas," *Electrical Engineering in Japan*, vol. 91, no. 2, pp. 167–175, 1971.

[B41] Takuma, T.; Watanabe, T.; and Kita, K.; "Flashover characteristics of compressed SF_6 at very long gaps for various impulse waves," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 6, p. 2262, Nov./Dec. 1972.

[B42] Teich, T. H., and Zaengl, W. S. "The Dielectric Strength of an SF_6 Gap." *In Current Interruption in High Voltage Networks*, edited by K. Ragaller, pp. 269–297. New York: Plenum Press, 1978.

[B43] Torshin, Y. V., "Electrical strength of sulfur hexafluoride at high pressure and at the liquid state," *IEE Third International Conference on Gas Discharges*, no. 118, pp. 389–393, Sept. 1974.

[B44] Wang, You Lin, "An analysis and calculation of quenching properties of SF_6-He," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 87–89, 1991.

[B45] Weck, K. H., and Fischer, A., "Dielectric strength of air and SF_6 insulation under non-standard lightning impulses," *CIGRE SC 33 Colloquium*, 44 pages, June 1975.

[B46] Wohlmuth, M., "Measurement and calculation of lift-off fields and charges for free moving particles," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 414–417, 1992.

[B47] Yashima, M.; Fujinami, H.; and Takuma, T.; "Breakdown characteristics of SF_6 in nonuniform fields under steep-fronted oscillating impulse voltages," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 426–429, 1992.

6.1.2 Basic physics

[B48] Abdel-Salem, A., and Abul-Shohoud, W., "Effect of polarity on the breakdown voltage of gas gaps," *Second International Symposium on Gaseous Dielectrics*, pp. 108–114, Mar. 1980.

[B49] Agostino, R., and Flamm, D. L., "Plasma etching of Si and SiO_2 in SF_6-O_2 mixtures," *Journal of Applied Physics*, vol. 52, no. 1, p. 162, Jan. 1981.

[B50] Airey, D. R., "Axial and radial heat transport in high temperature SF_6 arc," *Journal of Physics D.*, vol. 12, 1979.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B51] Airey, D. R., "Simple convection-loss dominated model for optically-thick SF_6 arcs," *Proceedings, IEE*, vol. 125, no. 8, pp. 770–775, Aug. 1978.

[B52] Airey, D. R.; Richards, P. H.; and Swift, J. D.; "Anomalous electrical conductivity enhancement in very high current SF_6 arcs," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 8–11, Sept. 1976.

[B53] Airey, D. R.; Richards, P. H.; and Swift, J. D.; "Spectroscopic analysis and core formation in high current, gas flow stabilized SF_6 arcs," *IEE Third International Conference on Gas Discharges*, no. 118, pp. 488–492, Sept. 1974.

[B54] Airey, D. R., and Urwin, R. J., "Energy balance of a high current SF_6 interrupter arc," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 63–66, Sept. 1976.

[B55] Allied Corporation, "Sulphur Hexafluoride," Technical Bulletin, 1984.

[B56] Ashbaugh, P. G.; McAdam, D. W.; and James, M. F.; "SF_6—Its properties and uses as a gaseous insulator in Van der Graaf accelerators," *IEEE Transactions on Nuclear Science*, vol. NS-12, p. 266, June 1965.

[B57] ASTM D2685-84, Test Method for Nitrogen and Carbon Tetrafluoride in Sulfur Hexafluoride by Gas Chromatography.

[B58] Babcock, L. M., and Streit, G. E., "Ion molecule reactions of SF_6: Determination of I.P., A.P., and D(SF_5-F)," *Journal of Chem. Phys.*, vol. 74, no. 10, p. 5700, May 1981.

[B59] Baker, A., et al., "Study or arc by-products in gas-insulated equipment," *EPRI*, Report EL-1646, Dec. 1980.

[B60] Beaty, E.; Dutton, J.; and Pitchford, L.; "Electron swarm data relevant to high voltage insulation," *Second International Symposium on Gaseous Dielectrics*, pp. 25–31, Mar. 1980.

[B61] Bernard, G., "Electric faults mastery in high voltage SF_6-insulated substations," *Revue Generale de l'Electricite*, no. 4, pp. 231–249, Apr. 1982.

[B62] Bhalla, M. S., and Craggs, J. D., "Measurement of ionization and attachment coefficients in sulfur hexafluoride in uniform fields," *Proceedings of the Physical Society*, vol. 80, pp. 151–160, 1962.

[B63] Binns, D. F., and Daragan, C. L., "Statistical time lags in mixtures of SF_6 and air," *British Journal of Applied Physics*, vol. 16, pp. 181–183, 1965.

[B64] Binns, D. F., and Hood, R. J., "Breakdown in sulfur hexafluoride and nitrogen under direct and impulse voltages," *Proceedings, IEE*, vol. 116, no. 11, pp. 1962–1968, Nov. 1969. Correspondence, vol. 117, no. 5, pp. 1055–1056, May 1970.

[B65] Binns, D. F., and Mansoor, E F., "Breakdown in a horizontal gas-filled duct containing a heated bus bar," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 67–70, Sept. 1976.

[B66] Blair, D. T. A.; Macleod, N. M.; and Orr, J. S.; "Radiation from gases in the vacuum ultra-violet range," *IEE Third International Conference on Gas Discharges*, no. 118, pp. 68–72, Sept. 1974.

[B67] Blair, D. T. A.; Macleod, N. M.; and Orr, J. S.; "Radiation in the vacuum ultraviolet from discharges in gas mixtures," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 401–403, Sept. 1976.

[B68] Boeuf, J. P., et al., "Calculations of transport parameters in SF_6 for a non-equilibrium medium by Monte Carlo and Boltzmann methods," *Proceedings of the Seventh International Conference on Gas Discharges and Their Applications*, pp. 347–349, Sept. 1982.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B69] Bortnik, I. M., and Cooke, C. M., "Electrical breakdown and the similarity law in SF_6 at extra high voltages," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 5, pp. 2196–2203, Sept./Oct. 1972.

[B70] Bott, J. F., and Jacobs, T. A., "Shock tube studies of SF_6," *Journal of Chem. Phys.*, vol. 50, pp. 3850–3855, 1969.

[B71] Boyd, H. A., and Crichton, G. C., "Measurements of ionization and attachment coefficient in SF_6," *Proceedings, IEE*, vol. 118, no. 12, pp. 1872–1877, Dec. 1971.

[B72] Browne, T. E., Jr., and Strom, A. P., "Interruption of capacitance charging currents in sulfur hexafluoride," *AIEE Transactions*, vol. 75, pt. 3, pp. 1357–1361, 1956.

[B73] Camilli, G., and Chapman, J. J., "Gaseous insulation for high-voltage apparatus," *AIEE Transactions*, vol. 66, pp. 1463–1470, 1947.

[B74] Camilli, G.; Liao, W.; and Plump, R. E.; "The dielectric behavior of some fluorogases and their mixtures," *AIEE Transactions*, vol. 74, pt. 1, pp. 637–642, Nov. 1955.

[B75] Castonguay, J.; Theoret, A.; and Gilbert, R.; "Arc degradation of SF_6 in the presence of polymeric materials," *IEEE International Symposium on Electrical Insulation*, no. 78CH1287-2-EI, pp. 162–166, June 1978.

[B76] Chalmers, I. D., et al., "Leader development in short point plane gaps in compressed SF_6," *IEE, Proceedings A* (G.B.), vol. 131, no. 3, pp. 159–163, May 1984.

[B77] Cherneera, L. I., et al., "Investigating the properties of sulfur hexafluoride (SF_6)," *Power Engineering*, vol. 21, no. 4, pp. 95–102, 1983.

[B78] Christophorou, L. G., *Electron-Molecule Interactions and Their Applications*. Academic Press, 1984.

[B79] CIGRE, Discussion "Group 15, Insulating materials," *CIGRE*, vol. 1, 48 pages, 1976.

[B80] Compton, R. N.; Reinhardt, P. W.; and Cooper, C. D.; "Collisional ionization between fast alkali atoms and selected hexafluoride molecules," *Journal of Chem. Phys.*, vol. 68, no. 5, p. 2023, Mar. 1978.

[B81] Cooke, C. M., and Cookson, A. H., "The nature and practice of gases as electrical insulators," *IEEE Transactions on Electrical Insulation*, vol. EI-13, no. 4, pp. 239–248, Aug. 1978.

[B82] Craggs, J. D., and Meek, J. M., "Electrical discharges in SF_6," *International Conference on Gas Discharges and the Electricity Supply Industry*, pp. 338–347, 385–389, 1962.

[B83] Crichton, B. H.; Tedford, D. J.; and Chalmers, P.; "The temporal growth of ionization in long uniform field gaps in air and sulphur hexafluoride," *IEE Third International Conference on Gas Discharges*, no. 118, pp. 100–104, Sept. 1974.

[B84] Davidson, J. C., "Charge movement on dielectric surfaces in high pressure gases," *IEE Colloquium on Breakdown and Discharge Phenomena on Insulating Surfaces in Gas Media and Vacuum*, Digest no. 1975/26, pp. 2/1–2/4, Nov. 1975.

[B85] Dincer, M. S., and Raju, G. R., "Monte Carlo simulation of the motion of electrons in SF_6 in uniform electric field," *Journal of Applied Physics*, vol. 54, no. 11, p. 6311, 1983.

[B86] Dudukovic, P R., "Conduction in SF_6 at high electrical stress-coffespondence," *Proceedings, IEE*, vol. 117, no. 12, pp. 2333–2335, Dec. 1970.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B87] Dutton, J., "The basic physics of gaseous dielectrics," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 2–27, Mar. 1978.

[B88] Dutton, J.; Harris, F. M.; and Jones, G. J.; "Departures from Paschen's Law for sulfur hexafluoride," *Proceedings, IEE*, vol. 118, no. 5, pp. 732–733, May 1971.

[B89] Edelson, D., et al., "Electrical decomposition of SF_6," *Industrial and Engineering Chemistry*, vol. 45, pp. 2094–2096, Sept. 1953.

[B90] Erme, M., "Electron emission currents in compressed SF_6 in the coaxial cylindrical field," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 191–194, Sept. 1976.

[B91] Fehsenfeld, F. C., "Electron attachment to SF_6," *Journal of Chem. Phys.*, vol. 53, no. 5, p. 2000, 1970.

[B92] Finer, E. G., and Harris, R. K., "High resolution nuclear magnetic resonance spectroscopy of pentafluorosulphur compounds 3," *Spectrochimica Acta.*, Pergamon Press, vol. 24A, 1968, p. 1939.

[B93] Frost, L. S., and Lieberman, R. W., "Composition and transport properties of SF_6 and their use in a simplified enthalpy flow arc model," *Proceedings, IEEE*, vol. 59, no. 4, pp. 474–484, Apr. 1971.

[B94] Fukuda, S., et al., "Recent studies on arc behaviors around current zero in SF_6 gas," *CIGRE*, Paper 13-03, 10 pages, June 1968.

[B95] Garzon, R. D., "The effects of SF_6-N_2 mixture upon the recovery voltage capability of a synchronous interrupter" *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 1, pp. 140–144, Jan./Feb. 1976.

[B96] "Gases for EHV insulation," *Electrical Review*, vol. 178, no. 1, pp. 132–134, Jan. 28, 1966.

[B97] Howard, P. R., "Insulation properties of compressed electronegative gases," *Proceedings, IEE*, vol. 104, pt. A, pp. 123–138, 1957.

[B98] Hudis, M., "Arc recovery measurements in sonic flow fluorocarbon gas arcs." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 4, p. 1020, July/Aug. 1974.

[B99] Inaba, T., "Analytical similarity between stabilized arc characteristics and transport properties in gases," *IEE Third International Conference on Gas Discharges*, no. 118, pp. 28–31, Sept. 1974. Also published in *Electrical Engineering in Japan*, vol. 94, no. 2, p. 1/7, 1974.

[B100] Kinsinger, R. E., and Noeske, H. O., "Relative arc thermal recovery speeds in different gases," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 24–28, Sept. 1976.

[B101] Knudsen, N. H., "Experimental investigation concerning influence of electron emission on the withstand performance of SF_6 gaps," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-104, no.2, pp. 454–457, Feb. 1985.

[B102] Kopainsky, J., and Schade, E., "Investigation of a rotating, magnetically-driven SF_6 arc," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 83–85, Sept. 1976.

[B103] Krenck, R, "Ionization equilibrium and electrical conductivity of partially ionized gases in a strong and time-dependent electrical field, and the application to SF_6," *Acta Tech CSAV* (Czechoslovakia), vol. 29, no.6, pp. 722–750, 1984.

[B104] Lann, J. S., "Review of properties and applications of currently available fluorocarbon dielectric gases," *Doble Client Conference*, sec. 10, pp. 501–507, Apr. 1976.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

[B105] Lawrence, R. C.; Doctor, S. R.; and Martin, E. C.; "Development of radiographic parameters for evaluation of energized compressed gas-insulated systems," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 380–381, Mar. 1978.

[B106] Le Ny, R.; Charrier, J.; and Boulloud, A.; "Simple models in room air simulating the influence of conducting microrugosity of the electrodes on the breakdown voltage in compressed gases," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 121–124, Sept. 1976.

[B107] Leadon, R. E., et al., "Effect of ambient gas on arc initiation characteristics in soil," *IEEE Transactions on Nuclear Science* (U.S.), vol. NS-30, no. 6, pp. 4572–4576, Dec. 1983.

[B108] Lee, Z. Y, "Time resolved observation of electron swarms in SF_6-CO_2 mixtures," *1984 Annual Report of the Conference on Electrical Insulation and Dielectric Phenomena*, Claymont, Del., pp. 381–386, Oct. 1984.

[B109] Leeds, W. M.; Browne, T. E., Jr.; and Strom, A. P.; "The use of SF_6 for high power arc quenching," *AIEE Transactions on Power Apparatus and Systems*, vol. 74, pt. 3, pp. 906–909, 1957.

[B110] Lingal, H. J.; Strom, A. P.; and Browne, T. E., Jr.; "Investigation of arc-quenching behavior of sulfur hexafluoride," *AIEE Transactions*, vol. 72, pt. 3, pp. 242–246, Apr. 1953.

[B111] Luxa, G., et al., "Paschen curve for sulfur hexafluoride (SF_6)," *CIGRE, Electra*, no. 32, pp. 75–82, Jan.1974.

[B112] Lyman, J. L., "A model for unimolecular reaction in SF_6," *Journal of Chem. Phys*., vol. 68, p. 1868, Sept. 1977.

[B113] Manion, J. P.; Philosophos, J. A.; and Robinson, M.; "Arc stability of electronegative gases," *IEEE Transactions on Electrical Insulation*, vol. 2, pt. 1, 1967.

[B114] McGeehan, J. P., et al., "Negative ion/molecule reactions in SF_6," *Journal of Physics D*., vol. 8, p. 153, 1975.

[B115] Mears, W. H.; Rosenthal, E.; and Sinka, J. V.; "Physical properties and virial coefficients of sulfur hexafluoride," *Journal of Physical Chemistry*, vol. 73, no. 7, pp. 2254–2261, July 1969.

[B116] Misaki, T., et al., "Techniques for charge simulation analysis of three-dimensional field distribution in SF_6 gas-insulated cables," *IEEE Power Engineering Society Winter Meeting*, Paper A80 056-2, 1 page, Feb. 1980.

[B117] Miyamoto, T., and Kamatani, A., "Application of a time-resolved-type panoramic mass spectrometer to the studies of arc-quenching reactions in SF_6 gas," *Electrical Engineering in Japan*, vol. 85, no. 4, pp. 30–39, 1965.

[B118] Murano, M., et al., "Heavy current clogging phenomena in SF_6 gas arc." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 5, p. 1735, Nov./Dec. 1974.

[B119] Nabuaki, K.; Matsuura, K.; and Natsume, F.; "Fundamental technologies of SF_6 gas-insulated switchgear," *Fuji Elect. Review*, vol. 30, no. 2, pp. 67–73, 1984.

[B120] Narbut, P., et al., "Factors controlling electric strength of gaseous insulation," *AIEE Transactions on Power Apparatus and Systems*, vol. 78, pt. 3A, pp. 545–550, Aug. 1959.

[B121] Nitta, T., "Time dependence of breakdown voltage and endurance testing of compressed gas insulation," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3055–3065, June 1981.

[B122] Noto, F.; Yoshimura, N.; and Shindo, H.; "Effects of void gas on the growth of trees," *Electrical Engineering in Japan*, vol. 91, no. 3, pp. 58–65, 1971.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B123] Okabe, S., and Kouno, T., "Experimental and theoretical investigations of flashover properties of SF_6 and $CC1_2F_2$ gas mixtures," *Japan Journal of Applied Physics* (Japan), vol. 24, pt. 1, no. 7, pp. 836–842, July 1984.

[B124] Pai, R. Y, and Garrity, T. F., "Basic discussion panel—Summary," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 414–427, Mar. 1978.

[B125] Pedersen, A., and Munk-Nielsen, T., "Time lags in SF_6 in a uniform field gap," *IEE Third International Conference on Gas Discharges*, no. 118, pp. 105–108, Sept. 1974.

[B126] Perkins, J. F., and Frost, L. S., "Enthalpy-flow limitation of gas-blasted SF_6 arcs," *Proceedings, IEE*, vol. 118, no. 7, pp. 948–954, July 1971.

[B127] Philosophos, J. A., and Robinson, M., "Voltage recovery characteristics of electronegative gases," *Insulation/ Circuits*, p. 42, Apr. 1970.

[B128] Rapp, D., and Englander-Golden, P., "Ionization by electron impact," *Journal of Chem. Phys.*, vol. 43, p. 1464, 1965.

[B129] Rein, A.; Arnesen, A.; and Johansen, I.; "A statistical approach to the streamer breakdown criterion in SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 96, no. 4, pp. 945–954, May/June 1977.

[B130] Ryan, H. M.; Lightle, D.; and Milne, D.; "Factors influencing dielectric performance of SF_6-insulated GIS," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-104, no. 6, pp. 1527–1535, June 1985.

[B131] Sakakibara, T., et al., "The application of charge simulation method to three dimensional asymmetric field with two dielectric media," *Second International Symposium on Gaseous Dielectrics*, pp. 312–322, Mar. 1980.

[B132] Schemmann, B., "SF_6 and vacuum combined to provide 'constant climate,'" *Electr. Rev.* (G.B.), vol. 215, no. 5, pp. 24–26, Sept. 1984.

[B133] Schmidt, W., et al., "Ionic and electronic processes in sulfur hexafluoride," *Second International Symposium on Gaseous Dielectrics*, pp. 1–11, Mar. 1980.

[B134] Schweinler, H. C., and Christophorou, L. G., "Calculation of electric field-induced detachment rate of electrons from mononegative ions: Relevance to gaseous dielectrics," *Second International Symposium on Gaseous Dielectrics*, pp. 12–24, Mar. 1980.

[B135] Siegel, B., and Breisacher, P., "Oxidation of SF_6," *Journal of Inorganic and Nuclear Chemistry*, vol. 31, pp. 675–683, 1969.

[B136] Swanson, B. W., and Roidt, R. M., "Boundary layer analysis of an SF_6 circuit breaker arc," *IEEE Transactions on Power Apparatus and Systems*, vol. 90, no. 3, pp. 1086–1093, May/June 197 1.

[B137] Swanson, B. W., and Roidt, R. M., "Some numerical solutions of the boundary layer equations for an SF_6 arc," *Proceedings, IEEE*, vol. 59, no. 4, pp. 493–501, Apr. 1971.

[B138] Swanson, B. W.; Roidt, R. M.; and Browne, T. E., Jr.; "Effects of gas dynamics and properties of SF_6 and air on short line fault interruption," *IEEE Transactions on Power Apparatus and Systems*, vol. 89, no. 6, pp. 2033–2042, Nov./Dec. 1970.

[B139] Takuma, T., "Discharge mechanism of gases and its application to calculation of flashover voltages of sphere gaps in the atmospheric air," *Electrical Engineering in Japan*, vol. 91, no. 1, pp. 63–72, 1971.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B140] Takuma, T., "Electric field calculations in configurations containing volume or surface resistance: Charge simulation method with complex fictitious charges," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 4666–4673, Nov. 1981.

[B141] Takuma, T., and Watanabe, T., "Comparison between gas insulation and atmospheric air insulation," *Electrical Engineering in Japan*, vol. 90, no. 6, pp. 227–234, 1970.

[B142] Takuma, T., and Watanabe, T., "Discharge characteristics of long gaps in high-pressure SF_6 gas," *Electrical Engineering in Japan*, vol. 90, no. 3, pp. 166–176, 1970.

[B143] Takuma, T., and Watanabe, T., "Theoretical analysis of discharge characteristics in high-pressure SF_6 gas," *Electrical Engineering in Japan*, vol. 90, no. 4, pp. 26–33, 1970.

[B144] Teich, T. H., and Branston, D. W., "Time resolved observation of ionization and electron detachment in SF_6," *IEE Third International Conference on Gas Discharges*, no. 118, pp. 109–113, Sept. 1974.

[B145] Trump, J. G., "Compressed gas insulation and electric power systems," *International Conference on Gas Discharges and the Electricity Supply Industry*, pp. 348–356, 1952.

[B146] Wilkins, R. L., *Theoretical Evaluation of Chemical Propellants*. Prentice-Hall, 1963, p. 100.

[B147] Wock, S., "Comments on the toxicity of SF_6 insulating gas (by A. Van Roggen, et. al.)," *IEEE Transactions on Electrical Insulation*, vol. EI-19, no. 2, p. 156, Apr. 1984.

[B148] Wootton, R. E., and Chantry, R J., "A critique of methods for calculating the dielectric strength of gas mixtures and a proposed test for N-synergism," *Second International Symposium on Gaseous Dielectrics*, pp. 32–42, Mar. 1980.

[B149] Yamada, N., and Fujiwara, Y., "Area effects of electrical breakdown in compressed SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 2, pp. 623–629, Mar./Apr. 1974.

[B150] Yoon, K. H., and Spindle, H. E., "A study of the dynamic response of arcs in various cases," *AIEE Transactions on Power Apparatus and Systems*, vol. 17, pt. 3, pp. 1634–1642, Feb. 1959.

[B151] Zalesskii, A. M.; Ziber, K.; and Poltev, A. I.; "Some studies of discharge voltages in air and SF_6," *Electric Technology*, vol. 4, no. 10–12, pp. 96–105, 1967.

6.1.3 Corona and breakdown

[B152] Abdel-Salam, M.; Radwan, R.; and Ali, K.; "Analysis of positive static corona-stabilized breakdown voltage of SF_6—Part 1: Rising voltage-pressure characteristics." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 1, p. 11, Jan./Feb. 1979. Paper presented at *IEEE Power Engineering Society Summer Meeting*, Paper A 77 646-3, July 1977.

[B153] Akbar, M., "Electric breakdown of N_2O-SF_6, N_2O-$CC1_2F_2$ and N_2OCO_2 gas mixtures," *IEEE Transactions on Electrical Insulation*, vol. EI-20, no. 3, pp. 581–585, June 1985.

[B154] Anis, H., "Particle-initiated breakdowns in compressed gas-insulation under time-varying voltages," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3694–3702, Aug. 1981.

[B155] Anis, H.; Bakos, J. S.; and Soerlei, Z.; "Coordination of multi-path insulation in gas-insulated transmission lines," *Proceedings of the 17th International Conference on Phenomena in Ionized Gases*, Budapest, Hungary, vol. 2, pp. 546–548, July 1984.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B156] Anis, H., and Srivastava, K. D., "Pre-breakdown discharges in highly non-uniform fields in relation to gas-insulated systems," *IEEE Transactions on Electrical Insulation*, vol. EI-16, no. 2, pp. 131–142, Apr. 1982.

[B157] Antonov, A. V.; Lyapin, A. G.; and Popkov, V. I.; "Dielectric strength of sulphur hexafluoride upon condensation," *Power Eng*. (J. Acad. Sci., USSR), vol. 21, no, 6, pp. 91–95, 1983.

[B158] Azer, A. A., and Comsa, R. P., "Influence of field non-uniformity on the breakdown characteristics of SF_6," *IEEE Transactions on Electrical Insulation*, vol. 8, no. 4, pp. 136–142, Dec. 1973.

[B159] Baumgartner, R., et al., "Partial discharge (PD) in gas-insulated substations—Fundamental considerations," *IEEE Electrical Insulation Magazine*, vol. 7, no. 6, pp. 5–13, 1991.

[B160] al-Bawy, I., and Farish, O. "Insulator flashover in SF_6 under impulse voltage conditions," *IEE Proceedings—Part A: Physical Science, Measurement and Instrumentation, Management and Education, Reviews*, vol. 138, no. 1, pp. 89–97, Jan. 1991.

[B161] Berg, D., and Works, C. N., "Effect of space charge on electric breakdown of SF_6 in nonuniform fields," *AIEE Transactions*, vol. 77, pt. 3, pp. 820–823, Oct. 1958.

[B162] Binns, D. F., and Mansoor, F. E, "Breakdown characteristics for a heated busbar in a gas-filled duct," *IEEE Power Engineering Society Winter Meeting*, Paper F 78 209-9, Jan. 1978.

[B163] Blackburn, T. R.; Li, Z. Z.; and Phung, B. T.; "Investigation of partial discharges in SF_6 using a computer-based data acquisition system," *IEEE Transactions on Electrical Insulation,* vol. 27, no. 3, pp. 661–668,1992.

[B164] Blackburn, T. R.; Li, Z. Z.; and Phung, B. T.; "Investigations of corona discharge in SF_6 using a computer-based data acquisition system," *IEEE Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials,* vol. 2, pp. 1214–1217, 1991.

[B165] Boggs, S. A., "Electromagnetic techniques for fault and partial discharge location in gas-insulated cables and substations," *IEEE Transactions on Power Apparatus and Systems,* vol. PAS-101, no. 7, pp. 1935–1941, July 1982.

[B166] Bortnik, I. M., and Vertikov, V. P., "Some special features of volt-second characteristics of discharge in SF_6," *Electric Technology,* vol. 4, pp. 59–69, 1979.

[B167] Boyd, H. A., and Crichton, G. C., "Uniform field breakdown—Voltage measurements in sulfur hexafluoride," *Proceedings, IEE,* vol. 119, no. 2, pp. 275–276, Feb. 1972.

[B168] Braun, J. M., et al., "Modulation of partial discharge activity in GIS insulators by x-ray irradiation," *IEEE Transactions on Electrical Insulation,* vol. 26, no. 3, pp. 460–468, Feb. 1972.

[B169] Bui, A., et al., "Dielectric breakdown of sulfur hexafluoride gas under high pressure," *Second International Conference on Power Cables and Accessories,* IEE, London, pp. 189–190, Nov. 1986.

[B170] Castonguay, J., "Kinetics of the arc decomposition of SF_6-gas mixtures," *Proceedings of the IEE International Symposium on Electrical Insulation,* 1980.

[B171] Castonguay, J., and Larocque, R., "Low cost technique for field analysis of SF_6 decomposed by-products," *Proceedings of the International Symposium on Gas-Insulated Substations,* Sept. 1985.

[B172] Castonguay, J.; Theoret, A.; and Gilbert, R.; "Arc degradation of SF_6 in the presence of polymeric insulating materials," *Proceedings of the IEEE International Symposium on Electrical Insulation,* 1978.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

[B173] Centurioni, L., et al., "Behaviour of polymeric insulating materials exposed to arced SF_6," *Proceedings of the Fourth International Symposium on High Voltage Engineering,* Athens, Greece, Sept. 1983.

[B174] Chakrabarti, A. K.; van Heeswijk, R. G.; and Srivastava, K. D.; "Free particle-initiated 60 Hz breakdown at a spacer surface in a gas-insulated bus," *IEEE Transactions on Electrical Insulation,* vol. 24, no. 4, pp. 549–560, Aug. 1989.

[B175] Chalmers, I. D., and Thom, J., "Conditioning effects in pressurized spark gaps," *IEE Fourth International Conference on Gas Discharges,* no. 143, pp. 166–168, Sept. 1976.

[B176] Chee-Hing, D. J. "Electrical Breakdown of Sulphur Hexafluoride Gas between Dielectric Coated Electrodes under dc and Impulse Voltages." Master's thesis, University of Waterloo, Ontario, 1974.

[B177] Chu, F. Y, "Arc behavior in SF_6-insulated equipment and effect of arc motion on damage," *IEEE Transactions on Power Apparatus and Systems,* vol. T-PAS, pp. 114–120, Jan. 1981.

[B178] Chu, F. Y, "Experience with solid arcing by-products in SF_6 insulated equipment," *Transmission and Distribution,* pp. 54–58, Apr. 1981.

[B179] Chu, F. Y, "Fault analysis in gas-insulated equipment," *EPRI,* Final Report EL-2248, Feb. 1982.

[B180] Chu, F. Y., et al., "Effects of power arc faults in gas-insulated substations," *Proceedings of the CIGRE Symposium on High Current in Power Systems,* Brussels, 1985.

[B181] Chu, F. Y.; Ford, G. L.; and Law, C. K.; "Estimation of burn-through probability in SF_6-insulated substations," *IEEE Transactions on Power Apparatus and Systems,* vol. PAS-101, no. 6, pp. 1391–1399, June 1982.

[B182] Chu, F. Y., and Law, C. K., "Effects of power arc faults in gas-insulated equipment," *Proceedings of the Sixth International Conference on Gaseous Discharges,* Edinburgh, Ill., IEEE Publication 189, 1980.

[B183] Chu, F. Y.; Stuckless, H. A.; and Braun, J. M. "Generation and Effects of Low Level Contamination in SF_6-Insulated Equipment." In *Gaseous Dielectrics IV* edited by L. G. Christophorou and M. O. Pace, pp. 462–472. Pergamon Press, 1984.

[B184] Cookson, A. H., "Electrical breakdown for uniform fields in compressed gases," *Proceedings, IEE,* vol. 117, no. 1, pp. 269–280, Jan. 1970.

[B185] Cookson, A. H., and Mastroianni, M. J., "Electrical breakdown studies of SF_6CO_2 fluorocarbon mixtures," *Proceedings of the Second International Symposium on Gaseous Dielectrics,* Knoxville, Tenn., pp. 169–178, Mar. 1980.

[B186] Cookson, A. H., and Pedersen, B. O., "High voltage performance of mixtures of SF_6 with N_2, air and CO_2 in compressed-gas-insulated equipment," *Fifth International Conference on Gas Discharges,* IEE, Liverpool, U.K., pp. 161–164, Sept. 1978.

[B187] Cookson, A. H., and Wootton, R. E., "AC corona and breakdown characteristics for rod gaps in compressed hydrogen, SF_6 and hydrogen-SF_6 mixtures," *IEEE Transactions on Power Apparatus and Systems,* vol. 97, pp. 415–423, Mar./Apr. 1978.

[B188] Dale, S. J., and Cookson, A. H., "Impulse breakdown of corrugated coaxial electrodes in compressed SF_6," *Proceedings of the Second International Symposium on Gaseous Dielectrics,* Knoxville, Tenn., pp. 179–189, Mar. 1980.

[B189] Dodds, J. J., "Moisture measurements in GIS," *Doble Client Conference,* Boston, Mass., 1985.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B190] Dunz, Th.; Niemeyer, L.; and Riquel, G. “The Effect of Leader Propagation on the V-T Curves Under LI and VFT in GIS.” In *Gaseous Dielectrics VI,* 1991, pp. 255–260.

[B191] Dutton, J.; Harris, F. M.; and Hughes, D. B.; “Electrical breakdown on N_2O, SF_6 and N_2O/SF_6 mixtures,” *Proceedings, IEE,* vol. 121, no. 3, pp. 223–226, Mar. 1974.

[B192] EPRI, “Superposition gas breakdown,” *EPRI,* Report EL- 1484, Aug. 1980.

[B193] Farish, O., “Breakdown in SF_6 and its mixture in uniform and non-uniform fields,” *International Symposium on Gaseous Dielectrics,* no. CONF-780301, pp. 60–83, Mar. 1978.

[B194] Farish, O., and al-Bawy, I. “Impulse Surface Charging and Flashover.” In *Gaseous Dielectrics VI,* 1991, pp. 305–310.

[B195] Farish, O.; Dale, S. J.; and Sletten, A. M.; “Impulse breakdown of negative rod-plane gaps in hydrogen and hydrogen-SF_6 mixtures,” *IEEE Transactions on Power Apparatus and Systems,* vol. 97, no. 1, pp. 118–124, Jan./Feb. 1978.

[B196] Farish, O.; Dale, S. J.; and Sletten, A. M.; “Impulse breakdown of positive rod-plane gaps in hydrogen and hydrogen-SF_6 mixtures,” *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 5, pp. 1639–1647, Sept./ Oct. 1976.

[B197] Felsenthal, P., and Proud, J. M., “Nanosecond pulse breakdown in gases,” *Physical Review*, vol. 139, no. 6A, pp. A1796–A1804, Sept. 13, 1965.

[B198] Foord, T. R., “Some experiments on positive point-to-plane corona and spark breakdown of compressed gases,” *Proceedings, IEE*, vol. 100, pt. 11, no. 78, p. 585, 1953.

[B199] Frees, L. C., et al., “Positive ions in spark breakdown or SF_6,” *Journal of Physics D: Applied Physics*, vol. 14, pp. 1629–1642, 1981.

[B200] Frost, L. S., and Lieberman, R. W., “Compositions and transport properties of SF_6 and their use in a simplified enthalphy flow arc model,” *Proceedings, IEEE*, vol. 59, pp. 474–484, 1971.

[B201] Fujinami, H., and Kuffel, E. “Breakdown Characteristics of Non-Uniform Gaps in SF_6 Under Fast Oscillating Impulse Voltages.” In *Gaseous Dielectrics VI*, 1991, pp. 247–252.

[B202] Fukuda, S., et al., “Recent studies on arc behavior around current zero in SF_6 gas,” *CIGRE*, Paper 13-03, 1968.

[B203] George, D. W., and Richards, P. H., “Electrical breakdown in sulphur hexafluoride,” *British Journal of Applied Physics*, vol. 2, pp. 1470–1471, 1969.

[B204] Giesselmann, G.; Pfeiffer, W.; and Wolf, J.; “Nanosecond pulsed breakdown of N_2 and SF_6,” *1984 Annual Report of the Conference on Electrical Insulation and Dielectric Phenomena*, Claymont, Del., pp. 434–438, Oct. 1984.

[B205] Ginno, M., et al., “Heat transfer characteristics of gas-insulated transmission lines,” *IEEE Transmission Power Delivery*, vol. PWRD-1, no. 1, pp. 2–9, Jan. 1986.

[B206] Gockenback, E., “Influence of pre-existing dc voltage on the breakdown performance of SF_6 under impulse voltage,” *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 138–149, Mar. 1978.

[B207] Goldman, M., and Goldman, A. “Corona Discharges.” In *Gaseous Electronics*, vol. 1, p. 219. Academic Press, 1978.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B208] Griffin, G. D., et al. "Disulfur decafluoride (S_2F_{10}): A Review of the Biological Properties and Our Experimental Studies of This Breakdown Product of SF_6." In *Gaseous Dielectrics VI*, 1991, pp. 545–551.

[B209] Hamouda, E. A.; Gabris, F.; and Chatterton, P. A.; "Electric field probe and breakdown voltage measurements using impulse voltage in SF_6 and SF_6/N_2 mixtures at pressures up to eight bar," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 382–384, Mar. 1978.

[B210] Hampton, B. F., and Gregory, H., "Effect of discharge energy on switching surge breakdown in SF_6," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 79–82, Sept. 1976.

[B211] Hara, M.; Lee, H. H.; and Egashira, T.; "Effect of electrode shape on particle-initiated breakdown in SF_6 gas under dc voltage," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 1, pp. 156–170, Feb. 1991.

[B212] Hazel, R. L., and Kuffel, E., "Static field anode corona characteristics in sulphur hexafluoride," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 1, pp. 178–186, Jan./Feb. 1976.

[B213] Hickman, W. M., and Berg, D., "Negative ion formation and electric breakdown in some halogenated gases," *Journal of Chem. Phys.*, vol. 29, no. 3, p. 517, 1958.

[B214] Hiesinger, H. "The Calculation of Leader Propagation in Point/Plane Gaps Under Very Fast Transient Stress." In *Gaseous Dielectrics VI*, 1991, pp. 129–134.

[B215] Honda, M., et al., "Deterioration of Epoxy Mold Insulations Due to Voltage Endurance," *Gaseous Dielectrics III*, edited by L. G. Christophorou, pp. 322–326. Pergamon Press, 1982.

[B216] Ibrahim, O. E., and Farish, O., "Impulse breakdown and prebreakdown corona processes in SF_6 and SF_6/N_2 mixtures," *Second International Symposium on Gaseous Dielectrics*, pp. 83–91, Mar. 1980.

[B217] Ichikawa, K.; Arai, K.; and Guoxiang, X. "Corona Discharge Phenomena in GIL and Its Detection Method." *In Memoirs of the Faculty of Engineering*, pp. 235–243. Kobe University, Japan, Nov. 1989.

[B218] Ishii, T., et al. "Non-Uniform Field Flashover Characteristics in SF_6 Gas Under Negative Steep Front and Oscillating Impulse Voltages." In *Gaseous Dielectrics VI*, 1991, pp. 239–245.

[B219] Jarmula, J., "Effect of SF_6 and its by-products evolved by electric arc on metals and insulating materials," *Proceedings, Inst. Electrotechnichy* (Poland), vol. 23, no. 88, pp. 97–102, 1975.

[B220] Johansen, I., et al., "Voltage-time characteristics and area effect of breakdown in SF_6," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 150–161, Mar. 1978.

[B221] Karlsson, P. W., and Pedersen, A., "Inherent limitation in uniform field discharge data for SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 4, pp. 1597–1601, July/Aug. 1972.

[B222] Kawaguchi, Y.; Sakata, K.; and Menju, S.; "Dielectric breakdown of sulphur hexafluoride in nearly uniform fields," *IEEE Transactions on Power Apparatus and Systems*, vol. 90, no. 3, pp. 1072–1078, May/June 1971.

[B223] Kawasaki, T., et al., "Localization of partial discharges using time difference of arrival of radiation fields," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials, IEEE*, vol. 2, pp. 910–914, 1991.

[B224] Khalaffala, K., and Kuffel, E., "Breakdown of high voltage gas-filled cable insulation under switching surge voltages," *IEEE Winter Power Meeting*, Paper 71CP190-PWR, Feb. 1971.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B225] Khalaffala, K., and Kuffel, E., "Breakdown voltage-frequency characteristics of gas-filled cable joints," *IEEE Winter Power Meeting*, Paper 71CP191-PWR, Feb. 1971.

[B226] Klewe, K. C., and Tozer, B. A., "Impulse breakdown of a point-plain gap in SF_6," *IEE Conference on Gas Discharges*, pp. 36–41, 1970.

[B227] Kuffel, E., and Yializis, A.; "Impulse breakdown of positive and negative rod-plane gaps in SF_6-N_2 mixtures," *IEEE Power Engineering Society Winter Meeting*, Paper F78, 183-6, 6 pages, Jan. 1978.

[B228] Kurimoto, A., et al., "Impulse discharge characteristics in long non-uniform field gaps in low pressure SF_6," *International High Voltage Symposium*, pp. 349–354, Sept. 1975.

[B229] Kurimoto, A.; Aked, A.; and Tedford, D. J.; "Pre-breakdown phenomena in long non-uniform-field gaps in SF_6," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 162–165, Sept. 1976.

[B230] Kuwahara, H., et al., "Experimental study of internal arcs in SF_6 gas-filled enclosure," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3977–3987, Oct. 1982.

[B231] Kuwahara, H., et al., "Investigation of dielectric recovery characteristics of hot SF_6 gas after current interruption of developing new 300 kV and 550 kV gas circuit breakers," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 6, pp. 1371–1376, 1984.

[B232] Laghari, J. R., "Space flashovers in compressed gases," *IEEE Transactions on Electrical Insulation*, vol. EI-20, no. 1, pp. 83–92, Feb. 1985.

[B233] Laghari, J. R.; Qureshi, A. H.; and Theophilus, G. D.; "Flashover studies in SF_6-N_2 mixtures using direct applied voltages," *Second International Symposium on Gaseous Dielectrics,* pp. 227–236, Mar. 1980.

[B234] Lautenschlaeger, H., "AC corona and breakdown characteristics of SF_6 gas mixtures in non-uniform alternating voltage fields," *ETZ Arch.*, vol. 7, no. 4, pp. 137–142, Apr. 1985.

[B235] Lautenschlager, H., and Cooke, C. M., "Bundled conductors in gas-insulated high voltage power transmission cables," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-100, no. 1, pp. 394–399, Jan. 1981.

[B236] Lee, Z. Y., "Ionization and attachment and breakdown measurements in SF_6-CO_2-air," *IEEE 1983 Conference on Electrical Insulation and Dielectric Phenomena*, Buck Hill Falls, Pa., Annual Report (New York: IEEE, Nov. 1983), pp. 35–41, Oct. 1983.

[B237] Lee, Z. Y, "Measurement of breakdown potential and ionization and attachment in SF_6-CO_2 mixtures," *IEEE Transactions on Electrical Insulation*, vol. El-18, no. 6, pp. 637–641, Dec. 1983.

[B238] Leeds, W.; Browne, F.; and Strom, A.; "The use of SF_6 for high power arc quenching," *AIEE Transactions*, vol. 76, p. 906, 1957.

[B239] Legros, W. P., and Morant, M. M., "Breakdown of a coaxial cylinder gap in SF_6 under switching impulse voltages," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 4, pp. 849–854, Apr. 1984.

[B240] Lieberman, R. W., and Lowke, J. J., "Radiation emission coefficient for SF_6 arc plasma," *Journal of Quantitative Spectroscopic Radiation Transfer*, vol. 16, pp. 253–264, 1976.

[B241] Lowke, J. J., and Lieberman, R. W., "Negligible effect of negative ions on the constriction of arcs in SF_6," *Journal of Applied Physics*, vol. 43, pp. 1991–1994, 1972.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B242] Lowke, J. J., and Lieberman, R. W., "Predicted arc properties in SF_6," *Journal of Applied Physics*, vol. 42, no. 9, p. 3532, 1971.

[B243] MacAlpine, J. M. K. "The Breakdown of Compressed Gases Between Di-Electric-Covered Electrodes." Ph.D. diss., London University, 1968.

[B244] MacAlpine, J. M. K., and Cookson, A. H., "Impulse breakdown of compressed gases between dielectric-covered electrodes," *Proceedings, IEE*, vol. 117, no. 3, pp. 646–652, Mar. 1970.

[B245] Malik, N. H., et al., "Prebreakdown phenomenon in SF_6-N_2 mixtures at various pressures," *IEEE International Symposium on Electrical Insulation*, no. 78CH1287-2-2-El, pp. 140–145, June 1978.

[B246] Malik, N. H., and Qureshi, A. H., "Breakdown mechanism in sulphur-hexafluoride," *IEEE Transactions on Electrical Insulation*, vol. EI-13, no. 3, pp. 135–145, June 1978.

[B247] Malik, N. H., and Qureshi, A. H., "The influence of voltage polarity and field non-uniformity on the breakdown behavior of rod-plane gaps filled with SF_6," *IEEE Transactions on Electrical Insulation*, vol. 14, no. 6, pp. 327–333, Dec. 1979.

[B248] Malik, N. H.; Qureshi, A. H.; and Safar, Y. A.; "DC voltage breakdown of SF_6-air and SF_6-CO_2 mixtures in rod plane gaps," *IEEE Transactions on Electrical Insulation*, vol. El-18, no. 6, pp. 629–636, Dec. 1983.

[B249] Meek, J. M., and Craggs, J. D., *Electrical Breakdown of Gases*. New York: J. Wiley & Sons, 1978.

[B250] Menju, S., et al., "Dielectric breakdown of high pressure SF_6 in sphere and coaxial cylinder gaps," *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 5, pp. 1706–1712, Sept./Oct. 1974.

[B251] Minaguchi, D., et al., "Heat transfer characteristics of gas-insulated transmission lines," *IEEE Transactions on Power Delivery*, vol. PWRD-1, no. 1, pp. 2–9, Jan. 1986.

[B252] Morcos, M. M.; Anis, H.; and Srivastava, K. D.; "Metallic particle movement, corona and breakdown in compressed gas insulated transmission line systems," *Conference Record of the IEEE Industry Applications Society Annual Meeting*, San Diego, Calif., vol. 2, pp. 2220–2232, 1989.

[B253] Morcos, M. M.; Anis, H.; and Srivastava, K. D.; "Particle-initiated corona and breakdown in GIT L systems," *IEEE Transactions on Electrical Insulation,* vol. 24, no. 4, pp. 561–571, Aug. 1989.

[B254] Morcos, M.M.; Sengupta, S.S.; and Srivastava, K.D.; "Statistics of particle initiated breakdown in GIT L systems," *IEEE International Symposium on Electrical Insulation,* Cambridge, Mass., Conference Record (Cat. no. 88CH2594-0-DEI), pp. 116–119, June 1988.

[B255] Morcos, M. M., and Srivastava, K. D., "On the measurements of particle discharges caused by metallic contaminants in gas insulated systems," *Nordic Insulation Symposium*, Trondheim, Norway, Nord-1S 88, pp. 5/1–5/8, June 1988.

[B256] Morcos, M. M., and Srivastava, K. D., "Particle-initiated corona as indicative diagnosis in gas insulated systems," *Acta Physica Hungarica*, vol. 68, no. 1–2, pp. 3–13.

[B257] Morgan, J. D., and Abdellah, M., "Time to breakdown of covered electrodes in SF_6 and SF_6 gas mixtures," *1984 Annual Report of the Conference on Electrical Insulation and Dielectric Phenomena*, Claymont, Del., pp. 349–357, Oct. 1984.

[B258] Morrow, R., "Theory of positive corona in SF_6 due to a voltage impulse," *IEEE Transactions on Plasma Science*, vol. 19, no. 2, pp. 86–94, Apr. 1991.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B259] Morrow, R., "Theory of positive onset corona pulses in SF_6," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 3, pp. 398–404, June 1991.

[B260] Mosch, W., and Hauschild, W., "Calculating the breakdown voltage in SF_6 in a system of coaxial cylinders," *Electric Technology,* vol. 2, pp. 71–81, 1974.

[B261] Mulcahy, M. J., et al., "A review of insulation breakdown and switching in gas insulation," *Insulation/Circuits*, p. 55, Aug. 1970.

[B262] Mulcahy, M. J.; Milde, H.; and Bell, W. R.; "Insulation, breakdown and switching in high pressure gases—A review," *IEEE*, Publication 68C6-EI-92, pp. 221–226, 1968.

[B263] Munk-Nielson, T., and Pedersen, A., "Edge breakdown between uniform-field electrodes in SF_6," *Second International Conference on Gas Discharges*, no. 90, pp. 323–325, 1972.

[B264] Nakanishi, K., et al., "Experimental study of the breakdown characteristics at a gas-insulated bus," *IEEE Transactions on Electrical Insulation*, vol. El-16, no. 2, p. 117, Apr. 1981.

[B265] Nakanishi, K.; Shibuya, Y.; and Nitta, T.; "Experimental study of the breakdown characteristics of large scale gas-insulated systems," *Second International Symposium on Gaseous Dielectrics*, pp. 400–408, Mar. 1980.

[B266] Natsui, K., et al., "Interrupting characteristics of puffer and suction-type SF_6 gas interrupters, especially in thermal breakdown region," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 4, pp. 803–810, Apr. 1954.

[B267] Niemeyer, L. "Leader Breakdown in Compressed SF_6: Recent Concepts and Understanding." In *Gaseous Dielectrics VI*, 1991, pp. 49–59.

[B268] Nishijima, K., and Tsuneyasu, I., "Comparisons of direct-current breakdown characteristics in dry air and SF_6 gaps using a parallel-plane arrangement with variable height protrusion," *Electrical Engineering in Japan*, vol. 112, no. 7, pp. 46–54, 1992.

[B269] Nitta, T., et al., "Statistical approach to the breakdown characteristics of large scale gas insulated systems," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 338–359, Mar. 1978.

[B270] Nitta, T., and Kuwahara, H., "Time dependence and endurance testing of compressed gas insulation," *IEEE Power Engineering Society Summer Meeting*, Paper 80 SM703-9, July 1980.

[B271] Nitta, T., and Shibuya, Y., "Electrical breakdown of long gaps in sulfur hexafluoride," *IEEE Transactions on Power Apparatus and Systems*, vol. 90, no. 3, pp. 1065–1071, May/June 1971.

[B272] Nitta, T.; Yamada, N.; and Fujiwara, Y.; "Area effects of electrical breakdown in compressed SF_6" *IEEE Transactions on Power Apparatus and Systems*, vol. 1, pp. 623–629, Mar./Apr. 1974.

[B273] Okuda, S., et al., "Spectroscopic approach to the analysis of high current arcs in SF_6," *IEEE Transactions on Plasma Science*, vol. PS-8, no. 4, pp. 395–399, Dec. 1980.

[B274] Olivier, G.; Gervais, Y.; and Mukhedkar, D.; "A new approach to compute uniform field breakdown in gases," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 3, pp. 969–976, May/June 1978.

[B275] Ozawa, J., et al., "Electrical breakdown at gas gaps and insulator surfaces in SF_6 gas." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 6, p. 1745, Nov./Dec. 1974.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B276] Pai, R. Y., and Christophorou, L. G., "Impulse breakdown of c-C_4F_8/SF_6 and c-$C_4F_8/SF_6/N_2$," *Second International Symposium on Gaseous Dielectrics*, pp. 190–200, Mar. 1980.

[B277] Pederson, A., "Criteria for spark breakdown in SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 89, no. 8, pp. 2043–2048, Nov./Dec. 1970.

[B278] Pedersen, A., et al., "Anomalous breakdown in uniform field gaps in SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 6, p. 1810, Nov./Dec. 1973.

[B279] Pedersen, A., and Brengsbo, E., "Estimation of breakdown voltages in compressed SF_6," *International High Voltage Symposium*, Sept. 1975.

[B280] Pedersen, A.; Karlsson, P. W.; and Lebeda, J.; "The effect of field non-uniformity and asymmetry on ionization current growth measurements in sulfur hexafluoride," *IEEE Transactions on Power Apparatus and Systems*, vol. 90, no. 5, pp. 2175–2180, Sept./Oct. 1971.

[B281] Pfeiffer, W., "Breakdown development in compressed sulphur hexafluoride," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 149–152, Sept. 1976.

[B282] Pfeiffer, W., and Leitl, A., "The relation between luminous phenomena and discharge mechanism in SF_6" *Second International Symposium on Gaseous Dielectrics*, pp. 92–99, Mar. 1980.

[B283] Pfeiffer, W., and Schmidt, W., "Nanosecond time and spatial resolved investigation of breakdown development in SF_6," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 370–374, Mar. 1978.

[B284] Pfeiffer, W.; Zimmer, V.; and Zipfl, P.; "Predischarge development and dielectric strength of N_2, SF_6 and SF_6N_2-mixtures stressed by very fast transient voltages," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 390–393, 1992.

[B285] Pfender, E. "Electric arcs and arc gas heaters." In *Gaseous Electronics*, vol. 1, p. 291. Academic Press, 1978.

[B286] Phung, B. T.; Blackburn, T. R.; and Li, Z. Z.; "Application of a computer-based partial discharge analyser to corona discharge in gases," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 2, pp. 718–721, 1992.

[B287] Pinnekamp, F., and Niemeyer, L., "Qualitative model of breakdown in SF_6 in inhomogeneous gaps," *Journal of Physics D: Applied Physics* (U.K.), vol. 16, pp. 1293–1302, 1983.

[B288] Qiu, Y., et al., "Breakdown of SF_6 air mixtures in nonuniform field gaps under lightning impulse voltages," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 398–401, 1992.

[B289] Qiu, Y.; Chalmers, I. D.; and Li, H. M.; "Effect of injected space charges on the positive impulse breakdown of SF_6 in a point-plane gap," *Journal of Physics D: Applied Physics*, vol. 26, no. 2, pp. 326–328, 1993.

[B290] Radwan, R. M. "Electrical Discharge and Time Lags in Sulphur Hexafluoride." Ph.D. diss., Victoria University of Manchester, 1965.

[B291] Radwan, R. M., and Salma, M. M., "Calculations of breakdown voltage of electronegative gases (SF_6 and CI_2CF_2)." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 94, no. 4, p. 1094, July/Aug. 1975.

[B292] Rain, P, and Tobazeon, R., "Behaviour of free conducting particles and their role on breakdown in oils under ac and dc voltages," *IEE Conference*, Publication no. 363, pp. 96–99, 1992.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B293] Rein, A., "Breakdown mechanisms and breakdown criteria in gases—Measurements of discharge parameters and literature survey," *CIGRE, Electra*, no. 32, pp. 43–60, Jan. 1974.

[B294] Rein, A., and Arnesen, A., "High voltage breakdown mechanisms in SF_6 gas," *IEE Third International Conference on Gas Discharges*, no. 118, pp. 399–402, Sept. 1974.

[B295] Rein, A.; Arnesen, A.; and Ulriksen, Th.; "Breakdown in SF_6 with different voltage waveforms," *International High Voltage Symposium*, Sept. 1975.

[B296] Rengu, Zhang, "Researches on HV insulations and their present situation in China," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, vol. 1, pp. 557–562, 1991.

[B297] Rong, X.; Feser, K.; and Kohler, W.; "Influence of the steepness of impulse voltages on the corona stabilization in SF_6," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 298–301, 1992.

[B298] Rothhardt, L., "Simple computing instructions for the dielectric strength of warm, thermally inhomogeneous gas paths in SF_6" *Electric Akad de Wissenschaften der DDR*, Jena, Germany.

[B299] Ruegsegger, W.; Kneubuhl, F. K.; and Schoetzau, H. J.; "Mass spectrometry of high pressure arcs in air and SF_6," *Applied Physics B.*, vol. 31, pp. 9–13, 1983.

[B300] Ruegsegger, W.; Meier, H.; and Kneubuhl, F. K.; "Mass spectrometry of arcs in SF_6 circuit breakers," *Applied Physics B.* (Germany), vol. B37, no. 3, pp. 115–135, July 1985.

[B301] Ryan, H. M., and Watson, W. L., "Electrical breakdown and voltage-time characteristics in SF_6 at high pressures," *IEEE Power Engineering Society Summer Meeting*, Paper F76-390-5, July 1976.

[B302] Ryan, H. M., and Watson, W. L., "Impulse breakdown characteristics in SF_6 for non-uniform field gaps," *CIGRE*, Paper 15–01, 14 pages, 1978.

[B303] Sangkasaad, S., "Breakdown characteristics of compressed SF_6 in concentric spheres field," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 145–148, Sept. 1976.

[B304] Savic, P., and Kekez, M. M., "Possible interpretation of the gas discharge structure in a rod/plane gap," *Second International Symposium on Gaseous Dielectrics*, pp. 65–73, Mar. 1980.

[B305] Schulz-Guide, E., "Temperature determination for arcs in SF_6 accounting for demixing," *Journal of Physics D.*, vol. 13, pp. 793–803, 1980.

[B306] Schumb, V. C.; Trump, J. G.; and Priest, G. L.; "Effects of high voltage electrical discharge on SF_6," *Industrial and Engineering Chemistry*, vol. 41, pp. 1348–1351, July 1949.

[B307] Sekiya, Y., et al., "Effect of the small arc current generated by a poor contact on the breakdown voltage in SF_6 gas," *Electrical Engineering in Japan*, vol. 112, no. 1, pp. 74–83, 1992.

[B308] Sellars, A. G.; Hampton, B. F.; and Farish, O.; "UHF diagnosis of pre-breakdown corona pulses in GIS," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 2, pp. 706–709, 1992.

[B309] Shibuya, Y., "Breakdown time lag of short gaps in various gases," *IEE Third International Conference on Gas Discharges*, no. 116, pp. 132–135, Sept. 1974.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B310] Shibuya, Y.; Yamada, N.; and Nitta, T.; "Electrical breakdown and prebreakdown dark current in compressed SF_6," *Second International Conference on Gas Discharges*, pp. 320–322, 1972.

[B311] Siddagangappa, M. C., and Van Brunt, R. J., "Influence of oxygen on the decomposition rate of SF_6 in corona," *Proceedings of the IEEE Electrical Insulation Symposium*, June 1986.

[B312] Somerville, I. C., and Tedford, D. J., "Electrical breakdown in compressed SF_6 between highly polished electrodes," *Second International Symposium on Gaseous Dielectrics*, pp. 100–107, Mar. 1980.

[B313] Spence, G., and Ryan, H. M., "Breakdown characteristics in high pressure SF_6 for uniform and non-uniform fields," *IEE Fourth International Conference on Gas Discharges*, no. 143, pp. 157–161, Sept. 1976.

[B314] Spriggs, K. R., "Limiting values of critical electric stress, and the design prediction of EHV/UHV SF_6 insulation breakdown," *IEEE Transactions on Electrical Insulation*, vol. 14, no. 3, pp. 142–147, June 1979.

[B315] Srivastava, K. D., and Anis, H., "Pre-breakdown discharges in highly non-uniform fields in relation to gas-insulated systems," *IEEE Conference on Electrical Insulation and Dielectric Phenomena*, New York, N.Y, p. 219, Oct. 1981.

[B316] Srivastava, K. D., and van Heeswijk, R. G., "Dielectric coatings-effect on breakdown and particle movement in GITL systems," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-104, no. 1, pp. 22–3 1, Jan. 1985.

[B317] Stuckless, H. A.; Braun, J. M.; and Chu, F. Y; "Degradation of silica-filled epoxy spacers by arc contaminated gases in SF_6-insulated equipment," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-104, p. 359, Dec. 1985.

[B318] Sugiyama, S., et al., "An investigation of breakdown voltage with small arc current due to poor contact in SF_6 gas," *IEEE Transactions on Power Delivery*, vol. 7, no. 1, pp. 332–338, 1992.

[B319] Suzuki, T., et al., "Degradation process of grease due to SF_6 dissociation products," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 8, pp. 2805–2809, 1982.

[B320] Suzuki, T.; Nokayama, S.; and Yoshimitsu, T.; "Degradation of insulating materials including SiO_2 due to SF_6 gas dissociation products," *IEEE Transactions on Electrical Insulation*, vol. El-15, p. 53, 1980.

[B321] Swarbrick, P., "Compositions and properties of an SF_6 arc plasma," *Journal of Applied Physics: B.*, vol. 18, pp. 419–426, 1967.

[B322] Takahashi, Y., "Partial discharges in high-pressure gases and deterioration of plastics by partial discharge," *Electrical Engineering in Japan*, vol. 91, no. 2, pp. 189–195, 1971.

[B323] Takuma, T.; Aoshima, Y.; and Watanabe, T.; "Discharge extension of long gaps in compressed SF_6 gas and gas mixtures," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 401–405, Mar. 1978.

[B324] Thorburn, R., "Permanent dissociation of SF_6 in corona discharge," *Nature*, vol. 175, p. 423, 1955.

[B325] "Threshold limit values for chemical substances and physical agents in the workroom environment with intended changes for 1981," *American Conference of Government Industrial Hygienists Association Publication*, Cincinnati, Ohio, 1981.

[B326] Trinh, N. G. "Failure Mechanisms of Gas Insulation and Interface: Their Influence on Gas-Insulated Equipment at Gas-Insulator." In *Gaseous Dielectrics VI*, 1991, pp. 517–528.

 Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B327] Trinh, N. G., "Risk of burn-through—A quantitative assessment of the capability of gas-insulated equipment to withstand internal arcs," *IEEE Transactions on Power Delivery*, vol. 7, no. 1, pp. 225–236, 1992.

[B328] Van Brunt, R. J., "Production rates for oxyfluorides SOF_2, SO_2F_2 and SOF_4 in SF_6 corona discharge," *Journal of Research*, National Bureau of Standards, vol. 90, no. 3, pp. 229–253, May 1985.

[B329] Van Brunt, R. J.; Lazo, T. C.; and Anderson, W. E. "Production Rates for Discharge Generated SOF_2, SO_2F_2, and SO_2 in SF_6 and SF_6-H_2O Mixtures." In *Gaseous Dielectrics IV*, edited by L. G. Christophorou and M. O. Pace, pp. 276–285. Pergamon Press, 1984.

[B330] Van Brunt, R. J., and Mashikian, M., "Mechanisms for inception of dc and 60 Hz ac corona in SF_6," *IEEE Transactions on Electrical Insulation*, vol. EI-17, no. 2, p. 106, 1982.

[B331] Van Brunt, R. J., and Mashikian, M., "Role of photodetachment in initiation of electric discharges in SF_6 and O_2" *Journal of Applied Physics*, vol. 54, no. 6, pp. 3074–3079, June 1983.

[B332] van der Zel, G. L., and Reynders, J. P., "Corona stabilization in SF_6 and its influence on breakdown under fast rising impulses," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 55–58, 1991.

[B333] van Heeswijk, R. G.; Srivastava, K. D.; and Chakrabarti, A. K.; "Particle-initiated breakdown at a spacer surface in a gas-insulated bus," *Canadian Electric Association Report*, 1985.

[B334] Van Slambrouck, T., "Use of tunable diode lasers for the determination of low level gas by-products in arced SF_6," *Spectra Physics Report* (unpublished), Sept. 1983.

[B335] Vijh, A. K., "The nature of metal-electrodes/SF_6 reactions in SF_6 decomposition due to direct current interruption under simulated circuit breaker conditions," *IEEE Transactions on Electrical Insulation*, vol. EI-11, no. 4, pp. 157–160, Dec. 1976.

[B336] Vlastos, A. E., and Rusck, S., "Impulse and ac breakdown characteristics of SF_6 with bare and covered electrodes," *International Symposium on Gaseous Dielectrics*, Publication no. CONF-780301, pp. 385–400, Mar. 1978.

[B337] Vlastos, A. E., and Rusck, S., "The influence of a thin electrode coating on the ac breakdown of SF_6," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 59–62, Sept. 1976.

[B338] Vouros, P., "The analysis of arc by-products by SF_6 by combined gas chromatography or mass spectrometry," *EPRI*, Final Report EL80-8-LD, Dec. 1980.

[B339] Watson, W. L., and Ryan, H. M., "Breakdown and voltage-time characteristics in SF_6 for voltages in the range 0.6-2 MV," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 153–155, Sept. 1976.

[B340] Watts, M. W., "Cosmic rays and breakdown in SF_6," *Central Electricity Research Laboratories*, Report no. RD/L/N 58/79, Mar. 1979.

[B341] Wiegart, N., et al. "Inhomogeneous field breakdown in GIS." *IEEE Power Engineering Society Winter Power Meeting*, 1987.

[B342] Wootton, R. E.;Dale, S. J.; and Zimmerman, N. J.; "Electric strength of some gases and gas mixtures," *Proceedings of the Second International Symposium on Gaseous Dielectrics*, Knoxville, Tenn., pp. 137–148, Mar. 1980.

[B343] Works, C. N., and Deakin, T. W., "Dielectric breakdown of SF_6 in uniform fields," *AIEE Transactions*, vol. 72, pt. 1, pp. 682–689, Nov. 1953.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B344] Yializis, A., et al., "Impulse breakdown and corona characteristics for rod-plane gaps in mixtures of SF_6 and nitrogen with less than 1% of SF_6 content," *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 5, pp. 1832–1840, Sept./Oct. 1979.

[B345] Yildirim, F., and Korasli, C., "Statistical approach for determining breakdown voltage of gas-insulated cables," *IEEE Transactions on Electrical Insulation*, vol. 27, no. 6, pp. 1186–1192, 1992.

[B346] Yunping, Feng, et al., "Particle-initiated breakdown in coaxial systems in SF_6 and SF_6 air mixtures," *Proceedings of the Eighth International Conference on Gas Discharges and Their Applications*, Oxford, U.K., pp. 235–238, Sept. 1985.

6.1.4 Effects of particles and surface roughness

[B347] Abdel-Salam, M., "On the computation of lifting voltages for free conducting particles in compressed SF_6," *IEEE Power Engineering Society Winter Meeting*, Paper A 79 003-5, 7 pages, Jan. 1979.

[B348] Afzelius, R. W., and Bergqvist, H. W., "Particle traps in gas-insulated systems," *Proceedings of the Second International Symposium on Gaseous Dielectrics*, Knoxville, Tenn., pp. 266–274, Mar. 1980.

[B349] Anis, H., and Srivastava, K. D., "Free conducting particles in compressed gas insulation," *IEEE Transactions on Electrical Insulation*, vol. EI-16, no. 4, pp. 327–338, Aug. 1981.

[B350] Berger, S., "Influence of a single electrode surface protrusion on the onset voltage in air and SF_6." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 94, no. 6, p. 1920, Nov./Dec. 1975.

[B351] Berger, S., "Onset or breakdown voltage reduction by electrode surface roughness in air and SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 4, pp. 1073–1079, July/Aug. 1976.

[B352] Brand, K. P., and Kopainsky, J., "Particle densities in a decaying SF_6 plasma," *Applied Physics,* vol. 16, pp. 425–432, 1978.

[B353] Brown, G. W.; Samm, R.; and Cronin, J. C.; "AC analysis and testing of realistically contaminated gas insulated systems," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 1, pp. 59–67, Jan./Feb.1978.

[B354] Cooke, C. M., "Electrostatics of particle control in gas-insulated apparatus," *Second International Symposium on Gaseous Dielectrics*, pp. 275–282, Mar. 1980.

[B355] Cooke, C. M., "Ionization, electrode surfaces and discharges in SF_6 at extra high voltages," *IEEE Transactions on Power Apparatus and Systems*, vol. 94, no. 5, pp. 1518–1523, Sept./Oct. 1975.

[B356] Cooke, C. M., "Particle contamination in compressed gas insulation: Limitations and control," *International Symposium on Gaseous Dielectrics*, Publication no. CONF-780301, pp. 162–189, Mar. 1978.

[B357] Cooke, C. M., "Particles-initiated breakdown in gas dielectric cable insulation expanded scope program," *EPRI* (DOE), EL-1264, Project 7802, Final Report, no. 1979, 113 pages.

[B358] Cooke, C. M.; Wootton, R. E.; and Cookson, A. H.; "Influence of particles on ac and dc electrical performance of gas insulated systems at extra-high voltages," *IEEE Transactions on Power Apparatus and Systems*, vol. 96, no. 3, pp. 768–777, May/June 1971.

[B359] Cookson, A. H., "Particle Trap for Compressed Gas Insulated Transmission Systems," U.S. Patent no. 4,554,399, Nov. 1985.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B360] Cookson, A. H., et al., "Recent research in the United States on the effects of particle contamination reducing the breakdown voltage in compressed gas insulated systems," *CIGRE*, Paper 15-09, 10 pages, Aug. 1976.

[B361] Cookson, A. H., and Farish, O., "Motion of spherical particles and ac breakdown in SF_6," *Conference on Electrical Insulation and Dielectric Phenomena*, p. 129, 1971.

[B362] Cookson, A. H., and Farish, O., "Particle-initiated breakdown between coaxial electrodes in compressed SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 3, pp. 871–876, May/June 1973.

[B363] Cookson, A. H., and Farish, O., "Particle initiated breakdown in compressed SF_6," *Conference on Electrical Insulation and Dielectric Phenomena*, NAS publication 1870, pp. 179–186, 1971.

[B364] Cookson, A. H.; Farish, O.; and Sommerman, G. M. L.; "Effect of conducting particles on ac corona and breakdown in compressed SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 4, pp. 1329–1338, July/Aug. 1972.

[B365] Cookson, A. H., and Wootton, R. E., "Movement of filamentary conducting particles under ac voltages in high pressure gases," *International High Voltage Symposium*, pp. 416–420, Sept. 1975.

[B366] Cookson, A. H., and Wootton, R. E., "Particle movement and gas breakdown in high pressure nitrogen and sulphur hexafluoride," *Third International Conference on Gas Discharges*, pp. 385–388, Sept. 1974.

[B367] Crichton, B. H.; Ibrahim, O. E.; and Farish, O.; "The dependence of breakdown voltage in SF_6 mixtures of electrode-surface roughness," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 117–120, Sept. 1976.

[B368] Dale, S. J., and Hopkins, M. D., "Methods of particle control in SF_6 insulated CGIT systems," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 6, pp. 1654–1663, June 1982. Paper presented at *IEEE Power Engineering Society Transmission and Distribution Conference and Exposition*, Minneapolis, Minn., Sept. 1981.

[B369] Dale, S. J.; Wootton, R. E.; and Cookson, A. H.; "Effects of particle contamination in SF_6 CGIT systems and methods of particle control and elimination," *Proceedings of the Second International Symposium on Gaseous Dielectrics*, Knoxville, Tenn., pp. 256–265, Mar. 1980.

[B370] Diessner, A., and Trump, J. G., "Free conducting particles in a coaxial compressed gas insulated system," *IEEE Transactions on Power Apparatus and Systems*, vol. 89, no. 8, pp. 1970–1978, Nov./Dec. 1970.

[B371] Doepken, H. C., Jr., "Free conducting particles and gas breakdown," *Conference on Electrical Insulation and Dielectric Phenomena*, NAS publication 1764, pp. 7–11, 1970.

[B372] Eteiba, M., et al., "Influence of conducting particle attached to an epoxy resin spacer on the breakdown voltage of compressed-gas insulation," *Second International Symposium on Gaseous Dielectrics*, pp. 250–255, Mar. 1980.

[B373] Ganger, E. B., "The danger of foreign particles on the voltage safety of SF_6-insulated apparatus," *Ball Assoc., Suisse Electr.*, vol. 76, no. 13, pp. 769–776, July 1985.

[B374] Ganger, E. B., and Leibold, A. A., "The influence of foreign particles on dielectric strength in SF_6 installations." Abstract (A76 152-9) in *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 3, p. 762, May/June 1976.

[B375] Gockenbach, E., "Effects of the electrode surface on the breakdown performance of SF_6," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 113–115, Sept. 1976.

Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---
Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B376] Graybill, H. W., "Effects of contamination in SF_6 gas-insulated substations and transmission systems," *Doble Client Conference*, sec. 10, pp. 101–106, Apr. 1978.

[B377] Hampton, B. F., and Fleming, S. P., "Impulse flashover of particle-contaminated spacers in compressed sulphur hexafluoride," *Proceedings*, *IEE*, vol. 120, no. 4, pp. 514–518, Apr. 1973.

[B378] Hara, M., et al., "Influence of surface shape on dc surface breakdown characteristics under metallic-particle contaminated conditions in SF_6 gas," *Electrical Engineering in Japan*, vol. 111, no. 3, pp. 37–46, 1991.

[B379] Homburg, V.; Karner, H. C.; and Schwarz, R.; "Degradation of spacer surfaces in SF*6*-GIS by test flashovers," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 25–27, 1991.

[B380] Ikeda, C., and Yoda, B., "Effects of electrode surface conditions and dust particles on the electrical breakdown of SF_6 gas," *Electrical Engineering in Japan*, vol. 91, no. 5, pp. 67–74, 1971.

[B381] Kaminaga, K., et al., "Development of compact 500 kV 8000 A gas insulated transmission line-dust control during field jointing and method for detecting conductive particles," *IEEE Transactions on Power Delivery*, vol. PWRD-2, no. 4, pp. 961–968, Oct. 1987.

[B382] Korasli, C.; Somerville, I. C.; and Farish, O.; "Electrode-area and surface roughness effects on breakdown of SF_6/N_2 mixtures," *Second International Symposium on Gaseous Dielectrics*, pp. 218–226, Mar. 1980.

[B383] Kuwahara, H., et al., "Effects of solid impurities on breakdown in compressed SF_6 gas," *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 5, pp. 1546–1555, Sept./Oct. 1974.

[B384] Lampe, J.; Latour-Slowikowska, H.; and Slowikowski, J. "Study on Metal Fluoride Products Formation Caused By an Electric Arc in SF_6." In *Gaseous Dielectrics III*, edited by L. G. Christophorou, p. 433. Pergamon Press, 1982.

[B385] Latour-Slowikowska, H., et al., "Some test results on the effect of SF_6 decomposition products on superficial properties on epoxy resin compositions," *IEEE International Symposium on Electrical Insulation*, Publication 78CH 1287-2-EI, p. 180, June 1978.

[B386] Matsuura, K., and Takano, T., "Influence of conducting particles on flashover voltage over insulation surface of epoxy-resin insulation," *A.I. M. International Meeting*, 9 pages, Nov. 1979.

[B387] Morcos, M. M., and Srivastava, K. D., "On electrostatic trapping of particle contamination in GITL systems," *IEEE Transactions on Power Delivery*, vol. 7, no. 4, pp. 1698–1705, 1992.

[B388] Morcos, M. M.; Srivastava, K. D.; and Anis, H.; "An approach to breakdown probability calculations for particle contaminated GIT L systems," *IEEE International Symposium on Electrical Insulation*, Montreal, Quebec, Canada, pp. 159–162, June 1984.

[B389] Morrow, R., and Morgan, V. T., "The effect of surface roughness on the ac corona onset voltage for cylindrical conductors in air," *Second International Symposium on Gaseous Dielectrics*, pp. 237–242, Mar. 1980.

[B390] Nitta, T., et al., "Effects of electrode and solid insulated surfaces on the flashover in compressed SF_6," *CIGRE*, Paper 15-04, 12 pages, Aug. 1976.

[B391] Nitta, T., et al., "Factors controlling surface flashover in SF_6 gas insulated systems," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 3, pp. 959–968, May/June 1978.M

[B392] Ouyang, M., "A system approach to particle control for HVDC GIT L," *Proceedings of the Fourth International Symposium on Gaseous Dielectrics*, Knoxville, Tenn., pp. 482–491, Apr. 1984.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B393] Parekh, H.; Srivastava, K. D.; and Van Heeswijk, R. G.; "Lifting field of free conducting particles in compressed SF_6 with dielectric coated electrodes," *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 3, pp. 748–758, May/June 1979.

[B394] Pedersen, A., "The effect of surface roughness on breakdown in SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 94, no. 5, pp. 1749–1754, Sept./Oct. 1975.

[B395] Pedersen, A., "Evaluation of the effect of surface defects on breakdown in strongly electronegative gases or gas mixtures," *Second International Symposium on Gaseous Dielectrics*, pp. 201–209, Mar. 1980.

[B396] Pfeiffer, W., and Volker, P., "Influence of conductive particles on the dc voltage strength of spacers in compressed SF_6," *Second International Symposium on Gaseous Dielectrics*, pp. 243–249, Mar. 1980.

[B397] Ryan, H. M., et al., "Factors affecting the insulation strength of SF_6-filled systems," *CIGRE*, Paper 15-02, 9 pages, Aug. 1976.

[B398] Samuelsson, R., "Corrosion and surface resistivity changes in different insulating materials caused by decomposed SF_6 and moisture," *ASEA Journal*, vol. 52, no. 6, pp. 133–136, 1970.

[B399] Samuelsson, R., "The dielectric strength of SF_6 by irregularities on conductor surface," *ASEA Journal*, vol. 52, no. 4, pp. 87–91, 1979.

[B400] Suzuki, T.; Nakayama, S.; and Yoshimitsu, T.; "Degradation of insulating materials including SiO_2 due to SF_6 gas dissociation products," *IEEE International Symposium on Electrical Insulation*, Publication 78CH 1287-2-EI, pp. 176–179, June 1978.

[B401] Takuma, T.; Watanabe, T.; and Kawamoto, T.; "Second limiting field strength in SF_6 gas discharge—Quantitative estimation of effect of electrode surface roughness on breakdown," *International Symposium on Gaseous Dielectrics*, Publication no. CONF-780301, pp. 190–205, Mar. 1978.

[B402] Vlastos, A. E., and Rusck, S., "Influence of coating polished and rough electrodes on the impulse and ac breakdown of SF_6," *Second International Symposium on Gaseous Dielectrics*, pp. 210–217, Mar. 1980.

[B403] Wootton, R. E.; Emery, F. T.; and Cookson, A. H.; "Effect of duration of voltage application and number of conducting particles on the ac breakdown strength of compressed SF_6 in a coaxial system," *International Symposium on Gaseous Dielectrics*, Publication no. CONF-780301, pp. 206–223, Mar. 1978.

[B404] Yamamoto, O.; Hara, T.; and Hayashi, M.; "Measurement of streamer charge distribution on insulator in SF_6 gas," *Electrical Engineering in Japan*, vol. 111, no. 3, pp. 47–56, 1991.

6.1.5 Gas decomposition and aging

[B405] Aksenov, Yu P., et al., "A diagnostic method for sulfur hexafluoride insulation based on partial discharge parameters," *Power Eng*., vol. 21, no. 3, pp. 44–49, 1983.

[B406] Amalric, J., "Practical consequences of the decomposition by arc of SF_6," *Revue Generale de l'Electricite*, pp. 45–78, June 1974.

[B407] Amalric, J., et al., "Practical consequences of research on the decomposition by arc of SF_6," *Revue Generale de l'Electricite*, Special Issue, pp. 79–85, June 1974.

[B408] Aoki, N., and Kumai, K., "Decomposition of SF_6 by arc discharge—Influence of water, organic material, and electrode materials upon arc decomposition products of SF_6," *Central Research Institute Of Electric Power Industry* (Japan), Report E278OO4, 1978.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

[B409] Bargigia, A., et al., "Endurance test on solid insulating materials used for GIS cast insulators," *Proceedings of the Fourth International Symposium on High Voltage Engineering*, Athens, Greece, Sept. 1983.

[B410] Belmadani, B., et al., "SF_6 decomposition under power arcs—I: Physical aspects," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 6, pp. 1163–1176, Dec. 1991.

[B411] Belmadani, B.; Casanovas, J.; and Casanovas, A. M.; "SF_6 decomposition under power arcs—II: Chemical aspects," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 6, pp. 1177–1182, Dec. 1991.

[B412] Benson, S. W., and Bott, J., "The kinetics and thermochemistry of S_2F_{10} pyrolysis," *International Journal Chem. Kinetics*, vol. 1, p. 451, 1969.

[B413] Boudene, C., et al., "Identification and study of some properties of compounds resulting from the decomposition of SF_6 under the effects of electric arcing in circuit breakers," *Revue Generale de l'Electricite*, Special Issue, pp. 45–78, June 1984.

[B414] Brown, G. W.; Samm, R.; and Cronin, J.; "AC analysis and testing of realistically contaminated gas-insulated systems," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-97, no. 1, pp. 59–67, Jan./Feb. 1978.

[B415] Bruno, G.; Capezzuot, P.; and Cramarossa, F; "Inorganic volatile fluorides obtained from electrical decomposition of sulfur hexafluoride in a quartz tube," *Journal of Fluorine Chemistry*, vol. 14, pp. 115–129, 1979.

[B416] Chakrabarti, A. K.; van Heeswijk, R. G.; and Srivastava, K. D.; "Spacer involvement in conducting particle-initiated breakdown in compressed gas insulated systems," *IEEE Transactions on Electrical Insulation*, vol. EI-22, no. 4, pp. 431–438, Aug. 1987.

[B417] Chalmers, I. D., and Tedford, D. J., "Spark breakdown in sulfur hexafluoride and arcton 12," *Proceedings, IEE*, vol. 118, no. 12, pp. 1893–1894, Dec. 1971.

[B418] Chu, F. Y, "SF_6 decomposition in gas-insulated equipment," *IEEE Transactions on Electrical Insulation*, vol. EI-21, no. 5, pp. 693–725, Oct. 1986.

[B419] Chu, F Y., and Lutz, F., "SF_6 decomposition in a plasma arc for various electrode materials," *Proceedings of the Sixth International Symposium on Plasma Chemistry*, p. 231, July 1983.

[B420] Chu, F. Y., and Massey, R. M. "Thermal Decomposition of SF_6 and SF_6-Air Mixtures in Substation Environments." In *Gaseous Dielectrics III*, edited by L. G. Christophorou, pp. 410–417. Pergamon Press, 1982.

[B421] Dakin, T. W. "Thermal Aging of Dielectric Gas." In *Gaseous Dielectrics II*, edited by L. G. Christophorou, pp. 283–293. Pergamon Press, 1980.

[B422] Dominelli, N., "Analysis of gaseous SF_6 decomposition products," *Proceedings of the International Symposium on Gas-Insulated Substations*, Sept. 1985.

[B423] Edelson, D., et al., "Electrical decomposition of SF_6," *Industrial and Engineering Chemistry*, vol. 45, no. 9, pp. 2094–2096, Sept. 1953.

[B424] Edelson, D., and McAffee, K. B., "Notes on the infrared spectrum of SF_6," *Journal Chem. Phys.*, vol. 19, no. 10, p. 1311, Oct. 1951.

[B425] Eibech, R. E., and Nears, W. H. "Sulfur Hexafluoride." In *Kirk-Othmer Encyc. Chem. Tech.*, 3d ed., vol. 10, 1980, p. 799.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B426] Fischer, T. N., Jr., "Experience with contaminated SF_6 gas," *Transmission and Distribution*, vol. 27, no. 10, pp. 45–46, Oct. 1975. Letter to the Editor, p. 8, Feb. 1976.

[B427] Goff, R. W., "New England Electric System experience with SF_6 arc products," *Doble Client Conference*, sec. 10, pp. 1301–1307, Apr. 1976.

[B428] Griffin, G. D., et al., "Cytotoxic activity of spark-decomposed SF_6 and analysis of cytotoxic contributions of individual spark decomposition products," *Toxicological and Environmental Chemistry*, vol. 9, pp. 139–166, 1984.

[B429] Griffin, G. D., et al. "Decomposition of Sparked SF_6 and Cytotoxicity of SF_6 Decomposition Products." In *Gaseous Dielectrics IV*, edited by L. G. Christophorou and M. O. Pace, pp. 261–272. Pergamon Press, 1984.

[B430] Hirooka, K., et al., "Decomposition products of SF_6 gas by high-current arc and their reaction mechanism," *Electrical Engineering in Japan*, vol. 95, no. 6, pp. 14–19, 1975.

[B431] Hollinger, A., "Analyzer for decomposition products and moisture in SF_6 gas," *Canadian Electric Association*, Final Report 086-T-176, June 1984.

[B432] Holmberg, R. W., "Problems with SF_6 decomposition in large electro-static accelerators," *EPRI*, Report EL80-8-LD, Dec. 1980.

[B433] Hudson, A. A., "Degradation of SF_6 in electrical equipment, toxic and corrosive effect," *Electrical Research Association*, Report no. 5185, Surrey, England, 1967.

[B434] Janssen, F. J. J. G., "Measurements at the sub-ppm level of sulphur-fluoride compounds resulting from the decomposition of SF_6 by arc discharge," *KEMA Scientific and Technical Reports*, The Netherlands, vol. 2, no. 2, 1984.

[B435] Kharitonov, F. Ya., et al., "Investigation of stability of ceramic materials in products of SF_6 decomposition," *Soviet Electrical Engineering*, vol. 62, no. 1, pp. 24–27, 1991.

[B436] Kulsetas, J.; Rein, A.; and Holt, J.; "Arcing in SF_6 insulated equipment: Decomposition products and pressure rise," *A.I.M. International Meeting*, 5 pages, Nov. 1979.

[B437] Kulsetas, J.; Rein, A.; and Holt, P. A.; "Arcing in SF_6-insulated equipment, decomposition products and pressure rise," *Proceedings of the Nordic Insulation Symposium*, NORD-IS-78, June 1978.

[B438] Latour-Slowikowska, et al., "Some test results on the effect of SF_6 decomposition products on superficial properties of epoxy resin compositions," *IEEE Proceedings on Insulation Symposium*, 1978.

[B439] Latour-Slowikowska, H.; Lampe, J.; and Slowikowski, J. "On Reactions Occurring in the Gaseous Phase in Decomposed SF_6." In *Gaseous Dielectrics IV*, edited by L. G. Christophorou and M. O. Pace, pp. 286–291. Pergamon Press, 1984.

[B440] Mauthe, G., et al., "Handling of SF_6 and its decomposition products in gas insulated switchgear (GIS)," *Electra*, no. 137, pp. 80–108, 1991.

[B441] McDonald, R. S., "Analysis of SF_6 arc by-products by FT-1R," *EPRI*, Report EL80-8-LD, Dec. 1980.

[B442] Mitchel, G.; Castonguay, J.; and Trinh, N. G.; "Practical themodynamics of SF_6 recovery from SF_6/ N_2 or SF_6/ air mixtures," *International Symposium on Gas-Insulated Substations*, Toronto, Canada, Sept. 1985.

[B443] Modica, A. P., "Shock tube study of SF_6 and SF_5-C1 equilibrium decomposition," *Journal of Phys. Chem.*, vol. 77, no. 23, 1973.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B444] Mukaiyama, Y., et al., "Principal decomposition by-products generated at various abnormalities in gas-insulated transformers," *IEEE Transactions on Power Delivery*, vol. 6, no. 3, pp. 1117–1123, 1991.

[B445] Nakayama, H., et al., "Breakdown of the mixture ($ArSF_6$) in a needle-plane gap under MUS pulse voltage," *Japanese Journal of Applied Physics, Part 1: Regular Papers and Short Notes*, vol. 30, no. 4, pp. 858–859, Apr. 1991.

[B446] Niemeyer, L., and Pinnekamp, F. "Surface Discharge in SF_6." In *Gaseous Dielectrics III*, edited by L. G. Christophorou, p. 379. Pergamon Press, 1982.

[B447] Nissan, A. H., "Permanent dissociation of SF_6 in corona discharges," *Nature*, vol. 15, pp. 423–424, Mar. 1955.

[B448] Nossier, A., and Hawley, R., "Effects of dissolved sulphur hexafluoride on electrical breakdown in mineral oil," *Proceedings, IEE*, vol. 113, no. 2, pp. 359–363, Feb. 1966.

[B449] Ophel, T. R., et al., "Aspects of breakdown product contamination of SF_6 in electro-static accelerators," *Nuclear Instruments and Methods*, vol. 217, pp. 383–396, 1983.

[B450] Padma, D. K., and Murthy, A. R., "Thermal decomposition of SF_6," *Journal of Fluorine Chemistry*, vol. 5, pp. 181–184, 1975.

[B451] Pohl, M. C., "Analytical procedures for detecting the decomposition products of SF_6," *EPRI*, Report EL80-8-LD, Dec. 1980.

[B452] Sakai, T., and Yumoto, M., "A proposal of an optical method for measurement of gas composition (SF_6 and N_2)," 1984 *Annual Report of the Conference on Electrical Insulation and Dielectric Phenomena*, Claymont, Del., pp. 387–392, Oct. 21–25, 1984.

[B453] Sauers, I., et al., "Spark decomposition of SF_6: Toxicity of by-products," *Oak Ridge National Laboratory*, Report ORNL/TM-9062, Oct. 1984.

[B454] Sauers, I., et al. "Studies of Spark Decomposition Products of SF_6 and SF_6 Perfluorocarbon Mixtures." In *Gaseous Dielectrics III*, edited by L. G. Christophorou, pp. 387–401. Pergamon Press, 1982.

[B455] Sauers, I.; Christophorou, L. G.; and Spyrou, S. M. "Negative Ion Formation in SF_6 Spark By-Products." In *Gaseous Dielectrics IV*, edited by L. G. Christophorou and M. O. Pace, pp. 292–309. Pergamon Press, 1982.

[B456] Siddagangappa, M. C., and Van Brunt, R. J., "Decomposition products from corona in SF_6/N_2 and SF_6/O_2 mixtures," *Proceedings of the Eighth International Conference on Gas Discharges and Their Applications*, Oxford, U.K., Sept. 1985.

[B457] Suzuki, T.; Nakayama, S.; and Yoshimitsu, T.; "Degradation of insulating materials, including $S1O_2$ due to SF_6 gas dissociation products," *IEEE Transactions on Electrical Insulation*, vol. 15, no. 1, pp. 53–58, Feb. 1980.

[B458] Tahiliani, V., and Baker, A. E., "Study of arc by-products in gas-insulated equipment," *Doble Client Conference*, sec. 10, pp. 201–207, Apr. 1980.

[B459] Tokuyama, S., et al., "Analysis of SF_6 gas decomposition due to current interruption," *Second International Conference on Gas Discharges*, IEEE Conference Publication 90, p. 200, 1972.

[B460] Tominaga, S., "SF_6 gas analysis technique for evaluating internal conditions in SF_6-insulated equipment," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 4196–4206, Sept. 1981.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B461] Tominaga, S.; Kuwahara, H.; and Hirooka, K.; "Influence of arc-decomposed SF_6 gas on cast epoxy insulators for gas insulated switchgear," *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 6, pp. 2107–2114, Nov./Dec. 1979.

[B462] Van Brunt, R. J., and Leep, D. A. "Corona-Induced Decomposition of SF_6." In *Gaseous Dielectrics IV*, edited by L. G. Christophorou and M. O. Pace, pp. 402–409. Pergamon Press, 1982.

[B463] Wootton, R. E., et al., "Prediction of electrical breakdown carbonization of gases and gas mixtures," *Second International Symposium on Gaseous Dielectrics*, pp. 294–302, Mar. 1980.

[B464] Wray, K. L., and Feldman, E. V, "Shock tube study of the decomposition kinetics of SO_2 F_2," *Journal of Chem. Phys.*, vol. 34, no. 8, pp. 3445–3449, Apr. 1971.

[B465] Yamashita, H., and Mori, T., "The effect of sulphur-hexafluoride on the electrical breakdown of transformer oil," *Electrical Engineering in Japan*, vol. 93, no. 5, pp. 1–5, 1973.

6.1.6 Gaseous dielectrics

[B466] Ahearn, A. J., and Hannay, N. B., "The formation of negative ions of SF_6," *Journal of Chem. Phys.*, vol. 21, no. 1, pp. 119–124, Jan. 1953.

[B467] Akiyama, H., et al., "Voltage-current characteristics of high-current pulsed discharges in SF," *Electrical Engineering in Japan*, vol. 111, no. 3, pp. 29–36, 1991.

[B468] ASTM D2472-92, Specification for Sulfur Hexafluoride.

[B469] Baldo, G.; Diaz, R. R.; and Pesavento, G.; "The effects of flames on discharge characteristics in air gaps," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 2, pp. 954–957, 1992.

[B470] Bargigia, A.; Koltunowicz, W.; and Pigini, A.; "Detection of partial discharges in gas insulated substations," *IEEE Transactions on Power Delivery*, vol. 7, no. 3, pp. 1239–1249, July 1992.

[B471] Bauer, A. W., et al., "Gases superior to SF_6 for insulation and interruption," *EPRI*, Report EL-2620, 1982.

[B472] Baumgartner, R., "Dielectric characteristics of mixtures of sulfur hexafluoride (SF_6) and nitrogen (N_2)," *IEE Third International Conference on Gas Discharges*, Publication no. 118, pp. 366–369, Sept. 1974.

[B473] Baumgartner, R., et al., "Partial discharge (PD) in gas-insulated substations-measurement and practical considerations," *IEEE Electrical Insulation Magazine*, vol. 8, no. 1, pp. 16–27, 1992.

[B474] Becher, W., and Massone, J., "Contribution to the study of the decomposition of SF_6 in electric arcs and sparks," *ETZ-A*, vol. 91, no. 11, pp. 605–610, 1970.

[B475] Boeck, W. A., and Kruger, K., "Arc motion and burn through in GIS," *IEEE Transactions on Power Delivery*, vol. 7, no. 1, pp. 254–261, 1992.

[B476] Boggs, S. A.; Fujimoto, N.; and Stone, G. C.; "A wideband digital correlator for partial discharge location in GIS," *Proceedings of the Third International Symposium on Gaseous Dielectrics*, Knoxville, Tenn., pp. 439–448, Mar. 1982.

[B477] Brechtken, D.; Konig, D.; and Muller, B.; "Dielectric strength of ceramic walls of SF_6 fuses contaminated by silver wire deposits," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 129–132, 1991.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B478] Chen, C. L., and Chantry, P. J., "Photon-enhanced dissociative electron attachment in SF_6 and its isotopic selectivity," *Journal of Chem. Phys.*, vol. 71, no, 10, p. 3897, Nov. 1979.

[B479] Christophorou, L. G., et al., "Recent advances in gaseous dielectrics at Oak Ridge National Laboratory," *IEEE Transactions on Electrical Insulation*, vol. EI-19, p. 550, 1984.

[B480] Christophorou, L. G., and Pace, M. O., eds., *Proceedings of the Fourth International Symposium on Gaseous Dielectrics*, Conference Proceedings, Knoxville, Tenn., Apr. 1984.

[B481] Christophorou, L. G., and Sauers, I., eds., *Gaseous Dielectrics VI*. New York: Plenum Press, 1991.

[B482] Chu, F. Y., "Gas analysis as a diagnostic tool for gas-insulated equipment," *Proceedings of the Fifth International Symposium on Gaseous Dielectrics*, Knoxville, Tenn., pp. 219–227, May 1987.

[B483] Chu, F. Y., et al., "A new approach to moisture measurement and control in gas-insulated switchgear," *Proceedings of the Canadian Electrical Association Spring Meeting*, Toronto, Canada, Mar. 1986.

[B484] Cookson, A. H., "Review of high voltage gas breakdown and flashover of insulators in compressed sulfur hexafluoride," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, vol. 1, pp. 369–376, 1991.

[B485] Cosgrave, J. A., et al., "Non-invasive optical fibre acoustic monitoring of partial discharges within G.I.S.," IEE Conference, Publication no. 363, pp. 274–277, 1992.

[B486] Crichton, B. H.; Lee, D. I.; and Tedford, D. J.; "Pre-breakdown in compressed SF_6 and SF_6/N_2 mixtures in projection perturbed uniform fields," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 199–202, Sept. 1976.

[B487] Davidson, J. C.; Lynch, B. R.; and Farish, O.; "Corona and breakdown in N_2/SF_6 and N_2/O_2 mixtures in static and flowing gas," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 242–245, Sept. 1976.

[B488] "Dielectric strength, boiling point, and toxicity of gases—Different aspects of some molecular properties," *IEEE Transactions on Electrical Insulation*, vol. EI-17, pp. 451–456, 1982.

[B489] Dutton, J.; Harris, F. M.; and Hughes, D. B.; "The dielectric strength of N_2O/SF_6 and N_2O/O_2 mixtures," *IEE Third International Conference on Gas Discharges*, Publication no. 118, pp. 95–99, Sept. 1974.

[B490] EPRI, "Fault and partial discharge location systems for gas-insulated transmission lines," *EPRI*, Report EL-3313, 1983.

[B491] EPRI, "Gases superior to SF_6 for insulation and interruption," *EPRI*, Report EL-2620, 1982.

[B492] EPRI, "Improving gas dielectric performance for substation design," *EPRI Journal, J/A*, p. 20, 1976.

[B493] Felici, N., and Marchal, Y., "New research on the dielectric strength of compressed gases," *Revue Generale de l'Electricite*, vol. 57, pp. 155–162, 1948.

[B494] Ganger, E. B., and Vigreux, J., "May the GIS SF_6 insulation be considered as self-restoring?" *CIGRE Working Group 15-03*, July 1980.

[B495] Garbar, E. D., et al., "Using the ZNOG-500-83U3 transformers for high-voltage tests of insulation in complete elementary-gas switchgear," *Soviet Electrical Engineering*, vol. 63, no. 7, pp. 13–19, 1992.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B496] Garbar, E. D.; Stepenkov, V. V.; and Syromyatnikov, B. D.; "Estimation of GIS gas insulation defects parameters by electric method of partial discharge measurements," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 33–36, 1991.

[B497] Gleizes, A., et al., "Calculation of net emission coefficient in N_2, SF_6 and SF_6N_2 arc plasmas," *Journal of Physics D: Applied Physics*, vol. 24, no. 8, pp. 1300–1309, Aug. 14, 1991.

[B498] Gleizes, A., et al., "Cooling and chemical kinetics in a wall-stabilized SF_6 arc in extinction," *Journal of Physics D: Applied Physics*, vol. 24, no. 8, pp. 1333–1338, Aug. 14, 1991.

[B499] Glidden, S. C., et al., "The effects on electrode damage of delaying the onset of large currents through high pressure spark gaps," *1991 IEEE International Conference on Plasma Science*, p. 198, 1991.

[B500] Gockenbach, J. E., "The breakdown behavior of some new gases and gas mixtures in uniform and nonuniform fields," *Second International Symposium on Gaseous Dielectrics*, pp. 128–136, Mar. 1980.

[B501] Grob, R., et al., "Interaction between SF_6 and water exposed to gamma radiation or to partial discharge," *Conference Recording, IEEE International Symposium on Electrical Insulation*, vol. 5, pp. 147–150, 1984.

[B502] Guruprasad, K. P., et al., "Investigation of the characteristics of an SF_6 rotating arc by a mathematical model," *Proceedings of the 1991 IEEE Power Engineering Society Transmission and Distribution Conference*, pp. 478–484, 1991.

[B503] Hampton, B. F.; Farish, O.; and Larigaldie, S. "Detection of Partial Discharges During a Lightning Surge." In *Gaseous Dielectrics VI*, 1991, pp. 571–576.

[B504] Hanrahan, J. M., and Peterson, A. R., "Adsorption-desorption gas chromatographic-infrared determination of trace disulphur decafluoride in sulfur hexafluoride," *Journal of Chromatography*, vol. 193, pp. 265–270, 1980.

[B505] Hertz, W.; Motschmann, H.; and Wittle, H.; "Investigation of the properties of SF_6 as an arc quenching medium," *Proceedings, IEEE*, vol. 59, pp. 485–492, 1971.

[B506] Heylen, A. E. D., "Paschen characteristics of gases in crossed magnetic field," *Second International Symposium on Gaseous Dielectrics*, pp. 160–168, Mar. 1980.

[B507] Hildebrand, D. L., "Mass spectrometric studies of some gaseous fluorides," *Journal of Physical Chemistry*, vol. 77, no. 7, 1973.

[B508] Jackson, G., et al., "Surface studies of dielectric materials used in spark gaps," *Journal of Applied Physics*, vol. 55, no. 1, pp. 262–268, 1984.

[B509] James, D. R., et al., "Dielectric strength of new gases and gas mixtures," Oak Ridge National Laboratory, 28 pages, 1978.

[B510] James, D. R., et al., "Dielectric strengths of new gases and gas mixtures," *International Symposium on Gaseous Dielectrics*, Publication no. CONF-780301, pp. 224–257, Mar. 1978.

[B511] James, D. R.; Christophorou, L. G.; and Mathis, R. A.; "New unitary and multicomponent gaseous dielectrics," *Second International Symposium on Gaseous Dielectrics*, pp. 115–126, Mar. 1980.

[B512] Jandrell, I. R., and Reynders, J. P., "Consideration of skin effect in high-voltage coaxial systems under transient and steady-state conditions, and its impact on steep travelling waves," *IEE Proceedings, Part C: Generation, Transmission and Distribution*, vol. 138, no. 5, pp. 445–451, Sept. 1991.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B513] Kline, L. E., et al., "Dielectric properties for SF_6 and SF_6 mixtures predicted from basic data," *Journal of Applied Physics*, vol. 50, pp. 6789–6796, Nov. 1979. Also published in *International Symposium on Gaseous Dielectrics*, " Publication no. CONF-780301, pp. 258–275, Mar. 1978.

[B514] Konig, D., and Schuhman, H. "Experimental Studies on the Pressure Rise in GIS by Internal Arcs With Various Material Parameters and Test Arrangements." In *Gaseous Dielectrics VI*, 1991, pp. 459–464.

[B515] Kranz, H. G., and Krump, R., "Partial discharge diagnosis using statistical optimization on a PC-based system," *IEEE Transactions on Electrical Insulation*, vol. 27, no. 1, pp. 93–98, 1992.

[B516] Kristiansen, M.; Guenther, A.; and Schaefer, G. "High Power Gaseous Opening and Closing Switches." In *Gaseous Dielectrics VI*, 1991, pp. 321–329.

[B517] Lagemann, R. T., and Jones, E. A., "The infrared spectrum of SF_6," *Journal of Chem. Phys.*, vol. 19, no. 5, May 1951.

[B518] Lippert, T., and Bohme, H., "Calculation of temperatures in enclosed switchgears with regard to the closed circulation flow of gaseous dielectrics," *European Transactions on Electrical Power Engineering*, vol. 2, no. 1, pp. 27–31, 1992.

[B519] Lundgaard, L. E., et al., "Acoustic diagnoses of GIS: Field experience and development of expert system," *IEEE Transactions on Power Delivery*, vol. 7, no. 1, pp. 287–294, 1992.

[B520] Manion, J.; Philosophos, J.; and Robinson, M.; "Arc stability of electronegative gases," *IEEE Transactions on Electrical Insulation*, vol. El-1, no. 1, 1967.

[B521] Milsore, P. K., "Monte Carlo simulations of magnetic field effects in a sulphur hexafluoride gas discharge," *Journal of Physics D: Applied Physics*, vol. 26, no. 2, pp. 237–243, 1993.

[B522] Mukaiyama, Y, et al. "Abnormal Phenomena Caused by Contact Failure in 300 kV GIS." In *Gaseous Dielectrics VI*, 1991, pp. 475–480.

[B523] Mulcahy, M. J., "Pressurized SF_6 mixture as the insulating medium for high power system components," *IEEE*, Publication 68C6-EI-91, pp. 216–220, 1968.

[B524] Munch, R., "Investigations on the rotary motion of internal arcs in single phase SF_6-insulated switchgear," *European Transactions on Electrical Power Engineering*, vol. 1, no. 4, pp. 181–187, 1991.

[B525] Muramoto, H., et al., "Partial discharge characteristics of wedge gap in SF_6 gas-insulated transformer," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 45–48, 1991.

[B526] Niemeyer, L. "Leader Inception in SF_6." In *Gaseous Dielectrics IV*, edited by L. G. Christophorou, p. 379. Pergamon Press, 1982.

[B527] Niemeyer, L.; Fruth, B.; and Kugel, H. "Phase Resolved Partial Discharge Measurements in Contaminated SF_6 Insulation." In *Gaseous Dielectrics VI*, 1991, pp. 579–585.

[B528] Nitta, T.; Sakai, M.; and Sakuma, S. "Improvement of the Reliability of GIS by Dielectric Diagnostics." In *Gaseous Dielectrics VI*, 1991, pp. 563–569.

[B529] Oda, T., et al., "Thermally stimulated discharge current observation of cross-linked polyethylene," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, pp. 89–92, 1992.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B530] Pace, M. O., et al., "Improved unitary and multi-component gaseous insulators," *IEEE Electrical/ Electronics Insulation Conference*, Publication 77CH1273-2-El, pp. 313–317, Sept. 1977.

[B531] Pace, M. O.; Chan, C. C.; and Christophorou, L. G.; "Application of basic gas research to practical systems," *Seventh IEEE Transmission and Distribution Conference*, Publication CH 1139-5, pp. 168–177, Apr. 1979.

[B532] Pace, M. O.; Chan, C. C.; and Christophorou, L. G.; "Ternary gas mixtures for high voltage industrial insulation," *Proceedings of the 15th Electrical/Electronics Insulation Conference*, Chicago, Ill., pp. 285–288, Oct. 1981.

[B533] Pelletier, J. M., "Dielectric strength of N_2-He Mixtures: Comparison with N_2-SF_6 and CO_2-SF_6 mixtures," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3861–3869, Aug. 1981.

[B534] Pennell, P. M., "The breakdown strength of mixture of SF_6 and nitrogen with 50 c/s ac and impulse stresses," *IEE Conference on Dielectric and Insulating Materials*, 1964.

[B535] Pfeiffer, W., et al., "Forum I: Future research directions in gaseous dielectrics," *Second International Symposium on Gaseous Dielectrics*, pp. 467–474, Mar. 1980.

[B536] Philip, S. F., "Compressed gas insulation in the million-volt range: A comparison of SF_6 with N_2 and CO_2," *IEEE Transactions on Power Apparatus and Systems*, vol. 82, pp. 356–359, June 1963.

[B537] Picard, A., and Turban, G., "Plasma etching at refractory metals and silicon in SF_6 and SF_6-O_2: An analysis of the reaction products," *Plasma Chemistry and Plasma Processing*, vol. 5, no. 4, p. 333, Dec. 1985.

[B538] Popkov, V. I.; Lyapin, A. G.; and Mazurin, I. M.; "The dielectric strength of flexible gas-insulated electric power transmission lines," *Izvestiya Akademii, Nauk, SSSR, Energetika i Transport* (Translated in *Power Engineering-Academy of Sciences of the USSR*, vol. 13, no. 5, pp. 53–60), pp. 59–67, 1975.

[B539] Qiu, et al., "Dielectric strength of gas mixtures comprising SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 1445–1451, May 1983.

[B540] Robledo-Martinez, A.; Guzman, E.; and Hernandez, J. L.; "Dielectric characteristics of a model transmission line in the presence of fire," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 4, pp. 776–782, 1991.

[B541] Sangkasaad, S., "Current status of dielectric research and application in Thailand," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, pp. 582–585, 1992.

[B542] Sauers, I, et al. "Aspects of Environmental Effects of Dielectric Gases." In *Gaseous Dielectrics III*, edited by L. G. Christophorou, p. 387. Pergamon Press, 1982.

[B543] Sauers, I, et al. "S_2F_{10} Formation by Electrical Discharges in SF_6: Comparison of Spark and Corona." In *Gaseous Dielectrics VI*, 1991, pp. 553–561.

[B544] Schmidt, W. F., et al. "Ionic and Electronic Processes in SF_6." In *Gaseous Dielectrics II*, edited by L. G. Christophorou, pp. 1–11. Pergamon Press, 1980.

[B545] Smardzewski, R. R., and Fox, W. B., "Vacuum ultraviolet photolysis of SF_6 and its derivatives in argon matrices: The infrared spectrum of S_2F_{10}," *Journal of Chem. Phys.*, vol. 67, no. 5, p. 2309, Sept. 1977.

[B546] Smardzewski, R. R.; Noftle, R. E.; and Fox, W. B.; "Argon matrix Rahmann and infrared spectra of SF_5Cl, SF_5Br, and S_2F_{10}," *Journal of Molecular Spectroscopy*, vol. 62, pp. 449–457, 1976.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B547] Stone, G. C., et al., "Practical implementation of ultrawideband partial discharge detectors," *IEEE Transactions on Electrical Insulation*, vol. 27, no. 1, pp. 70–81, 1992.

[B548] Tahiliani, V. H., and Reighter, D. H., "Investigation of insulating materials for high-temperature gas insulated systems." Abstract in *IEEE Transaction on Power Apparatus and Systems*, vol. 97, no. 4, p. 1011, July/Aug. 1978.

[B549] Tominaga, S., et al., "SF_6 gas analysis technique and its application for evaluation of internal conditions in SF_6 gas equipment," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 4196–4206, Sept. 1981.

[B550] Van Brunt, R. J., "Minutes of workshop on gaseous dielectrics for use in future electric power systems," National Bureau of Standards, NBSIR 80-1966, 65 pages, Sept. 1979.

[B551] Varivodov, V. N., "Sulfur hexafluoride: State of the art and outlook," *Soviet Electrical Engineering*, vol. 62, no. 12, pp. 17–21, 1991.

[B552] Wang, H. T., and van Heeswijk, R. G. "Particle-Initiated Prebreakdown Characteristics With an Insulator Stressed on 60 Hz Voltage in SF_6." In *Gaseous Dielectrics VI*, 1991, pp. 313–320.

[B553] Wilkins, R. L., "Thermodynamics of SF_6 and its decomposition and oxidation products," *Journal of Chem. Phys.*, vol. 51, pp. 853–854, 1969.

[B554] Williams, P. F. "Laser Triggering of Gas Filled Spark Gaps." In *Gaseous Dielectrics VI*, 1991, pp. 331–338.

[B555] Wilmshurst, J. K., and Bernstein, H. J., "The infrared and Rahmann spectra of disulphur decafluoride," *Canadian Journal of Chem.* vol. 35, p. 191, 1957.

[B556] Wootton, R. E., et al., "Gases superior to SF_6 for insulation and interruption," *EPRI*, Final Report EL-2620, various pages, Sept. 1982.

[B557] Wootton, R. E.; Dale, S. J.; and Zimmerman, N. J.; "Electric strength of some gases and gas mixtures," *Second International Symposium on Gaseous Dielectrics*, pp. 137–147, Mar. 1980.

[B558] Wray, K. L., and Feldman, E. V., "The pyrolysis and subsequent oxidation of SF_6," *Proceedings of the Third International Conference on Combustion*, pp. 229–238, 1971.

[B559] Yamagata, Y., et al., "A sensor powered by pulsed light (for gas density of GIS)," *Transducers, IEEE*, pp. 824–827, 1991.

[B560] Yoshizawa, T., et al., "Boltzmann equation analysis of the electron swarm development in SF_6," *Journal of Physics D: Applied Physics*, vol. 12, p. 1839, 1979.

[B561] Zengin, V., et al. "Analysis of SF_6 Discharge by Optical Spectroscopy." In *Gaseous Dielectrics VI*, 1991, pp. 595–599.

[B562] Zaengl, W. S.; Lehmann, K.; and Albiez, M.; "Conventional PD measurement techniques used for complex HV apparatus," *IEEE Transactions on Electrical Insulation*, vol. 27, no. 1, pp. 15–27, 1992.

6.2 Equipment

6.2.1 Station design

[B563] Aguilar, J., and Fernandez, J. H., "Aspects of the electrical systems design of the COLMI 660 MW coal-fired power plant," *Proceedings of the 54th Annual Meeting of the American Power Conference*, pp. 101–108, 1992.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B564] Allaart, A. J., "Some economic considerations of high-current conductors in substations," *CIGRE*, Paper 23–02, 11 pages, Aug. 1976.

[B565] "American views of SF_6 metalclad substations," *Electrical Review*, p. 810, June 9, 1972.

[B566] Arvay, G. J., and Smith, R. T., "Electrical system for a large cogeneration plant," *Proceedings of the American Power Conference*, vol. 2, pp. 1424–1431, 1992.

[B567] Azumi, K., et al., "Design considerations on three phase enclosure type gas insulated substation," *IEEE Transactions on Power Apparatus and Systems*, vol. 99, no. 3, pp. 947–956, May/June 1980.

[B568] Bargigia, A.; Salvetti, M.; and Vallino, M.; "An in progress experience on seismic qualification of gas insulated substations," *IEEE Transactions on Power Delivery*, vol. 8, no. 1, pp. 132–138, 1993.

[B569] Beehler, J. E., "SF_6 gas insulated station—Operations, ratings, maintenance," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 6, p. 1805, Nov./Dec. 1973.

[B570] Beer, H., et al., "SF_6 substation enhances Canadian HV transmission system," *Energy and Automation*, vol. 11, no. 2, pp. 28–31, Mar./Apr. 1989.

[B571] Beer, H., and Olsen, W., "The new SF_6 insulated metalclad switchgear unit 8D.4 for rated voltages of 245/300 kV," *Siemens Review*, vol. 40, no. 10, pp. 443–445, Oct. 1973.

[B572] Boeck, W., and Troger, H., "SF_6 insulated metalclad switchgear for ultra-high voltages," *CIGRE*, Paper 23–08, 14 pages, Aug. 1972.

[B573] Boersma, R.; Delsing, R.; and Sidler, H.; "New SF_6 design for 420 kV metalclad switchgear," *CIGRE*, Paper 23–09, 12 pages, Aug. 1972.

[B574] Borin, V. N., "Calculating the electric strength of insulation structures in SF_6 suite-type distribution gear," *Electric Technology*, vol. 4, pp. 100–107, 1976.

[B575] Bortnik, I. M., "Selecting operating and test field strengths for H.V. gear with SF_6 insulation," *Electric Technology*, vol. 4, pp. 97–113, 1974.

[B576] Buck, K. E.; Kleine-Tebbe, K. A.; and Rees, V.; "Verification of the seismic resistance of gas-insulated switchgear (GIS)," *IEEE Transactions on Power Delivery*, vol. 8, no. 1, pp. 114–120, 1993.

[B577] Chierichetti, C., and Castelli, D., "High-voltage metalclad switchgear," *CIGRE*, Paper 123, 27 pages, June 1966.

[B578] CIGRE, Discussion "Group 23, Substations, Papers 23–01 to 23–06," *CIGRE*, vol. 1, 46 pages, 1970.

[B579] CIGRE, Discussion "Group 23, Substations, Papers 23–01 to 23–11," *CIGRE*, vol. 1, 80 pages, 1972.

[B580] CIGRE, Discussion "Group 23, Substations, Papers 23–01 to 23–12," *CIGRE*, vol. 1, 40 pages, 1976.

[B581] CIGRE, Discussion "Group 23, Substations, Papers 23–01 to 23–07," *CIGRE*, vol. 1, 57 pages, 1974.

[B582] Cuk, N., et al., "Specification and application of SF_6 compressed gas insulated switchgear: A utility's point of view," *IEEE Power Engineering Society Summer Meeting*, Paper F79 747–7, 5 pages, July 1979.

[B583] de Heus, A. A., "The application of a special system of insulation in a metalclad switchgear for extra high voltages," *CIGRE*, Report 134, 20 pages, June 1966.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B584] Dodds, T. H., "Optimum gas insulated substation switching arrangement for the United States," *IEEE Transactions on Power Apparatus and Systems*, vol. 3, no. 3, p. 853, May/June 1973.

[B585] Flugum, R. W.; Garrity, T. F.; and Vora, J. P.; "Gas insulated substation equipment for UHV problems and needs," *World Electrotechnical Congress*, 20 pages, June 1977.

[B586] Friedrich, R. E., "Requirements for gas insulated equipment through 1980," *American Power Conference*, vol. 37, pp. 1128–1135, 1975.

[B587] Frowein, E. A., and Szente-Varga, H. P., "Metalclad high-voltage installations with SF_6 insulation," *Brown Boveri Review*, vol. 53, no. 4/5, pp. 339–349, Apr./May 1966.

[B588] Fujimoto, T., et al., "Partial discharge phenomena in SF_6 Gas and their sensor signals," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, pp. 1140–1143, 1991.

[B589] Garrity, T F., et al., "Forum II: Future directions in gas-insulated apparatus," *Second International Symposium on Gaseous Dielectrics*, pp. 475–484, Mar. 1980.

[B590] Geitel, K., and Kulik, P., "SF_6 insulated metalclad 110 kV switchgear," *AEG Telefunken Progress*, pp. 113–117, April 1971.

[B591] Gilmozzi, G.; Hashoff, L.; and Lorenz, D.; "Metal enclosed SF_6 insulated switchgear for rated voltages from 420 to 525 kV," *Siemens Review*, vol. 44, pp. 315–319, 1971.

[B592] Graybill, H. W., "EHV gas-insulated substations," *1976 IEEE Region 6 Conference Record,* Publication 76 CH1062-9 Reg. 6, pp. 62–70, Apr. 1976.

[B593] Gremmel, H.; Konig, D.; and Leonhardt, G.; "A new concept for SF_6 insulated metal enclosed high voltage switchgear," *A.I.M. International Meeting*, 12 pages, Nov. 1979.

[B594] Gromier, A., and Voisin, G., "Behavior of SF_6 metalclad substations subjected to rated currents and heavy fault currents," *CIGRE*, Paper 23–06, 19 pages, Aug. 1978.

[B595] Harrington, R. J., and El-Faham, M. M., "Proposed methods to reduce transient sheath voltage rise in gas-insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-104, no. 5, pp. 1199–1206, May 1985.

[B596] Haszman, A.; Philippovich, V.; and Stolarz, W.; "Construction of UHV switchgear on the basis of experiences gained with EHV metalclad and hybrid substations," *CIGRE*, Paper 23-12, 11 pages, Aug. 1980.

[B597] Heiss, W., and Voss, G., "Decision criteria for the use of gas-insulated, metalclad medium voltage switching equipment in power utilities," *Electrizitaetswirtschaft* (Germany), vol. 84, no. 11, pp. 416–419, May 1985.

[B598] Hess, R., et al., "Control of high normal and short circuit currents in SF_6 insulated substations," *CIGRE*, Paper 23-07, 13 pages, Aug. 1978.

[B599] Hogg, P.; Schmidt, W.; and Strasser, H.; "Dimensioning of SF_6 metalclad switchgear to ensure high reliability," *CIGRE*, Paper 23-10, 12 pages, Aug. 1972.

[B600] Hogg, R., "The effect of the current rating on the cost of metalclad high voltage switchgear," CIGRE, Electra, no. 54, pp. 65–70, Oct. 1977.

[B601] "How trouble-free are SF_6 subs?" *Electric Light and Power*, vol. 55, no. 9, p. 30, Sept. 1977.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B602] IEC517: 1990 Gas-insulated metal-enclosed switchgear for rated voltages of 72.5 kV and above.

[B603] Ikeda, T., et al., "Supermobile substations," *Mitsubishi Denki Giho* (Japan), vol. 55, no. 11, pp. 789–793, 1981.

[B604] Karrenbauer, H., "A new modular system for SF_6 insulated switchgear," *A.I.M. International Meeting*, 6 pages, Nov. 1979.

[B605] Kato, F; Ogawa, H.; and Aoki, T; "Recent development in railway substation system and equipment," *Toshiba Review*, no. 131, Jan./Feb. 1981.

[B606] Kato, Y., et al., "Recent aspects of high voltage metal enclosed gas insulated substation," *A.I.M. International Meeting*, 4 pages, Nov. 1972.

[B607] Kennedy, J. J., "Gas-insulated substation equipment for industrial applications," *Record of Conference Papers, 30th Annual Petroleum and Chemical Industry Conference*, Denver, Colo. (New York: IEEE, 1983), pp. 231–237, Sept. 1983.

[B608] Kieffer, Jean, and Voisin, G., "Insulated metalclad substations for 400 kV networks," *Revue Generale de l'Electricite*, no. 708, pp. 550–560, July/Aug. 1981.

[B609] Kikuchi, T.; Tsubaki, T.; and Daimon, G.; "Recent aspects of Hitachi gas insulated switchgear," *Hitachi Review*, vol. 27, no. 5, pp. 237–242,1978.

[B610] Kramer, J. M., and Thakar, H. C., "Design considerations differ for gas-insulated substations," *Transmission and Distribution*, vol. 45, no. 3, pp. 48, 50–55, 1993.

[B611] Krznaric, Z., "Solutions for the erection of distribution substations of hydraulic power plant," *Elektroprivreda* (Yugoslavia), vol. 34, no. 5–6, pp. 125–130, May/June 1981.

[B612] Kulik, P., "The planning of high-voltage and medium-high-voltage switchgear," *AEG-Telefunken Progress*, pp. 54–60, Feb. 1969.

[B613] Kuwahara, H., and Inamura, S., "The present state and future trends of gas-insulated switchgear," *Mitsubishi Denki Giho* (Japan), vol. 57, no. 9, pp. 1–3, 1983 (in Japanese).

[B614] Lager, P.; Rimpp, F.; and Wegener, J.; "Metalclad-SF_6 insulated 110-kV switchgear," *Siemens Review*, vol. 33, pp. 547–550, Nov. 1956.

[B615] Laskowski, L., and Lembo, F., "765-kV gas-insulated substation is world's first," *Transmission and Distribution*, vol. 32, no. 7, pp. 20–22, 24, 26, July 1980.

[B616] Leeds, W. M., "SF_6 switchgear comes of age," *Electrical Review*, pp. 225–227, Aug. 14, 1970.

[B617] Lesnowski, J. J., "GIS replaces conventional switchyard," *Electrical World*, vol. 198, no. 4, pp. 95–97, Apr. 1984.

[B618] Lohmann, V. W., and Bolton, A. C., "Gas-insulated switchgear developed for 765 kV grid," *Mod. Power System*, vol. 5, no. 1, pp. 29, 32–33, Feb. 1985.

[B619] Maczka, W. J., "What lies ahead in substation design?" *Electric Light and Power*, vol. 55, no. 9, pp. 29, 31, Sept. 1977.

[B620] Marsun, R., "BBC-partner for Saudi Arabia's large industry in Yanabu," *BBC Nachr.* (Germany), vol. 65, no. 6, pp. 203–207, 1983.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

[B621] Matsuda, S., et al., "Analytical techniques for the more efficient design of gas-insulated switchgear," *Mitsubishi Denki Giho* (Japan), vol. 57, no. 9, pp. 9–13, 1983 (in Japanese).

[B622] Mauthe, G.; Hogg, P.; and Horisberger, W.; "SF_6 switchgear type ELK for 145 to 525 kV," *Brown Boveri Review*, vol. 60, no. 4, pp. 140–152, Apr. 1973.

[B623] "Metalclad SF_6 substations challenge air insulated designs," *Electrical Review*, vol. 196, no. 5, pp. 149–158, Feb. 7, 1975.

[B624] Morii, K.; Yamashita, Y.; and Harumoto, Y; "Development of 500 kV gas insulated switchgear and its application," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 6, pp. 1945–1957, Nov./Dec. 1973.

[B625] Muller, B.; Slamecka, E.; and Troger, H.; "Trends in the development of SF_6 insulated switchgear," *World Electrotechnical Congress*, June 1977.

[B626] Muller, H. G., "Some aspects for the design of metalclad substations," *CIGRE, Electra*, no. 34, pp. 63–74, May 1974.

[B627] Muller, W., "Single-phase and three-phase encapsulation of SF_6 insulated metalclad switchgear from 123 to 765 kV," *Siemens Review*, vol. 43, no. 3, pp. 122–125, Mar. 1976.

[B628] Munzinger, K.; Poole, D.; and Maier, G.; "A new standardized range of medium voltage cubicles for minimum oil and SF_6 switchgear," *Brown Boveri Review*, vol. 64, pp. 650–655, Nov. 1977.

[B629] Murakami, Y., and Menju, S., "Fundamental techniques for gas-insulated apparatus," *Toshiba Review*, no. 117, pp. 5–12, Sept./Oct. 1978.

[B630] Murayama, Y "Impact on GIS Design by Reducing the Rated LIWL." In *Gaseous Dielectrics VI*, 1991, pp. 491–494.

[B631] Nemoto, B., and Oishi, M., "Gas insulated switchgear (GIS) 'mini-clad' components and application," *Toshiba Review*, no. 117, pp. 21–32, Sept./Oct. 1978.

[B632] Nijland, H. A. H., "Some principles leading to the construction of metal clad switchgear," *CIGRE*, Report 131, 7 pages, 1950.

[B633] Nishida, I.; Ono, M.; and Kurosawa, Y.; "Improvement of SF_6 GIS to cope with the progressing transmission technology," *Hitachi Review*, vol. 40, no. 5, pp. 333–338, 1991.

[B634] Nishida, I.; Sasaki, K.; and Hirasawa, Y.; "Recent aspects of SF_6 gas-insulated switchgear," *Hitachi Review*, vol. 33, no. 3, pp. 141–146, June 1984.

[B635] Oishi, K.; Hirata, K.; and Honda, H.; "500 kV gas insulated combined switchgear," *Hitachi Review*, vol. 27, no. 5, pp. 243–249, 1978.

[B636] Pace, M. O., and Tahiliani, V. H., "Applied discussion panel-summary," *International Symposium on Gaseous Dielectrics*, Publication no. CONF-780301, pp. 428–446, Mar. 1978.

[B637] Pounds, C. G., et al., "Fuji's SF_6 gas circuit breakers and cubicles delivered to Dow Chemical, U.S.A." *Fuji Elect. Review*, vol. 30, no. 2, pp. 84–88, 1984.

[B638] Radgen, H., "The VIS system of switchgear construction," *AEG-Telefunken Progress*, pp. 115–119, Apr. 1973.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B639] Rebbapragada, R. V., et al., "Design modification and layout of utility substations for six phase transmission," *IEEE Transactions on Power Delivery*, vol. 8, no. 1, pp. 24–30, Jan. 1993.

[B640] "Remarkably improved Toshiba substations," *Toshiba Review Inter Ed.*, vol. 58, June 1971.

[B641] "Reyrolle and SF_6," *Reyrolle (Parsons) Review*, vol. 2, no. 6, pp. 1–12, Winter 1976–1977.

[B642] Rimpp, F., "Totally three phase enclosed SF_6 insulated switchgear for 123/145 kV," *A.I.M. International Meeting*, 5 pages, Nov. 1979.

[B643] Roberts, P, "Design of reduced site area for high-voltage substation," *CIGRE*, Paper 126, 17 pages, June 1966.

[B644] Schaumann, R., and Poole, D., "The H system—A new generation of SF_6 medium voltage switchgear," *Brown Boveri Review*, vol. 64, pp. 644–649, Nov. 1977.

[B645] Schmitz, W., and Strasser, H., "Design, reliability and operation of SF_6 metalclad switchgear," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 6, p. 2262, Nov./Dec. 1972.

[B646] Schmitz, W.; Watson, P. W.; and Leibold, A.; "SF_6 GIS of three-phase enclosure concept with voltage range of 69 to 145 kV," *Seventh IEEE Transmission and Distribution Conference*, Publication ChII39-5, pp. 429–435, Apr. 1979.

[B647] "SF_6 offers route to maintenance-free switchgear," *Energy International*, vol. no. 10, pp. 30–37, Oct. 1974.

[B648] Shaw, B. J., "Gas-insulated switchgear at Keadby 132 kV substation," *Power Engineering Journal*, vol. 7, no. 2, pp. 73–82, 1993.

[B649] Spindle, H. E., "Gas-insulated substations—Past, present and future," *1976 IEEE Region 6 Conference Record*, Publication 7G CH1062-9 Reg. 6, pp. 59–61, Apr. 1976.

[B650] Stopar, S. J., "Design, construction, and operation of an indoor 138 kV gas-insulated substation," *Proceedings of the American Power Conference*, Chicago, Ill., vol. 54, pp. 506–507, 1983.

[B651] Szente-Varga, H. P., "550 kV SF_6 gas-insulated switchgear for the Italpu hydro power station," *Brown-Boveri Review*, vol. 68, no. 3–4, pp. 157–159, Mar./Apr. 1981.

[B652] Szente-Varga, H. P., "High voltage metalclad switchgear installations with SF_6 insulation," *Brown Boveri Review*, vol. 56, no. 7, p. 245, July 1959.

[B653] Szente-Varga, H. P., "Metalclad switchgear with SF_6 insulation for 72 to 525 kV," *Brown Boveri Review*, vol. 56, no. 11/12, pp. 570–580, Nov./Dec. 1969.

[B654] Szente-Varga, H. P., and Krafft, N., "Metalclad high-voltage switchgear with SF_6 insulation," *Brown Boveri Review*, vol. 54, no. 12, pp. 769–774, Dec. 1967.

[B655] Takagi, T., et al., "Development of 500 kV miniclad," *CIGRE*, Paper 23-02, 17 pages, Aug. 1972.

[B656] Takagi, T., et al., "Special high service current SF_6 metal enclosed switchgear of EHV," *CIGRE*, Paper 23-01, 10 pages, Aug. 1976.

[B657] Tanabe, T., et al., "Systems engineering for gas-insulated switchgear," *Mitsubishi Denki Giho* (Japan), vol. 57, no. 9, pp. 14–17, 1983 (in Japanese).

[B658] "The design and application of EHV substations," *IEE Conference*, Publication 157, 150 pages, Nov. 1977.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B659] Thuries, E., and Vigreux, J., "Ultra high voltage substations," *CIGRE*, Paper 23-11, p. 10, Aug. 1980.

[B660] Toda, H., et al., "Development of 800 kV gas-insulated switchgear," *IEEE Transactions on Power Delivery*, vol. 7, no. 1, pp. 316–323, 1992.

[B661] Tokes, J., "Short-circuit protection of SF_6 gas-insulated switching equipment," *Elektrotechnicka* (Hungary), vol. 78, no. 1–2, pp. 12–16, Jan./Feb. 1985.

[B662] "Very high current SF_6 mini substation developed in Japan," *Electrical Review*, p. 33, Aug. 27- Sept. 3, 1976.

[B663] Vigreux, J., "Arrangement and architecture of metal-enclosed substations, *CIGRE, Electra*, no. 69, pp. 23–32, Mar. 1980.

[B664] Vontobel, J., "SF_6 metal enclosed substations for very high rated continuous rated short-circuit and ground fault currents," *CIGRE*, Paper 23-03, 8 pages, Aug. 1974.

[B665] Vontobel, J., and Gaigg, W., "A new generation of SF_6 switchgear," *Electrical Review*, pp. 50, 53–54, Nov. 18, 1977.

[B666] Watanabe, Y., et al., "Construction of first gas-insulated transmission line in Japan," *IEEE Power Engineering Society Winter Meeting*, Atlanta, Ga., Conference Paper 81/WM118-9, Feb. 1981.

[B667] Whitehead, D. L., and Spindle, H. E., "Pressurized SF_6 gas-insulated high voltage switchgear," *IEEE Winter Power Meeting*, Paper 31-PP 67-39, 7 pages, Feb. 1967.

[B668] Wieland, A.; Koglin, B. B.; and Leonhardt, G.; "Package substation system type ENK with SF_6 insulation," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 7, pp. 2300–2307, July 1982.

[B669] Yoshida, Y., et al., "Gas-insulated switchgear and site and environmental considerations," *Mitsubishi Denki Giho* (Japan), vol. 57, no. 9, pp. 23–38, 1983 (in Japanese).

[B670] Yoshikawa, I., and Inamoto, K., "Hitachi medium voltage metal-clad switchgear with SF_6 gas circuit breaker," *Hitachi Review*, vol. 27, no. 5, pp. 255–262, 1978.

6.2.2 Station installation and operation

[B671] Alexander, R. W., and Stevenson, J. B., "Installing 500 kV gas-insulated substations," *Transmission and Distribution*, vol. 36, no. 4, pp. 22–24, Apr. 1984.

[B672] Bachmann, B., and Hunziker, R., "Several years of operating experience with medium-voltage GIS PG 100," *Sprecher Energie Review*, no. 1, pp. 13–16, 1991.

[B673] "CEGB studies 400 kV metalclad switchgear," *Electrical Review*, p. 443, Mar. 31, 1972.

[B674] Chu, F. Y.; Ford, G. L.; and Law, C. K.; "Estimation of burn-through probability in SF_6-insulated substations," *IEEE Power Engineering Society Summer Meeting*, Portland, Ore., Conference Paper, July 1981.

[B675] Chu, F. Y., and Tahiliani, V., "Gas insulated substations fault survey," *IEEE Transactions on Power Apparatus and Systems*, vol. 99, no. 6, pp. 2351–2355, Nov./Dec. 1980.

[B676] Chu, F. Y., and Williamson, A., "Fault location in SF_6-insulated substations using thermal techniques," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 7, pp. 1990–1997, July 1982.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B677] Clark, T. F., et al., "Installation of compact substation equipment," *American Power Conference*, vol. 34, pp. 1039–1043, Apr. 1972.

[B678] Collier, R. T., "230 kV SF_6 insulated sub serves large industrial customer," *Transmission and Distribution*, vol. 31, no. 8, pp. 42–44, Aug. 1979.

[B679] Collier, R. T.; Doughty, F E.; and Kennedy, J. J.; "550 kV Gas insulated station energized," *Transmission and Distribution*, vol. 32, no. 7, pp. 28–30, July 1980.

[B680] Cooper, E. A., and Nikolas, J. T., "Gas-insulated switchgear solves difficult problems at hydroelectric plants," *American Power Conference*, vol. 39, pp. 1295–1303, 1977.

[B681] "First French EHV metalclad substations," *Electrical Review*, pp. 132–133, Jan. 26, 1968.

[B682] Fischer, F. E.; Wert, A. C.; and Hake, M. R.; "Compressed-gas-insulated substations of the Consolidated Edison Company of New York, Inc.," *Doble Client Conference*, sec. 5, pp. 901F–912F, Apr. 1975.

[B683] Fischer, T. N., Jr., "Utility experience with gas-insulated equipment," *EPRI*, Final Report, EL80-8-LD, Dec. 1980.

[B684] Frantz, R. A.; Lohmann, V. W.; and Spendal, E.; "420 kV SF_6 Gas-insulated switchgear installation for the pumped storage plant Drakensberg," *Brown Boveri Review*, vol. 68, no. 3–4, pp. 113–119, Mar./Apr. 1981.

[B685] Garrity, T. F.; Matulic, R.; and Rhodes, G.; "Installation and field testing of 138 kV SF_6 gas insulated station and transmission line," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-94, no. 5, pp. 1580–1598, Sept./Oct. 1975.

[B686] "Gas insulated substation for Cementa, Sweden," *ASEA Journal*, vol. 52, no. 4, p. 99, 1979.

[B687] Gothard, J. V., "MICA 500 kV SF_6 CGI substation," *Doble Client Conference*, sec. 9, pp. 201–208, Apr. 1977.

[B688] Graybill, H. W., "Workshop on user experience with gas-insulated substations," *EPRI*, Report EL-2189, Dec. 1981.

[B689] Habedank, U., "Short line fault interruption, critical path length," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3545–3552, July 1981.

[B690] Hale, C. K., "Experience with 345 kV GIS," *Transmission and Distribution*, vol. 36, no. 4, pp. 38–42, Apr. 1984.

[B691] Harper, W. E., and Clark, T. F., "Big space savings with mini-subs," *Allis Chalmers Engineering Review*, vol. 32, no. 2, pp. 4–9, 1972.

[B692] Hathaway, G. H., "Design of Detroit Edison SF_6 compact substations," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 6, p. 1805, Nov./Dec. 1973. Published under the title, "Where land is scarce and $$ high consider the SF_6 mini sub," *Transmission and Distribution*, pp. 34–38, 109, Dec. 1973.

[B693] Hathaway, G. H., and Sparks, W. W., "Installation of Detroit Edison gas-insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. 94, no. 5, pp. 1608–1617, Sept./Oct. 1975.

[B694] Hauge, O.; Rein, A.; and Sletthaug, J.; "High voltage SF_6-insulated metalclad switchgear for underground hydro power stations in Norway," *CIGRE*, Paper 23-03, 9 pages, Aug. 1972.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B695] Herrmann, G., and Stolarz, W, "Extension of a 245 kV SF_6 switchgear installation without interruption of service," *Brown Boveri Review*, vol. 63, no. 4, pp. 226–231, Apr. 1976.

[B696] Johnson, W. A., "Ways to get the most out of an SF_6 station," *Transmission and Distribution*, vol. 27, no. 10, pp. 34–36, 100, Oct. 1975.

[B697] Kansog, J. D. C., and Mark, D. A., "The Laquna Verde 400/230 kV hybrid gas insulated substations," *IEEE Power Engineering Society Winter Meeting*, Paper A80 095-0, 4 pages, Feb. 1980.

[B698] Kennedy, J. J., "Gas-insulated substation equipment for industrial applications," *IEEE Transactions on Industrial Applications*, vol. IA-20, no. 6, pp. 1440–1447, Nov./Dec. 1984.

[B699] Kennedy, J. J.; Cappel, R. J.; and Beringhaus, G. W.; "First SF_6 sub at nuke plant saves $860,000," *Electric Light and Power*, p. 53, Oct. 1977.

[B700] Kominiak, L. A., and Buchsbaum, J. A., "Midtown SF_6 switching station installed," *Transmission and Distribution*, vol. 29, no. 4, pp. 42–46, Apr. 1977.

[B701] Krznaric, Z., "Some solutions for the erection of distribution substations of hydraulic power plants," *Elektroprivreda* (Yugoslavia), vol. 34, no. 5–6, pp. 125–130, May/June 1981.

[B702] Kypreos, G., "Design of East Side 138 kV gas insulated substation." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 94, no. 4, p. 1094, July/Aug. 1975.

[B703] Laskowski, L. M., and Lembo, F., "765 kV Gas insulated substation is world's first," *Transmission and Distribution*, vol. 32, no. 7, pp. 20–22, 24, 26, July 1980.

[B704] Marks, J. A., "Giant planning for pygmy subs," *Electric Light and Power*, pp. 37–42, July 1973.

[B705] Martins, H. J. A.; Fernandes, V. R.; and Jacobsen, R. S. "Gas-Insulated Substation Performance in Brazilian System." *In Gaseous Dielectrics VI*, 1991, pp. 443–448.

[B706] Matsusaka, H., and Kikkawa, T., "69 kV GIS substation in Thailand," *Meiden Rev*., no. 1, pp. 18–21, 1984.

[B707] Mattia, J., "Field experience with Delle-Alsthom high voltage metal clad SF_6 minisubstation," *Doble Client Conference*, sec. 5, pp. 1201–1214, Apr. 1971.

[B708] Matulic, R., "AEP sets design of 765 kV SF_6 substation," *Electrical World*, vol. 180, pp. 53–54, Oct. 1, 1973.

[B709] Matulic, R., and Laskowski, L. M., "First 765 kV SF_6 station proves successful," *Electrical World*, vol. 194, no. 3, pp. 44–47, Aug. 1, 1980.

[B710] Maury, E.; Parisielle, R.; and Vigreux, J.; "Commissioning and initial operating results of 225 kV SF_6-insulated metalclad substations," *CIGRE*, Paper 23-06, 19 pages, Aug. 1970.

[B711] Menon, K. V., "145 kV SF_6 switchgear installation at Beaconsfield West, Australia," *Brown Boveri Review*, vol. 64, pp. 169–173, Mar. 1977.

[B712] Menon, K. V., "How Sydney came to get a 145 kV SF_6 switchgear installation," *Electrical Review*, pp. 47, 49–50, Oct. 28, 1977.

[B713] "Mini switchgear eases siting problems in Japan," *Electrical Review*, p. 161, July 30, 1971.

[B714] "Mini-sub Packs 260 MVA in tennis court sized area," *Electrical World*, pp. 44–45, Oct. 6, 1969.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B715] Minkwitz, R. E., "Some experience with SF_6-insulated equipment," *EPRI*, Final Report EL80-8-LD, Dec. 1980.

[B716] "More EHV metalclad substations planned," *Electrical Review*, p. 479, Oct. 3, 1970.

[B717] Mori, E., and Kawashima, K., "Transformer technology appropriate to environment," *Keizaburo Hitachi Review*, vol. 40, no. 5, pp. 327–332, Oct. 1991.

[B718] Morii, K., et al., "Field experience and future trends of 500 kV gas insulated metal-clad substations," *CIGRE*, Paper 23-02, 20 pages, Aug. 1978.

[B719] Oishi, M., "500 kV Substation equipment in conformity to environmental conditions," *Toshiba Review Inter Ed.*, vol. 77, pp. 9–19, Jan. 1973.

[B720] Olsen, W., and Wegener, J., "Metalclad SF_6, insulated switchgear in the 110 kV systems of Berlin and Cologne," *Siemens Review*, vol. 37, no. 1, pp. 40–45, Jan. 1970.

[B721] "Pocket station for mini or maxi voltages," *Transmission and Distribution*, p. 47, Apr. 1972.

[B722] Premur, K., "SF_6 in electrical installations," *Elteknik* (Denmark), pp. 12–15, June 1984.

[B723] "Preplanning can eliminate most historical SF_6 problems," *Electric Light and Power*, p. 40, July 1979.

[B724] Raimbault, J., et. al., "Electricity supply to large towns and metal clad equipment for 225 kV networks," *CIGRE*, Paper 136, 55 pages, June 1966.

[B725] "Rapid increase in SF_6 metalclad switchgear application," *Electrical Review*, vol. 195, no. 5, pp. 319–324, Sept. 13, 1974.

[B726] Reimers, T. D., and Owens, J. B., "345 kV metalclad pressurized SF_6 substation design," *CIGRE*, Paper 23-04, 8 pages, Aug. 1970.

[B727] Rimpp, F., "Applications of EHV metalclad switchgear with SF_6 insulation," *Energy International*, vol. 8, no. 5, pp. 18–21, May 1971.

[B728] Rimpp, F., "Typical application of 110/132 kV metalclad switchgear with SF_6 insulation," *Siemens Review*, vol. 37, pp. 585–589, Nov. 1970.

[B729] Scherer, H. N., Jr., et al., "Gas-insulated 800 kV station," *CIGRE*, Paper 23-09, 10 pages, Aug. 1976.

[B730] Schroeder, D. A., "Economic application of SF_6 compact substations," *American Power Conference*, vol. 37, pp. 1136–1147, Apr. 1975.

[B731] Scott, J. C., and Reilly, M. J., "Urban area served by 230 kV sub," *Transmission and Distribution*, pp. 59–62, Sept. 1979.

[B732] "SF_6 unscrambles 'spaghetti junction,'" *Electric Light and Power*, p. 38, July 1978.

[B733] Shiota, H., et al., "240 kV Gas-insulated switchgear for the Takano switchgear station of Kyushu Electric Power Company," *Mitsubishi Denki Giho* (Japan), vol. 57, no. 12, pp. 38–43, 1983.

[B734] Sparks, W. W., and Hathaway, G. H., "Operation of Detroit Edison gas-insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 1, pp. 344–351, Jan./Feb. 1976.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B735] Spendal, E., and Menon, K. V., "Germany's first 245 kV metalclad SF_6 switchgear installation," *Brown Boveri Review*, vol. 60, no. 2/3, pp. 108–116, Feb./Mar. 1973.

[B736] Spindle, H. E., and Bolin, P., "Westinghouse modular design of GIS and CGIT provides ease of installation, maintenance and future expansion," *Doble Client Conference*, sec. 5, pp. 901B-904B, Apr. 1975.

[B737] Steiner, K., "SF_6 insulated metalclad switchgear and open-air switchgear in Austria," *Elektrotech, and Maschimenbau* (Austria), vol. 101, no. 6, pp. 303–305, June 1984.

[B738] Supplee, G. W., "Compatibility of design—Compact substation equipment," *American Power Conference*, vol. 34, pp. 1032–1038, Apr. 1972.

[B739] Szente-Varga, H. P., "170 kV Metalclad SF_6 switchgear for Sempersteig substation," *Brown Boveri Review*, vol. 57, no. 12, pp. 572–577, Dec. 1970.

[B740] Szente-Varga, H. P., "High-voltage SF_6 switchgear installations, applications and performance," *Brown Boveri Review*, vol. 62, no. 4, pp. 139–147, Apr. 1975.

[B741] Tahiliani, V.; Lannes, W. J.; and Miners, K. B.; "Diagnostic techniques to detect abnormal operating conditions in GIS," *CIGRE*, Paper 23–08, 1984.

[B742] Takagi, T.; Saba, S.; and Kataoka, K.; "Miniaturization of substation in urban districts" *World Energy Conference*, Paper 1.3–159, 22 pages, June/July 1971.

[B743] Taylor, D. J., and Lincoln, M. C., "GIS built among high-rise buildings," *Transmission and Distribution*, vol. 36, no. 4, pp. 18–20, Apr. 1984.

[B744] Tokoro, K., et al., "Development of electronic potential and current transducers suitable for gas-insulated switchgear and adequate for application to substation digital control system," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 12, pp. 3967–3976, Oct. 1982.

[B745] Tsuchiya, Y., et al., "The 10000-operation field experience since 1965 of Japan's first SF_6 gas circuit breakers," *Mitsubishi Denki Giho* (Japan), vol. 55, no. 7, pp. 54–58, 1981.

[B746] Ushio, T., et al., "Design and application concept of gas insulated substations," *A.I.M. International Meeting*, 5 pages, Nov. 1979.

[B747] Vigreux, J., "Sulphur hexafluoride for EHV Urbanmore substations," *Energy International*, vol. 7, no. 8, pp. 18–21, Aug. 1970.

[B748] Vujovic, V., "The 110/2OkV substation at Zagreb-Sjever (Yugoslavia)," *Koncar Strucne Info.*, vol. 31, no.3, pp. 22–28, 1984.

[B749] Working Group 23.03, "The compilation of the international experience on installation and operation of metalclad substations," *CIGRE*, Paper 23–04, 15 pages, Aug. 1972.

[B750] "Workshop on user experience with gas-insulated substations," vol. EPRI-EL-2189, Portland, Ore., July 1981.

[B751] "World's first SF_6 mini-sub has good record," *Electrical World*, p. 50, Nov. 15, 1972.

[B752] Zava, M. B., et al., "MV transportable, remote controlled unit for HV/MV sub-stations," *CIRED*, vol. 1, pp. 1.20/1–5, 1993.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

6.2.3 Transmission line design

[B753] Araki, T., "Development and application of 500 kV gas insulated transmission lines," *Keikinzoku Yosetsu/ Journal of Light Metal Welding and Construction* (Japan), vol. 25, no. 8, pp. 353–361, 1987.

[B754] Araki, T.; Hayashi, T.; and Kuroyanagi, Y.; "Application of 8000A class 275 kV gas insulated transmission line," *Transactions of the Institute of Electrical Engineers of Japan*, vol. 110:7, pp. 591–597, July 1990.

[B755] Belanger, B. C.; Garrity, T. F.; and Smith, W. G.; "ERDA's research program for advanced power transmission," *Proceedings of the IEEE 1976 National Aerospace and Electronics Conference*, Dayton, Ohio, pp. 637–643, May 1976.

[B756] Bolin, P. C., et al., "Manufacture and installation of a three conductor SF_6 insulated transmission line," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 7, pp. 1966–1974, July 1982.

[B757] Bolin, P. C., et al., "Mechanical design and test of 1200 kV semi-flexible SF_6 insulated transmission line," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 6, pp. 1630–1637, June 1982.

[B758] Bondon, L. A., "High Voltage Flexible Cable for Pressurized Gas Insulated Transmission Line," U.S. Patent, Nov. 1987.

[B759] Bortnik, I. M., "The statistical characteristics of compressed gas insulation for the underground transmission lines," *IEEE Power Engineering Society Underground Transmission and Distribution Conference*, Publication 72-CHO-608-O-PWR (suppl.), pp. 317–322, Jan. 1973.

[B760] "Compressed-gas cables find application at both ends of the needed range of ratings," *Electrical World*, p. 45, July 1, 1974.

[B761] Cookson, A. H., "Compressed gas insulated transmission systems: The present and the future," *International Symposium on Gaseous Dielectrics*, Publication no. CONF-780301, pp. 286–313, Mar. 1978.

[B762] Cookson, A. H., "Gas-insulated cables," *IEEE Transactions on Electrical Insulation*, vol. El-20, no. 5, p. 859, Oct. 1985.

[B763] Cookson, A. H., "Transmission Line Including Support Means with Barriers," Patent, U.S. Department of Energy, October 1982.

[B764] Cookson, A. H., Garrity, T. F., and Samm, R. W., "Research and development in the United States on three-conductor and UHV compressed gas insulated transmission lines for heavy load transmission," *International Conference on Large High Voltage Electric Systems (CIGRE)*, Paris, France, pt. 1, Paper 21–09, pp. 1–12, Aug./Sept. 1978.

[B765] Cookson, A. N.; Lapen, R. J.; and Kothmann, R. E.; "Analysis of forced cooling of compressed gas insulated transmission lines," *EPRI*, Final Report EL-228, Project 7840–1, 103 pages, Dec. 1976.

[B766] Cookson, A. H., and Pederson, B. O., "Gas Insulated Transmission Line With Insulators Having Field Controlling Recesses," U.S. Patent, July 1984.

[B767] Cookson, A. H., and Pedersen, B. O., "Thermal measurements in a 1200 kV compressed gas insulated transmission line," *IEEE Transmission and Distribution Conference*, Publication CH1139-5, pp. 163–167, Apr. 1979.

[B768] Corbett, J. T., et al., "Three-conductor compressed-gas cable field demonstration," *EPRI*, Report EL-6771, vol. 2, Mar. 1990.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B769] Cronin, J. C., "Optimized design for gas cable systems," *EPRI*, Project 7825 and ERDA E(49-18)-1615, Final Report, 128 pages, Sept. 1975.

[B770] Cronin, J. C., et al., "Basic design characteristics of a three conductor gas-insulated power transmission system," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 6, p. 1812, Nov./Dec. 1973.

[B771] Cronin, J. C., et al.,"Incorporating flexibility into a gas-insulated transmission system designed for underwater use," *Underground Transmission and Distribution Conference*, IEEE, Dallas, Tex., pp. 343–348, Apr. 1974.

[B772] Cronin, J. C., and Conangla, A., "Heat flux-temperature relationships for closely spaced underground power transmission conductors," *IEEE Transactions on Power Apparatus and Systems*, vol. 90, no. 3, pp. 1256–1260, May/June 1971.

[B773] Cronin, J. C., and Dethlefsen, R., "Guide to use of gas cable systems," *EPRI*, Project 7825 and ERDA E(49-18)-1615, Technical Report, 83 pages, Sept. 1975.

[B774] Cronin, J. C., and Moran, J. A., Jr., "Economics of gas insulated power transmission systems," *IEEE Underground Transmission and Distribution Conference*, IEEE, Dallas, Tex., pp. 519–523, Apr. 1974.

[B775] Czech, F., and Floessel, C. D., "Metal-Encapsulated Gas-Insulated High Voltage Line," Patent, Canada, July 1987.

[B776] Dale, S. J., "1200 kV Compressed gas-insulated test loop completion," Westinghouse Electric Corporation, Trafford, Pa., Final Report, Sept. 1983.

[B777] Dale, S. J., "1200 kV Semi-flexible gas-insulated transmission program," Westinghouse Electric Corporation, Trafford, Pa., vol. 1: Final Report and vol. 2: Final Report Appendices, Feb. 1984.

[B778] Dale, S. J., "Vertically Aligned Gas-Insulated Transmission Line Having Particle Traps at the Inner Conductor," U.S. Patent, Apr. 1984.

[B779] Dale, S. J., et al., "Dielectric design and test of 1200 kV semi-flexible SF_6 insulated transmission line," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-102, no. 2, pp. 400–409, Feb. 1983.

[B780] Deschamps, L.; Schwab, A.; and Jegou, Y.; "Electric power transmission by gas-insulated cables," *Bulletin de la Direction des Etudes et Recherches* (France), serie B, no. 3–4, pp. 93–130, 1973.

[B781] "Design and test of three-conductor gas insulated cable," *EPRI*, Project 7816 and ERDA E (49-18)-1560, Final Report, 103 pages, June 1975.

[B782] DeSteese, J. G., et al., "Development of an evaporation-cooled underground transmission system," *EPRI*, TD-229, Project 7834 and ERDA E(49-18)-2126, Final Report, 115 pages, Aug. 1976.

[B783] Doepken, H. C., Jr., "Calculated heat transfer characteristics of air and SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 89, no. 8, pp. 1979–1985, Nov./Dec. 1970.

[B784] Doepken, H. C., Jr., "Compressed gas insulated cables with increased capacity and reduced cost," *IEEE Underground Transmission and Distribution Conference*, pp. 536–540, Apr. 1974.

[B785] Doepken, H. C., Jr., "Compressed gas insulation for concentric power lines," *Proceedings of the Eighth Electrical Insulation Conference*, pp. 202–205, 1968.

[B786] Doepken, H. C., Jr., "Compressed gas insulation in large coaxial lines," Ph.D. diss., Massachusetts Institute of Technology, 1968.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B787] Doepken, H. C., Jr., "Compressed gas insulation in large coaxial systems," *IEEE Transactions on Power Apparatus and Systems*, vol. 88, no. 4, pp. 364–369, Apr. 1969.

[B788] Doepken, H. C., Jr., "The present and future of compressed gas insulated transmission lines," *IEEE Power Engineering Society Underground Transmission and Distribution Conference*, Publication 72-CHO-608-0-PWR (suppl.), pp. 326–328, Jan. 1973.

[B789] Eidinger, A., "Design, application and testing of SF_6 insulated cable," *Brown Boveri Review*, vol. 63, no. 11, pp. 688–694, Nov. 1976.

[B790] Eidinger, A., "Transmission line development and short circuit powers," *Elektrotechniek*, vol. 53, no. 10, pp. 542–550, Aug. 1975.

[B791] Eidinger, A., and Dobsa, J., "Efficiency of direct and indirect cooling of underground transmission systems having solid or gaseous insulation" *CIGRE*, Paper 21–40, Aug. 1976.

[B792] Eidinger, A., and Floessel, C. D., "Dual Underground Cable System for Transmitting Electrical Power," U.S. Patent no. 3869562.

[B793] Eidinger, A., and Floessel, C. D., "SF_6 compressed gas insulated cables for extra high power transmission," *Brown Boveri Review*, vol. 61, no. 4, pp. 167–173, Apr. 1974.

[B794] Eidinger, A., and Klement, W., "Underground power transmission using compressed-gas-insulated cables," *International Conference on Large High-Voltage Electric Systems (CIGRE), 25th Session, Bull no. 1*, Paris, France, Paper 21-11, Aug. 1974.

[B795] "Elimination of particle effects in $SF_6$1-insulated transmission systems," Westinghouse Electric Corporation, Pittsburgh, Pa., Report, Aug. 1983.

[B796] Fischer, F. E., and Williams, J. A., "First underground 345-kV gas-insulated transmission system energized," *Journal: Transmission and Distribution* (U.S.), vol. 24, no. 5, pp. 37–39, May 1972.

[B797] Fisher, W. H., "Particle Trap To Sheath Non-Binding Contact for a Gas-Insulated Transmission Line Having a Corrugated Outer Conductor," U.S. Patent, Apr. 1984.

[B798] Fisher, W. H.; Cookson, A. H.; and Yoon, K. H.; "Particle Trap to Sheath Contact for a Gas-Insulated Transmission Line Having a Corrugated Outer Conductor," U.S. Patent, Apr. 1984.

[B799] Fisher, W. H., and Yoon, K. H., "Conductor Load Bearing Roller for a Gas-Insulated Transmission Line Having a Corrugated Outer Conductor," U.S. Patent, Apr. 1984.

[B800] Franca, W. J., and Pereira, M. J., "Utilization of gamagraphy in shielded substation," *Iberian-American Congress on Maintenance and 2 Brazilian Congress on Maintenance*, Rio de Janeiro, Brazil, Report, Conference Literature, Dec. 1987.

[B801] Fujimoto, N.; Boggs, S. A.; and Madge, R. C.; "Measurement of transient potentials in coaxial transmission lines using coaxial dividers," *Proceedings of Workshop on Measurement of Electrical Quantities in Pulse Power Systems*, Boulder, Colo., pp. 69–79, Mar. 1981.

[B802] Fukuda, S., "Ampacity of direct-buried EHV cables insulated with SF_6 gas," *IEEE Transactions on Power Apparatus and Systems*, vol. 89, no. 3, pp. 436–491, Mar. 1970.

[B803] Fukuda, S., "Current carrying and short circuit tests on EHV cables insulated with SF_6 gas," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-88, no. 2, pp. 147–156, Feb. 1969.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B804] Fukuda, S., "EHV cables with compressed SF_6 gas insulation," *IEEE Transactions on Power Apparatus and Systems*, vol. 86, no. 1, pp. 50–66, Jan. 1967.

[B805] "Gas-insulated EHV system can go above ground or under water," *Electrical World*, p. 54, Feb. 15, 1972.

[B806] Gillies, D. A., "Compressed gas insulation systems," *Doble Client Conference*, Minutes, sec. 5, pp. 901E–902E, Apr. 1975.

[B807] Graneau, P., et al., *IEEE Underground Transmission Conference*, Pittsburgh, Pa., May 1972.

[B808] Graybill, H. W., and Williams, J. A., "Underground power transmission with isolated-phase gas-insulated conductors," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-89, no. 1, pp. 17–23, Jan. 1970.

[B809] Hampton, B. F., "A flexible, compressed gas-insulated cable," *IEE Conference*, Publication no. 44, pp. 61–64, Sept. 1968.

[B810] Hampton, B. F., "Current-carrying and short-circuit tests on EHV cables insulated with SF_6 gas," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-88, no. 2, Feb. 1969.

[B811] Henry, G., and Kieffer, J., "Device and Process for Assembling a Clad Busbar of an Electrical Installation," Patent, Canada, Aug. 1988.

[B812] Ishikawa, M., et al., "An approach to the suppression of sheath surge induced by switching surges in a GIS/power cable connection system," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp.528–538,Feb.1981.

[B813] Itaka, K.; Araki, T.; and Hata, H.; "Heat transfer characteristics of gas spacer cables," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 5, pp. 1579–1585, Sept./Oct. 1978.

[B814] Itaka, K., and Ikeda, C., "Dielectric characteristics of compressed gas insulated cables," *IEEE Transactions on Power Apparatus and Systems*, vol. 59, no. 8, pp. 1986–1994, Nov./Dec. 1970.

[B815] Jackson, R. B., and Miners, K. B., "SF_6 gas analysis service—Analytical data and case histories," *The 49th Annual International Conference, Doble Clients*, Boston, Mass., Apr. 1982.

[B816] Jeffs, E., "Germany pushes pipe conductor development," *Energy International*, vol. 12, no. 7, pp. 13–15, July 1975.

[B817] Johnson, B. L.; Doepken, H. C., Jr.; and Trump, J. G.; "Operating parameters of compressed gas insulated transmission lines," IEEE Transactions on Power Apparatus and Systems, vol. 88, no. 4, pp. 369– 375, Apr. 1969.

[B818] Kawamura, H., and Hibino, M., "Gas insulated switchgear for transmission line," Takaoka Review, vol. 34, no. 3, pp. 335–338.

[B819] Kilar, L. A., and Cronin, J. C., "A general method for predicting the potential usage of specific transmission cables applied to SF6 cables," IEEE Power Engineering Society Underground Transmission and Distribution Conference, Publication 76 CH It 19-7-PWR, pp. 437–441, Sept. 1976.

[B820] Kind, D., "Gas insulated energy transmission systems: 23rd Bernard Price Memorial Lecture," Transactions of the South African Institute of Electrical Engineers, vol. 65, pt. 12, pp. 270–277, Dec. 1974.

[B821] Kobayashi, T., et a]., "Development of compact 500 kV 8000 A gas insulated transmission line," Sumitomo Electric Technical Review, no. 24, pp. 80–90, Jan. 1985.

 Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B822] Kreuger, F. H., and Van Deventer, G. C., "Spacer cable," CIGRE, Paper 21-04, 7 pages, Aug. 1974.

[B823] Kroon, P. J., et al., "Flexible gas-insulated metal-enclosed transmission system design," EPRI, Report EL-2563, Aug. 1982.

[B824] Lautenschlager, H. G., and Cooke, C. M., "Bundled conductors in gas insulated high voltage power transmission cables," IEEE Power Engineering Society Winter Meeting, Paper F80 165-1, 7 pages, Feb. 1980.

[B825] Miller, D. B., et al., "Flexible gas-insulated cable for 230 kV, 345 kV and 500 kV," IEEE Transactions on Power Apparatus and Systems, vol. PAS-103, no. 9, pp. 2480–2485, Sept. 1984.

[B826] Misaki, T.; Yamamato, H.; and Itaka, K.; "An analysis of three-dimensional asymmetric field distribution in SF6 gas insulated cables," IEEE Transactions on Power Apparatus and Systems, vol. 92, no. 6, pp. 2024–203 1, Nov./ Dec. 1973.

[B827] Mizukami, T.; Sato, H.; and Ando, N.; "Gas-insulated transmission cable with semi-prefabricated unit," IEEE, Transactions on Power Apparatus and Systems, vol. PAS-98, no. 5, pp. 1709–1716, Sept./Oct. 1979.

[B828] Morello, A., "Future outlook for underground cables transmitting large powers at extra high voltages," Electrotecnica (Italy), vol. 65, no. 5, pp. 405–413, May 1978.

[B829] Mori, S., "Gas-insulated cable response to short-circuit forces," IEEE Transactions on Power Apparatus and Systems, vol. T-PAS, pp. 2311–2319, May 198 1.

[B830] Mori, S., et al., "Characteristics of gas insulated transmission lines bonded at both ends in relation to short circuit forces," IEEE Transactions on Power Apparatus and Systems, vol. PAS- 100, no. 5, pp. 2311-2319, May 1981.

[B831] Nawrowski, R., "The influence of coupling between the electromagnetic field and the thermal field on the power losses and the temperature in power transmission lines with SF6 insulation," Modelling, Measurement and Control A, vol. 49, no.4, pp. 1 5–24, 1993.

[B832] Nicol, J., "Planning for more economical underground power transmission," IEEE Power Engineering Society Underground Transmission and Distribution Conference, Publication 72-CHO-608-0- PWR (suppl.), pp. 339–356, Jan. 1973.

[B833] Nishimoto, K., "Bulk electric power transmission in Japan," *World Energy Conference*, Paper 5, 1–9, 25 pages, Sept. 1974.

[B834] Pedersen, B. O.; Doepken, H. C., Jr.; and Bolin, P. C.; "Development of a compressed gas-insulated transmission line," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-90, no. 6, pp. 2631–2638, Nov./ Dec. 1971.

[B835] Perry, E. R., and Cronin, J. C., "Underwater high voltage power transmission using SF_6 insulated cable," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 6, p. 2265, Nov./Dec. 1972. Presented at *IEEE Power Engineering Society Underground Transmission and Distribution Conference*, Publication 72-CHO-608-O-PWR, pp. 71–75, May 1972.

[B836] Perry, M. P., and Carlson, G. J., "Compressed gas insulated transmission: Line trap development," General Electric Company, Schenectady, N.Y, Final Report, Oct. 1982.

[B837] Perry, M. P., and Major, L. B., "Misalignment of coaxial conductors," *IEEE Transactions on Instrumentation and Measurement*, vol. IM-26, no. 3, pp. 270–272, Sept. 1977.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B838] Perry, E. R., and Piscioneri, J. N., "First gas-insulated submarine cable developed at 345 kV," *Electric Light and Power*, pp. 40–41, Aug. 1972.

[B839] Popkov, V. I.; Lyapin, A. G.; and Shcherbina, O. V.; "Gas-insulated electric transmission lines," *Izv Akad Nauk* (USSR), pp. 98–106, Jan./Feb. 1973.

[B840] Pugh, P., "Gas-spacer cable of integrated design," *Electrical World*, vol. 188, no. 3, p. 47, Aug. 1, 1977.

[B841] Rizk, F. A. M., et al., "Design of compressed-SF_6-insulated systems for EHV transmission," *International Symposium on Gaseous Dielectrics*, Publication no. CONF-780301, pp. 406–409, Mar. 1978.

[B842] Samm, R. W., "Compressed gas-insulated transmission," *EPRI*, Technical Division Progress Report, Transmission and Distribution Division, pp. 5–7, Oct. 1974.

[B843] Sato, H., and Ando, N., "Gas-insulated transmission cable with semiprefabricated unit," *Hitachi Review* (Japan), vol. 28, no. 5, pp. 274–278.

[B844] Schmidt, R. L., et al., "Compressed gas insulated transmission line application economics," *Canadian Communications and Power Conference*, IEEE, Montreal, Quebec, Canada, pp. 157–160, Oct. 1978.

[B845] Schmidt, R. L., et al., "Economic study of the application of compressed gas insulated transmission lines," *Seventh IEEE Power Engineering Society Transmission and Distribution Conference and Exposition*, Atlanta, Ga., pp. 362–370, Apr. 1979.

[B846] Silver, D. A., "Development of 230-kV high-pressure, gas-filled, pipe-type cable system: Model Test program phase," *EPRI*, Report EL-6933, Sept. 1990.

[B847] Spencer, E. M., et al., "Research and development of a flexible 362 kV compressed gas insulated transmission cable," *Proceedings of the 28th Session, International Conference on Large High Voltage Electric Systems (CIGRE)*, Paris, France, vol. 1, pp. 21.02.1–21.02.9, Aug./Sept. 1980.

[B848] Takagi, T., et al., "Development of 500 kV gas spacer cable—Part I: Characteristics of current carrying capacity, and Part II: The voltage characteristics and the construction," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 5, pp. 1732–1748, Sept./Oct. 1978.

[B849] Takuma, T., et al., "Compartment gas-insulated transmission lines (C-GIL) at 500 kV class," *IEEE Transactions on Power Delivery*, vol. 4, no. 1, pp. 1–7, Jan. 1989.

[B850] Takuma, T.; Kita, K.; and Watanabe, T.; "Calculation of the electric field in three-phase gas insulated cables," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 6, p. 2261, Nov./Dec. 1972.

[B851] Tanizawa, K.; Minaguchi, D.; and Honaga, Y.; "Application of gas insulated transmission line in Japan," *International Conference on Large High Voltage Electric Systems, Proceedings of the 30th Session, CIGRE*, Paris, France, Aug./Sept. 1984.

[B852] "Technique allows study of cable use prospects," *Electrical World*, pp. 48–49, Nov. 1, 1976.

[B853] "Three-conductor compressed-gas cable field demonstration," *EPRI*, Report EL-6771, vol. 2, p. 2, Apr. 1990.

[B854] Trinh, N. G.; Vincent, C.; and De Tourrell, C. H.; "SF_6 insulated underground transmission," *IREQ*, Report no. 1986-C, 39 pages, May 1979.

[B855] Trump, J. G., "Gas-Insulated Transmission Line," U.S. Patent no. 3585270.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B856] Trump, J. G., and Cooke, C. M., "Gas dielectric cable insulation," *ERC Research*, Project PP-78–2, Final Report, 13 pages, Sept. 1972.

[B857] "Underground cable systems—Gas insulated systems," *Electrical World*, p. 51, Oct. 1, 1976.

6.2.4 Transmission line installation and operation

[B858] Abell, D. S., "Installation and testing experience with I-T-E SF_6 gas insulated 115 kV bus," *Doble Client Conference*, sec. 9, pp. 401–405, Apr. 1976.

[B859] Arrighi, R., "Operating characteristics of long links of ac high voltage insulated cables," *International Conference on Large High Voltage Electric Systems (CIGRE)*, Paris, France, pp. 21.13kl-21.13.10, Aug./Sept. 1986.

[B860] Baer, G. P.; Diessner, A.; and Luxa, G. F.; "420 kV SF_6 insulated tubular bus for the Wehr pumped-storage plant: Electric tests," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 2, pp. 469–477, Mar./Apr. 1976.

[B861] Baer, G. P., and Lehmann, W., "SF_6 insulated 420 kV tubular bus with transfer facility connected to an underground hydroelectric power station," *CIGRE*, Paper 23–02, 13 pages, Aug. 1974.

[B862] Bahder, G., et al., "Procedure to increase voltage rating of field installed 15 kV cable by replacement of nitrogen with sulfur hexafluoride," *IEEE Power Engineering Society Summer Meeting*, Paper F 76 357–4, July 1976.

[B863] Bolin, P. C., "Update on field experience with compressed gas-insulated transmission systems," *Proceedings of the American Power Conference*, Chicago, Ill., vol. 41, pp. 1126–1133, Apr. 1979.

[B864] "CEGB Research effort moves towards trouble shooting," *Electrical Review*, vol. 199, no. 13, pp. 20–21, Oct. 1, 1976.

[B865] Cookson, A. H., et al., "Development and test installation of three conductor and UHV compressed gas insulated transmission lines for heavy load transmission," *International Conference on Large High Voltage Electric Systems (CIGRE)*, Paris, France, Sept. 1982.

[B866] Cronin, J. C., et al., "Optimization of single conductor gas-insulated transmission systems," *IEEE 1978 Power Engineering Society Winter Meeting*, New York, N.Y., pp. 189-3/1–3/5, Jan./Feb. 1978.

[B867] DeMaris, S., "500-kV CGI system is installed in the Cascades," *Transmission and Distribution*, vol. 27, no. 4, pp. 50–54, Apr. 1975.

[B868] Fitzgerald, J. P., and Swoish, R. F., "SF_6-insulated 345 kV system reduces line-crossing hazard," *Electrical World*, Sept. 29, 1969.

[B869] Geary, E. F., "Single SF_6 line carries generator output," *Electrical World*, pp. 61–63, Oct. 15, 1975.

[B870] Graybill, H. W., "Gas-insulated bus solves 345 kV crossover problem," *Electric Light and Power*, Oct. 1970.

[B871] Green, D. R., "CEI installs first SF_6 345 kV bus," *Electrical World*, pp. 40–41, Dec. 1, 1971.

[B872] Handel, R. D., "Design of the MICA hydroelectric project—A major 500 kV SF_6 installation," *IEEE Transactions on Power Apparatus and Systems*, vol. 96, no. 5, pp. 1535–1545, Sept./Oct. 1977.

[B873] Johnson, B. L.; Doepken, H. C., Jr.; and Trump, J. G.; "Operating parameters of compressed-gas-insulated transmission lines," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-88, no. 4, pp. 369–375, Apr. 1969.

Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B874] Kilar, L. A., "Gas-insulated transmission perspective," *Proceedings of the 1975 IEEE Southeastern Region 3 Conference on Electricity and Expanding Technology*, Charlotte, N.C., pt. 1, pp. 2A-3/1-3/5, Apr. 1975.

[B875] Klumb, F. R., "SF_6 system moves power up the tower," *Electric Light and Power*, pp. 46–48, July 1972.

[B876] Kuroyanagi, Y., et al., "Construction of 8000 A class 275 kV gas insulated transmission line," *IEEE Transactions on Power Delivery*, vol. 5, no. 1, pp. 14–20, Jan. 1990.

[B877] Matulic, R., "Cost precludes 765 kV UG circuit," *Electrical World*, vol. 193, no. 6, pp. 108–109, Mar. 15, 1980.

[B878] McCluhan, F. J., et al., "345 kV SF_6 system eases switchyard crossing," *Electric Light and Power*, p. 47, Oct. 1976.

[B879] Memita, N., et al., "Development and installation of 275 kV SF_6 gas-insulated transmission line," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 4, pp. 691–698, Apr. 1984.

[B880] "Mica project to generate 2,610 MW," *Electrical World*, pp. 34–36, June 1, 1973.

[B881] Morcos, M. M.; Anis, H. I.; and Srivastava, K. D.; "Metallic particle movement, corona, and breakdown in compressed gas insulated transmission line systems," *IEEE Transactions on Industry Applications*, vol. 27, no. 5, pp. 816–823, 1991.

[B882] Mori, S., et al., "Effect of SF_6 gas-insulated transmission lines of internal conductor to enclosure arcs," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 860–869, Apr. 1983.

[B883] Perry, E. R., and Cronin, J. C., "CGT system softens impact on transmission," *Electrical World*, pp. 48–49, Aug. 15, 1972.

[B884] Reimers, T. D., and Heberlein, G. E., "SF_6 insulated system avoids overhead 345 kV crossing," *Electrical World*, July 15, 1968.

[B885] Schmidt, R. L., et al., "Economic study of the application of compressed gas insulated transmission lines," *IEEE Transmission and Distribution Conference*, Publication CH 1139-5, pp. 362–370, Apr. 1979.

[B886] "SF_6 solves transmission amenity problems," *Electrical Review*, pp. 667–668, Nov. 5, 1971.

[B887] Stolpe, J., and Mann, R. F., "A unique 220 kV SF_6 insulated underground getaway installation," *IEEE Underground Transmission and Distribution Conference*, pp. 337–342, Apr. 1974.

[B888] Stolpe, J., and Mateuchev, A., "SF_6 system links sub to overhead transmission," *Transmission and Distribution*, pp. 99–102, 162, Apr. 1974.

[B889] Supplee, G. W., et al., "Installation of a 230 kV compressed gas insulated bus," *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 1, pp. 349–353, Jan./Feb. 1974.

[B890] Szente-Varga, H. P.; Floessel, K.; and Schmidt, W.; "420 kV SF_6 gas-insulated cable for Mapragg power station," *Brown Boveri Review*, vol. 64, no. 5, pp. 285–289, May 1977.

[B891] "Tie gives Con Edison 400 MW more," *Electrical World*, pp. 58–59, Feb. 15, 1973.

[B892] Tikhodeev, N. N., and Gordin, B. I., "Problems of gas insulation in power engineering," *Power Engineering* (New York) (English Translation of *Izvestiya Akademii, Nauk, SSSR, Energetika I. Transport*), vol. 14, no. 4, pp. 156–157, 1976.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B893] Uchida, K., et al., "Construction of compact 500 kV gas insulated transmission line," *Sumitomo Electric Technical Review* (Japan), no. 26, pp. 242–251, Jan. 1987.

[B894] Watanabe, Y., "Gas-insulated 154 kV and 275 kV cables in Japan: Design, installation, and testing," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 4319–4328, Oct. 1981.

[B895] Watanabe, Y., et al., "Construction of first gas insulated transmission line in Japan," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-100, no. 10, pp. 4319–4329, Oct. 1981.

[B896] West, J. R., "In support of CGI cable," *Power Engineering*, pp. 42–43, Mar. 1970.

[B897] Williams, J. A.; Fischer, F. E.; and Koehler, H. C.; "Installation of 345 kV SF_6 insulated phase isolated underground bus," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 4, p. 1726, July/Aug. 1972. Published under the title, "First underground 345 kV gas insulated transmission system energized," Transmission and Distribution, pp. 37–39, May 1972.

[B898] Zelingher, S., and Matulic, R., "EHV gas insulated transmission lines: Parameters determination based on system performance criteria," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-100, no. 11, pp. 4515–4523, Nov. 1981.

6.2.5 Bus/conductor and enclosure

[B899] Emanuel, A. E.; Doepken, H. C., Jr.; and Solin, P. C.; "Design and test of a sliding plug-in conductor connector for compressed gas-insulated cables," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 2, pp. 570–579, Mar./Apr. 1976.

[B900] Gacek, Z., and Paszek, G., "Preliminary dimensioning of high voltage SF_6-insulated buses," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, vol. 1, 1991, pp. 521–524.

[B901] Grzan, J., and Goyette, R., "Sound cable crossing brings inexpensive electric power to Long Island," *Proceedings of the American Power Conference*, vol. 2, pp. 1112–1116, 1992.

[B902] Hand, C. L., and Tieszen, K., "Gas-insulated conductor used in unique 1000-ft vertical granite shaft," *Transmission and Distribution*, vol. 43, no. 3, pp. 38–43, 1991.

[B903] Hedman, L., "Cable connections for gas insulated switchgear 12–245 kV," *Cablewire*, pp. III-7 through III-10, 1991.

[B904] Ishikawa, M., "Switching-surge induced surges in sheath of SF_6-insulated switchgear-cable connection system," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 528–538, Feb. 1981.

[B905] Krenicky, A.; Schmitz, U.; and Sonderegger, G.; "Arcing faults in SF_6 insulated metalclad H.V. switchgear," *Brown Boveri Review,* vol. 61, no. 4, pp. 143–151, Apr. 1974.

[B906] Lautenschlager, H. G., "Bundle conductors in gas-insulated HV transmission cables: Several small subconductors used in place of single large center conductor," *IEEE Transactions on Power Apparatus and Systems,* vol. T-PAS, pp. 394–399, Jan. 1981.

[B907] Lieske, M., and Olsen, W, "SF_6-insulated bus trunking for extending conventional high-voltage switchgear," *Siemens Review,* vol. 39, pp. 467–469, Nov. 1972.

[B908] Mori, S., et al., "Effects of internal conductor to enclosure arcs on SF_6 gas insulated transmission lines," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS- 102, no. 4, pp. 860–869, Apr. 1983.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B909] Nakanishi, K., et al., "Experimental study of the breakdown characteristics of a gas-insulated bus," *IEEE Transactions on Electrical Insulation,* vol. El- 16, no. w, pp. 111–117, Apr. 1981.

[B910] Nakata, R., and Tuoho, E. J., "Practical bus gas design based on particle motion studies," *IEEE Power Engineering Society Winter Meeting,* Paper A 77 198–5, Jan. 1977.

[B911] Pettinga, J. A. J., "Full scale high current model tests on busbar constructions for GIS," *Proceedings of CIGRE Symposium on High Current in Power System,* pp. 506–585, 1985.

[B912] Safigianni, A., and Tsanakas, D., "Short-circuit electromagnetic forces in three phase gas insulated systems with steel enclosure," *Archiv fur Elektrotechnik,* vol. 75, no. 1, pp. 37–43, 1991.

[B913] Strasser, H.; Schmidt, K. D.; and Hogg, P.; "Effects of arcs in enclosures filled with SF_6 and steps taken to restrict them in SF_6 switchgear," *IEEE Transactions on Power Apparatus and Systems,* vol. 94, no. 3, pp. 1051–1060, May/June 1975.

[B914] Supplee, G. W., et al., "Installation of a 230 kV compressed gas insulated bus," *IEEE Transactions on Power Apparatus and Systems,* vol. PAS-93, no. 1, pp. 349–353, Jan./Feb. 1974.

6.2.6 Circuit breaker

[B915] "34.5–69 kV Puffer breakers introduced," *Electric Light and Power,* p. 68, Jan. 1980.

[B916] *1991 International Conference on Advances in Power System Control, Operation and Management, IEE,* vol. 1, pp. 195–200, 1991.

[B917] Abell, D. S., "Installation and testing experience with I-T-E SF_6 dead tank circuit breakers," Doble *Client Conference,* sec. 5, pp. 101–106, Apr. 1975.

[B918] Airey, D. R., et al., "Electrode vapour effects in high current gas blast switchgear arcs," *IEEE Transactions on Power Apparatus and Systems,* vol. 95, no. 1, pp. 1–13, Jan./Feb. 1976.

[B919] Allaart, A. J., "Experiments on circuit breaking, IV," *Elektrotechnik,* vol. 62, no. II, pp. 959–967, Nov. 1984.

[B920] Bachmaier, A., and Bogner, A., "Medium voltage load circuit breakers, SF_6 insulated proven in operation," *Electrizitaetswirtschaft,* vol. 83, no. 17–18, pp. 773–776, Aug. 1984.

[B921] Barber, J. C., "Repair and test of 500 kV compressed gas-insulated transmission system (CGITS)-SF_6," *Doble Client Conference,* sec. 9, pp. 301–309, Apr. 1978.

[B922] Bargigia, A., et al., "Preliminary tests for the observation of electric arcs in HV circuit-breakers adopting a spectroscopic system based on bidimensional CCD detectors," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications,* vol. 2, pp. 946–949, 1992.

[B923] Berger, G., et al., "Effect of water vapour on the discharge regimes and the deviations from similarity law in compressed SF_6 for positive polarity," *Journal of Physics D: Applied Physics,* vol. 24, no. 9, pp. 1551–1556, Sept. 14, 1991.

[B924] Berkebile, L. E., "Interrupter optimization provides improved EHV-SF_6 circuit breakers." Abstract (C75-039-3) in *IEEE Transactions on Power Apparatus and Systems,* vol. 94, no. 4, p. 1093, July/Aug. 1975.

[B925] Berkebile, L. E., and Pfleiderer, R., "Synthetic capacitor switching tests on a SF_6 circuit breaker," *IEEE Power Engineering Society Summer Meeting,* Paper A79 541–4, 5 pages, July 1979.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B926] Beroual, A., and Buret, F., "Dielectric behaviour of SF_6 in a high voltage circuit breaker at low temperature," *Seventh International Symposium on High Voltage Engineering,* vol. 3, pp. 113–116, 1991.

[B927] Beroual, A., and Buret, F, "SF_6 dielectric strength at low temperatures under dc voltages," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications,* vol. 1, pp. 406–409,1992.

[B928] Braun, D., "Problems with switching overvoltages solved by SF_6 self-extinguishing circuit breaker," *BBC Review*, vol. 72, no. 5, pp. 216–223, May 1985.

[B929] Broschk, H. O., "Third generation high voltage SF_6 circuit breakers for the present voltage range from 66–170 kV," *Elektron* (Johannesburg) vol. 8, no. 6, pp. 9–11, June 1991.

[B930] Calvino, B. J. ; Mazza, G. P.; and Rovelli, S.; "Study of current zero phenomena under various stress conditions of a single pressure SF_6-circuit breaker," *CIGRE,* Paper 13–07, 12 pages, Aug. 1976.

[B931] Calvino, B. J., and Pezzi, P, "Interruption characteristics of an SF_6 self-extinguishing circuit breaker: Influence of the initial rate of rise of the transient recovery voltage and of current-zero phenomena," *CIGRE,* Paper 13–04, 14 pages, June 1968.

[B932] Campbell, L. C.; Perkins, J. F.; and Dallachy, J. L.; "Effect of nozzle pressure ratio on SF_6 arc interruption," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 44–47, Sept. 1976.

[B933] Carter, S. L., "Duke Power's experience with Allis-Chalmers new 242 kV type GHO power circuit breakers," *Doble Client Conference*, sec. 5, pp. 501–519, Apr. 1978.

[B934] Chapman, A.; Jones, G. R.; and Strachan, D. C.; "Current zero electric field measurements in gas blast circuit breaker arcs," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 52–55, Sept. 1976.

[B935] Dauby, B., et al., "Numerical tools for auto-expansion in SF_6 circuit-breakers," *CIRED*, vol. 1, pp. 1.1/1–4, 1993.

[B936] "Development trends in high fault-level circuit breakers point to SF_6 liquid," *Electrical Review*, vol. 193, no. 19, pp. 634–635, Nov. 9, 1973.

[B937] Dirks, R., "SF_6 switchgear for inaccessible locations," *ETZ*, vol. 112, no. 4, pp. 182, 184–185, 1991.

[B938] Dodds, J. J., and Traylor, L. E., "550 kV Type ELK breaker failure," Paper presented at the *1986 Doble Client Conference*, Boston, Mass., 1986.

[B939] Dolezal, M., and Posmure, F., "Composition, toxicity, and filtration of the products of SF_6-generated in the arc quenching devices of power circuit breakers," *Electrotechnichy Obzor*, vol. 68, no. 4, pp. 216–220, 1979.

[B940] Dufournet, D., "Evolution of the SF_6 thermal blast interruption in high voltage up to 245 kV," *GEC ALSTHOM Technical Review*, no. 6, pp. 47–58, 1991.

[B941] Dufournet, D., "Thermal-blast circuit breaking up to 245 kV," *Modern Power Systems*, vol. 11, no. 3, pp.47, 49, 51, 1991.

[B942] Everson, D., "SF_6 or vacuum switching? The debate continues," *Int. Power Generation*, vol. 7, no. 9, 21–23, pp. 17–18, Nov. 1984.

[B943] Fang, M. T. C., and Banks, A. D. J., "The effects of the Lorentz Force on the flow in gas-blast circuit breakers," *Journal of Physics D.*, vol. 18, no. 2, pp. 229–238, Feb. 1985.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B944] Ferschl, L., et al., "Theoretical and experimental investigations of compressed gas circuit breakers under short-line fault conditions," *CIGRE*, Paper 13–07, 15 pages, Aug. 1974.

[B945] Friedrich, R. E., "Sulfur hexafluoride-filled, high voltage, high capacity circuit breakers," *American Power Conference*, vol. 21, pp. 580–588, 1959.

[B946] Friedrich, R. E., and Bates, G., "The use of SF_6 in high voltage interruption," *AIEE Summer General Meeting*, Paper C58-960, 17 pages, June 1958.

[B947] Frind, G.; Prescott, L. E.; and Van Noy, J. H.; "Current zero phenomena in an orifice type gas blast interrupter," *IEEE Power Engineering Society Winter Meeting*, Paper F79 288–2, 9 pages, Feb. 1979.

[B948] Frind, G., and Rich, J. A., "Recovery speed of axial flow gas blasted interrupter: Dependence on pressure and dl/dt for air and SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 5, pp. 1675–1684, Sept./Oct. 1974.

[B949] Frohlich, K., and Eriksson, A., "Special phenomena in high-voltage GIS", *International Power Generation*, vol. 15, no. 2, pp. 50, 52–54, 1992.

[B950] Garzon, R. D., "Rate of change of voltage and current as functions of pressure and nozzle area in breakers using SF_6 in the gas and liquid phases," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 5, pp. 1681–1688, Sept./Oct. 1976.

[B951] Garzon, R. D.; Wu, J. L.; and Amato, J. V.; "Synchronous transmission circuit breaker development," *ERDA*, E(49–18)-2155, 176 pages, Aug. 1976.

[B952] Girard, A.; Bernard, G.; and Malkin, P.; "Post arc currents in medium voltage interrupting devices," *IEEE Transactions on Power Delivery*, vol. 6, no. 2, pp. 849–857, 1991.

[B953] Gleizes, A.; Mitiche, A. M.; and Van Doan, P.; "Study of a circuit-breaker arc with self-generated flow—III: The post-arc phase," *IEEE Transactions on Plasma Science*, vol. 19, no. 1, pp. 12–19, Feb. 1991.

[B954] Gleizes, A.; Robert, T.; and Pons, A.; "Modelling of SF_6 circuit-breaker arc at current zero and its interaction with the circuit," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 2–5, 1992.

[B955] Graber, W., and Gysel, T., "The interruption of fault currents with delayed current zeros by HV circuit breakers," *Brown Boveri Review*, vol. 67, pp. 237–243, Apr. 1980.

[B956] Graf, R., "ITRV modification by interaction between SF_6 breaker and the test circuit," *CIGRE*, Paper 13–01, 7 pages, Aug. 1976.

[B957] Grant, D. M., et al., "Comparative interruption studies of gas-blast arcs in SF_6-N_2 and SF_6-He mixtures," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 48–51, Sept. 1976.

[B958] Guilloux, C., "Post-arc current measurement for EHV circuit-breaker tests," *Power Technology International*, pp. 91–92, 94–95, 1992.

[B959] Gurtzel, P., and Piechocki, A., "Saturated compositions W-Cu in application to singing, contacts for modern mt circuit-breakers" (In Polish), *Elektronika*, vol. 24, no. 10, pp. 5–8, 1983.

[B960] Habedank, U., and Knobloch, H., "Procedure for the optimization of SF_6 circuit-breakers," *U. European Transactions on Electrical Power Engineering*, vol. 2, no. 5, pp. 315–320, 1992.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B961] Haginomori, E., et al., "Recent progress in SF_6 gas circuit breaker technique," *Toshiba Review*, no. 117, pp. 13–20, Sept./Oct. 1978.

[B962] Hallested, R., et al., "Evaluation of the effect of mechanical operations on seismic qualification test of SF_6 circuit breakers," Proceedings of the 1991 *IEEE Power Engineering Society Transmission and Distribution Conference*, pp. 473–477, 1991.

[B963] Hamano, S., et al., "Investigation of a new extinguishing principle for a gas circuit breaker," *Electrical Engineering in Japan*, vol. 112, no. 4, pp. 10–26, 1992.

[B964] Harper, W. E., and Meinders, G. J., "Gas insulated breaker design simplify installation and maintenance," *Allis Chalmers Engineering Review*, vol. 38, no. 3, pp. 4–8, 1973.

[B965] Henry, J. C.; Perrissin, G.; and Rollier, C.; "The behavior of SF_6 puffer circuit breakers under exceptionally severe conditions," *CIGRE*, Paper 13–08, 13 pages, Aug. 1978.

[B966] Hermann, W., et al., "Investigation on the physical phenomena around current zero in HV gas blast breakers," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 4, pp. 1165–1176, July/Aug. 1976.

[B967] Hermann, W., and Ragaller, K., "Theoretical description of the current interruption in HV gas blast breakers," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 5, pp. 1546–1555, Sept./Oct. 1977.

[B968] Hertz, W., "Velocity measurement in SF_6 circuit-breaker arc channels," *16th International Conference on Phenomena in Ionized Gases*, Dusseldorf, Germany, pp. 506–507, Aug./Sept. 1983.

[B969] Hess, D. P., et al., "Noninvasive condition assessment and event timing for power circuit breakers," *IEEE Transactions on Power Delivery*, vol. 7, no. 1, pp. 353–360, Jan. 1992.

[B970] Hirasawa, K., et al., "Development of high power 2 cycle puffer type gas circuit breaker." Abstract (C74 089-9) in *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 4, p. 1020, July/Aug. 1974.

[B971] Hoerauf, R. G., and Shipp, D. D., "Characteristics and applications of various arc interrupting methods," *Record of the 1991 Annual Pulp and Paper Industry Technical Conference*, IEEE, pp. 151–163, 1991.

[B972] Hux, G., "HGF 2009/2011: New outdoor circuit breaker types for low-rating range," *Sprecher Energie Review*, no. 1, pp. 17–18, 1991.

[B973] Ikeda, Shimichi, "Mechanical failure diagnosis," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 4869–4875, Dec. 1981.

[B974] Iwata, K., et al., "SF_6 gas circuit breakers with hydraulic operating mechanism," *Fuji Elect. Review*, vol. 30, no. 2, pp. 61–66, 1984.

[B975] Jakob, T.; Schade, E.; and Schaumann, R.; "Self extinction, an economic new principle for SF_6 circuit breakers," *Brown Boveri Review*, vol. 64, pp. 671–674, Nov. 1977.

[B976] Jones, G., "The impact of SF_6 upon power switchgear technology—2: Switch systems implications," *Power Engineering Journal*, vol. 5, no. 2, pp. 95–100, 1991.

[B977] Kane, R. E., et al., "How power circuit breakers employ SF_6 gas for all functions," *Westinghouse Engineer*, pp. 130–136, Sept. 1970.

[B978] Knobloch, H., and Steppat, A., "Development of SF_6 circuit-breakers," *Seventh International Symposium on Engineering*, vol. 7, pp. 205–208, 1991.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B979] Kobayashi, A., et al., "Measurement of voltage distribution phenomena in SF_6 single pressure circuit breaker," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 4, pp. 1304–1312, July/Aug. 1978.

[B980] Kopainsky, J. "Influence of the arc on breakdown phenomena in circuit breakers." In *Current Interruption in High Voltage Networks*. Plenum Press, 1978, p. 329.

[B981] Korner, G., and Rees, V., "420 kV SF_6 circuit breakers for breaking currents up to 80kA," *BBC Nachr*., vol. 66, no. 11–12, pp. 405–412,1984.

[B982] Leeds, W. M., et al., "Application of switching surge arc and gas flow studies to the design of SF_6 Circuit Breakers," *CIGRE*, Paper no. 13–11, Aug./Sept. 1970.

[B983] Leeds, W. M., and Friedrich, A. E., "Recent developments in the use of SF_6 for power circuit breakers," *American Power Conference*, vol. 24, pp. 833–840, 1962.

[B984] Lowke, J. J. "Radiative Energy Transfer in Circuit Breaker Arcs." In *Current Interruption in High Voltage Networks*, edited by K. Ragaller. Plenum Press, 1978.

[B985] Martin, D., "Keeping an eye on circuit-breakers," *Electrical Review*, vol. 224, no. 3, pp. 14–15, 1991.

[B986] Matsumura, S., "550 kV Gas-insulated substations: Surge propagation performance," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3057–3054, June 1981.

[B987] Mauthe, G., et al., "Type ELK circuit-breakers for metal-enclosed SF_6 insulated switchgear installations," *Brown Boveri Review*, vol. 61, no. 4, pp. 152–166, Apr. 1974.

[B988] Mauthe, G.; Ottischnig, R.; and Schmidt, K. D.; "Metalclad SF_6 circuit breaker type ECK," *Brown Boveri Review*, vol. 57, no. 12, pp. 562–571, Dec. 1970.

[B989] Mazzoleni, B., "Dielectric stress during breaking operations of an SF_6 puffer single phase enclosure circuit breaker," *A.I.M. International Meeting*, 4 pages, Nov. 1979.

[B990] McCabe, A. K., et al., "Design and testing of a three-break 800 kV SF_6 circuit breaker with ZnO varistors for shunt reactor switching," Proceedings of the 1991 *IEEE Power Engineering Society Transmission and Distribution Conference*, pp. 499–507, 1991.

[B991] Miyamoto, T., and Kamatani, A., "Behavior of SF_6 gas blast-type circuit breakers around current zero (A study of the time constant of dynamic arcs)," *Electrical Engineering in Japan*, vol. 85, no. 4, p. 21, Apr. 1965.

[B992] Morii, K., et al., "SF_6 gas circuit breaker, new solution for generator main circuit switching," *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 3, pp. 759–769, May/June 1979.

[B993] Nagamatsu, H. T.; Sheer, R. E., Jr.; and Bigelow, E. C.; "Flow properties of air and SF_6 in supersonic circuit breaker nozzles." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 4, p. 1022, July/Aug. 1974.

[B994] Nakanishi, K., *Switching Phenomena in High-Voltage Circuit Breakers*. New York: Marcel Dekker, 1991.

[B995] Natsui, K., et al., "Experimental approach to one cycle puffer type SF_6 gas circuit breaker," *IEEE Transactions on Power Apparatus and Systems*, vol. 99, no. 3, pp. 833–840, May/June 1980.

[B996] "New trends in high-voltage engineering, SF_6 for arc interruption," *Siemens Review*, vol. 39, no. 12, pp. 540–547, Dec. 1972.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B997] Nishikawa, H., et al., "Arc extinction performance of SF_6 gas blast interrupters," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 6, pp. 1834–1844, Nov./Dec. 1976.

[B998] Noeske, H. O., "Investigation of dynamic nozzle parameters for various nozzle geometries and test conditions of an experimental half-size SF_6 puffer breaker," *IEEE Transactions on Power Apparatus and Systems*, vol. 96, no. 3, pp. 896–906, May/June 1977.

[B999] Okabe, S.; Kan, M.; and Kouno, T.; "Analysis of surges measured at 550 kV substations," *IEEE Transactions on Power Delivery*, vol. 6, no. 4, pp. 1462–1468, 1991.

[B1000] Okuno, M., "Dynamic characteristics and stress of various kinds of spring on the operation of a high-speed mechanism," *Transactions of the Japan Society of Mechanical Engineers*, pt. C, vol. 59, no. 558, pp. 221–226, 1993.

[B1001] Park, K. Y., and Fang, M. T. C., "Mathematical modelling of SF_6 puffer breakers," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 2, pp. 940–943, 1992.

[B1002] Perkins, J. E, "Scaling criteria for interruption in gas-blast circuit breakers," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 1, pp. 232–241, Jan./Feb. 1978.

[B1003] Perkins, J. F., and Frost, L. S., "Effects of nozzle parameters on SF_6 arc interruption," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 4, pp. 961–970, July/Aug. 1973.

[B1004] Perkins, J. F., and Frost, L. S., "Time variation of nozzle clogging in SF_6 blasted arcs near current-zero," *IEE Third International Conference on Gas Discharges*, Publication no. 118, pp. 498–501, Sept. 1974.

[B1005] Plechaty, L., and Vostracky, Z., "Type range or 123 to 420 kV outdoor circuit breaker with SF_6 arc extinguishing and insulating medium," *Czech. Heavy Ind.* (Czechoslovakia), no. 6, pp. 26–30, 1985.

[B1006] "Quenching with gas (SF_6 switchgear)," *International Power Generation*, vol. 14, no. 2, pp. 56–57, 59, 1991.

[B1007] Rappange, A., "SF_6 high-voltage circuit breaker for installation outdoors," *Brown Boveri Review*, vol. 63, no. 4, pp. 212–218, Apr. 1976.

[B1008] Roguski, A. T., "Laboratory test circuits for predicting overvoltages when interrupting small inductive currents with an SF_6 circuit breaker," *IEEE Power Engineering Society Summer Meeting*, Paper F79 760–0, 6 pages, July 1979.

[B1009] Scarpa, P., et al., "SF_6 auto-expansion circuit breaker design: Numerical and experimental investigations of arc-gas interactions," *IEEE Transactions on Power Delivery*, vol. 7, no. 1, pp. 339–345, 1992.

[B1010] Schaumann, R.; Jakob, T.; and Schade, E.; "SF_6 medium voltage circuit breaker, type H," *Brown Boveri Review*, vol. 67, pp. 251–256, Apr. 1980.

[B1011] Schwalb, E., et al., "Investigation of unit testing and full pole testing of a single pressure type double nozzle SF_6 circuit breaker under short line fault conditions," *CIGRE*, Paper 13–03, 12 pages, Aug. 1978.

[B1012] Shah, J. K., "SF_6 gas-SF_6 gas circuit breaker-gas-insulated substation (GIS)," *Electr. India*, vol. 24, no. 13, pp. 9–10, July 1984.

[B1013] Shay, G. A., "Maintenance experiences with ITE type 230 GA, 242 kV, SF_6 dead tank circuit breaker," *Doble Client Conference*, sec. 5, pp. 301–306, Apr. 1979.

[B1014] Smit, J., "The success of SF_6 (high voltage circuit breaker)," *PT/Elektrotech*, Elektron, vol. 39, no. 12, pp. 57–59, Dec. 1984.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1015] Spindle, H. E., "Circuit breaker development for 1200 kV GIS," *IEEE Transmission and Distribution Conference*, Publication CH 1139–5, pp. 227–236, Apr. 1979.

[B1016] St-Jean, G., "Modeling electrical arcs for power circuit-breakers," *IEEE Power Engineering Review*, vol. 11, no. 11, pp. 6–7, 1991.

[B1017] Stegmuller, I. K., "Switching of high-voltage motors (circuit breaker switching characteristics)," *Elektrotechnik*, vol. 66, no. 22, pp. 16–18, 21–23, Nov. 1984.

[B1018] Stelzer, R.; Rappange, A.; and Gaupp, O.; "Outdoor high-voltage SF_6 circuit breakers type ELF for medium breaking capacity," *Brown Boveri Review*, vol. 64, no. 5, pp. 268–276, May 1977.

[B1019] Stokes, A. D., et al., "SF_6 puffer circuit breaker: Schlieren visualization of hot circulation following fault interruption," *Energ. Electr.*, vol. 61, no. 6, pp. 275–280, June 1984.

[B1020] Sturzenegger, C.; Reinhardt, R.; and Schoetzau, H. J.; "Influence of a shock wave on the electric field strength distribution in a gas blast interrupter," *IEEE Power Engineering Society Winter Meeting*, Paper F80 278–2, 6 pages, Feb. 1980.

[B1021] Swanson, B. W, and Roidt, R. M., "Thermal analysis of an SF_6 circuit breaker arc," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 2, pp. 381–389, Mar./Apr. 1972.

[B1022] Szente-Varga, H. P., and Hogg, P., "HV SF_6 circuit breaker in gas with short circuit currents up to 100 kA," *A.I.M. International Meeting*, 110 pages, Nov. 1979.

[B1023] Takahashi, I., et al., "Research on a new type magnetic puffer gas circuit breaker," *IEEE Transactions on Power Apparatus and Systems*, vol. 1, pp, 421–428, Jan./Feb. 1974.

[B1024] Tamura, M., and Roe, D. M., "Design, installation and maintenance aspects of HVB buffer-type SF_6 gas circuit breakers," *Doble Client Conference*, sec. 5, pp. 101–121, Apr. 1978.

[B1025] Taylor, S., et al., "Current zero flow conditions in a circuit breaker-nozzle," *IEE Proceedings, Part A: Science, Measurement and Technology*, vol. 138, no. 5, pp. 259–264, Sept. 199 1.

[B1026] Tominaga, S., et al., "Estimation and performance investigation on SLF interrupting ability of puffer-type gas circuit breaker," *IEEE Power Engineering Society Winter Meeting*, Paper F 78 149–7, Jan. 1978.

[B1027] Tominaga, S., et al., "Extremely short line fault tests of a puffer-type gas circuit breaker by direct and synthetic methods," *IEEE Power Engineering Society Summer Meeting*, Paper 80 SM 702–1, July 1980.

[B1028] Tominaga, S., et al., "Investigation on gas flow of a puffer type gas circuit breaker based on observation of arc and pressure measurements," *EEE Power Engineering Society Winter Meeting*, Paper F80 280–8, 9 pages, Feb. 1980.

[B1029] Trepanier, J. Y., et al., "Analysis of the dielectric strength of an SF_6 circuit breaker," *IEEE Transactions on Power Delivery*, vol. 6, no. 2, pp. 809–815, 1991.

[B1030] Trepanier, J. Y., et al., "Computation of the gas flow and electrical fields in SF_6 circuit-breakers," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 2, pp. 936–939,1992.

[B1031] Trepanier, J. Y.; Reggio, M.; and Camarero, R.; "LTE computation of axisymmetric arc-flow interaction in circuit-breakers," *IEEE Transactions on Plasma Science*, vol. 19, no. 4, pp 580–589, Aug. 1991.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1032] Tsuchiya, Y., et al., "The 1000-operation field experience since 1965 of Japan's first SF_6 gas circuit breakers," *Mitsubishi Denki Giho* (Japan), vol. 55, no. 7, pp. 54–58, 1981.

[B1033] Tuma, D. T., "A comparison of the behavior of SF_6 and N_2 blast arcs around current zero," *IEEE Power Engineering Society Winter Meeting*, Paper F 80 279–0, 8 pages, Feb. 1980.

[B1034] Ueda, Yoshiro, "Without puffer action: Arc quenching based on self-flow generation," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3888–3898, Aug. 1981.

[B1035] Ushio, T., "Without puffer action: Interruption of breaker terminal fault and short line fault," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3801–3810, Aug. 1981.

[B1036] Ushio, T.; Shimura, I.; and Tominaga, S.; "Practical problems on SF_6 gas circuit breakers," *IEEE Transactions on Power Apparatus and Systems*, vol. 90, no. 5, pp. 2166–2174, Sept./Oct. 1971. Presented at *EEE Power Engineering Society Winter Power Meeting*, New York, Paper 71-TP-64-PWR, Jan. 1970.

[B1037] van der Sluis, L., and Rutgers, W. R., "Comparison of test circuits for high voltage circuit breakers by numerical calculations with arc models," *IEEE Transactions on Power Delivery*, vol. 7, no. 4, pp. 2037–2045, 1992.

[B1038] van der Sluis, L.; Rutgers, W. R.; and Koreman, C. G. A.; "A physical arc model for the simulation of current zero behavior of high-voltage circuit breakers," *Proceedings of the 1991 IEEE Power Engineering Society Transmission and Distribution Conference*, pp. 485–491, 1991.

[B1039] Vostracky, Z., and Plechaty, L., "Type SKODA very high voltage circuit breaker with SF_6 gas," *SKODA Rev*. (Czechoslovakia), no. 1, pp. 32–38, 1985.

[B1040] Wagner, C. L.; Garrity, T. F.; and Spindle, H. E.; "Development of a 1200 kV circuit breaker parameters," *CIGRE*, Paper 13–07, 17 pages, Aug. 1980.

[B1041] Wang, E.; Tong, L.; and Zhao, M.; "The computer simulation of the electrostatic-field distribution in the area of output line of the tank of SF_6 circuit breaker," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 2, pp. 924–927, 1992.

[B1042] Yeckley, R. N.; Wagner, C. L.; and Anderl, H. W.; "242 kV Puffer-type circuit breakers," *Doble Client Conference*, sec. 5, pp. 201–212, Apr. 1978.

[B1043] Yoshioka, Y., and Nakagawa, Y., "Investigation of the interrupting performance of a puffer type gas circuit breaker," *IEEE Power Engineering Society Winter Meeting*, Paper F80 280–6, 7 pages, Feb. 1980. Published in *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 1, p. 11, Jan./Feb. 1979.

[B1044] Yoshioka, Y.; Tsukushi, M.; and Natsui, K.; "A method and applications of a theoretical calculation for on-load pressure rises in puffer type gas circuit breakers," *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 3, pp. 731–737, May/June 1979. Presented at *IEEE Power Engineering Society Summer Meeting*, Paper F 78 682–7, July 1978.

6.2.7 Instrument transformers

[B1045] Brah, D. B., et al., "A coupling capacitor voltage transformer of metering accuracy for SF_6 insulated compact substations," *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 5, pp. 1345–1352, Sept./Oct. 1974.

[B1046] Camilli, G., "An experimental gas-insulated 138 kV current transformer," *AIEE Transactions*, vol. 74, pt. 3, pp. 100–104, Apr. 1955.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1047] Carlson, G. L., and Fisher, F. A., "Voltage and current sensors for a 1200 kV gas insulated bus," *IEEE Transmission and Distribution Conference*, Publication CH 1139–5, pp. 200–207, Apr. 1979.

[B1048] Innerling, J. J., "A safety concept against destructive consequences of high voltage instrument transformer failures," *Proceedings of the 1991 IEEE Power Engineering Society Transmission and Distribution Conference*, pp. 606–612, 1991.

[B1049] Kano, K., et al., "Line trapped charge discharging characteristic of gas insulated magnetic voltage transformer," *IEEE Transactions on Power Delivery*, vol. 7, no. 1, pp. 370–375, 1992.

[B1050] Kobayashi, S., et al., "Development and field test evaluation of optical current and voltage transformers for gas insulated switchgear," *Proceedings of the 1991 IEEE Power Engineering Society Transmission and Distribution Conference*, pp. 329–335, 1991.

[B1051] Krauss, H., and Moeller, J., "Metal-clad magnetic potential transformer with SF_6 impregnated plastic film layer insulation," *Canadian Communication and Power Conference*, 2 pages, Nov. 1974.

[B1052] Waddington, F. B., and Heighes, J., "SF_6 insulation for current transformers," AEI Engineering, vol. 7, no. 4, pp. 196–199, 1967.

[B1053] Yamauchi, A., et al., "Investigation of performance characteristics of EHV gas insulated potential transformer," *IEEE Power Engineering Society Winter Meeting*, Paper A80 050–5, 7 pages, Feb. 1980.

6.2.8 Insulators and barriers

[B1054] Akimov, V. V.; Varivodov, V. N.; and Volpov, E. K.; "An approach to the spacer design of HVDC SF_6 gas insulated equipment," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, vol. 1, pp. 525–528, 1991.

[B1055] Bartakova, B.; Krump, J.; and Vosahlik, V.; "Effect of electric partial discharge of SF_6," *Electrotechnichy Obzor*, Prague, vol. 67, p. 230, 1978.

[B1056] al-Bawy, I., and Farish, O., "Charge deposition on an insulating spacer under impulse-voltage conditions," *IEE Proceedings, Part A: Physical Science, Measurement and Instrumentation, Management and Education*, Reviews vol. 138, no. 3, pp. 145–152, May 1991.

[B1057] Binns, D. F. and Cook, G. H., "Breakdown between insulated ring conductors in SF_6-C8F160," *Fourth International Conference on Dielectric Materials, Measurements, and Applications, Lancaster*, England, pp. 10–13, Sept. 1984.

[B1058] Blackburn, T. R., and Boswell, R. W., "Insulator surface damage in SF_6-insulated systems," *Proceedings of the Eighth International Conference on Gas Discharge and Their Applications*, Sept. 1984.

[B1059] Bobikov, V. E., and Tripoten, I. G., "Investigating the electrostatic fields on the insulators of gas-filled plant," *Izv. VUZ Energ*. (USSR), no. 4, pp. 43–46, Apr. 1984.

[B1060] Bobo, J. C., and Vigreux, J., "Dielectric behaviour of insulation in SF_6 at extra high voltage," *CIGRE*, Paper 15–08, 12 pages, Aug. 1976.

[B1061] Brandt, T. F.; Netzel, P. C.; and Ponder, J. Z.; "Progress in insulator development for flexible gas insulated transmission systems," *Proceedings of the 13th IEEE Electrical/Electronics Insulation Conference*, New York, N.Y., Publication 77 CH 123-2-EI, pp. 331–335, Sept. 1977.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1062] Braun, J. M., et al., "PD scaling relationships in GIS insulators: Theory and experimental verification," *Sixth International Conference on Dielectric Materials, Measurements and Applications*, pp. 166–169, 1992.

[B1063] Braun, J. M.; Chu, E Y; and McIntyre, N. S.; "Characterization of degraded epoxy spacer surfaces by electron spectroscopy," *CEIDP*, Annual Report, 1984.

[B1064] Brockman, R., and von Olshausen, R., "Flashover voltage dependence on the tangential field strength of contaminated insulator surfaces in SF_6," *Seventh International Conference on Gas Discharges and Their Applications*, pp. 280–283, Sept. 1982.

[B1065] Chee-Hing, D. J., and Srivastava, K. D., "Insulation performance of dielectric-coated electrodes in sulphur hexafluoride gas," *IEEE Transactions on Electrical Insulation*, vol. 10, no. 4, pp. 119–124, Dec. 1975.

[B1066] Chenoweth, T. E.; Yeoman, F. A.; and Cookson, A. H.; "Epoxy casting composition for UHV service in compressed SF_6 insulated equipment," *Proceedings of the 13th IEEE Electrical/Electronics Insulation Conference*, New York, MY, Publication 77 CH 123-2-EI, pp. 322–326, Sept. 1977.

[B1067] Cherukupalli, S. E., "Surface Charge Accumulation on Spacers under Switching Impulses in Sulphur Hexafluoride Gas," Thesis, University of British Columbia, B.C., Canada, 1987.

[B1068] Cho, Y. O.; Choi, B. J.; and Kim, K. S.; "Local field control and laboratory testing of cone-type spacers for 345 kV GIS," *Seventh International Symposium on High Voltage Engineering*, vol. 1, pp. 143–145, 1991.

[B1069] Chu, F. Y; Braun, J. M.; and Seethapathy, R.; "Degradation mechanisms for epoxy insulators exposed to SF_6 arcing by-products," *Proceedings of the IEEE International Symposium on Electrical Insulation*, June 1986.

[B1070] Cooke, C. M., and Trump, J. G., "Post-type support spacers for compressed gas-insulated cables," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-92, no. 5, pp. 1441–1447, Sept./Oct. 1973.

[B1071] Cooke, C. M., and Velazquez, R., "The insulation of ultra-high voltages in coaxial systems using compressed SF_6 gas," *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 5, pp. 1491–1497, Sept./Oct. 1977.

[B1072] Crouch and Houlgate, R. G., "Technical implications of hollow composite insulators for HV SF_6 switchgear," *IEE Colloquium on Structural Use of Composites in High Voltage Switchgear/Transmission Networks*, Digest no. 223, pp. 2/1–4, 1992.

[B1073] Crucius, M., et al., "Long duration tests on epoxy insulators in SF_6 gas," *CIGRE*, Paper 15-07, 9 pages, Aug. 1978.

[B1074] Dakin, T. W., and Studniarz, S. A., "The voltage endurance of cast and molded resins," *IEEE Electrical/ Electronics Insulation Conference*, Publication 77 CH 123-2-EI, pp. 318–321, Sept. 1977.

[B1075] Dale, S. J., "Future development in solid dielectric insulators for compressed gas insulated transmission systems," *Conference on Electrical Insulation and Dielectric Phenomena*, IEEE, Whitehaven, Pa., pp. 404–409, Oct. 1981.

[B1076] de Metz-Noblat, B., and Doin, Y. "GIS Insulation and Disconnector Operation." In *Gaseous Dielectrics VI*, 1991, pp. 451–456.

[B1077] De Tourrell, C. H., and St. Onge, H., "Evaluation of epoxy resin formulations for SF_6 cable spacer materials," *IEEE International Symposium on Electrical Insulation*, Publication 78 CH1287-2-EI, pp. 167–171, June 1978.

[B1078] Farish, O. and al-Bawy, I., "Effect of surface charge on impulse flashover of insulators in SF_6," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 3, pp. 443–452, June 1991.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1079] Farouk, A. M., "Statistical stress-duration characteristics of HV insulation," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 400–408, Jan. 1981.

[B1080] Fujimoto, N., et al. "Characteristics of Ultra Low Level Partial Discharges in GIS Epoxy Insulators." In *Gaseous Dielectrics VI*, 1991, pp. 509–514.

[B1081] Fujimoto, N., and Braun, J. M., "Behaviour of GIS epoxy insulators with metallic inclusions: Effect of needle tip radius," *Seventh International Symposium on High Voltage Engineering*, vol. 2, pp. 111–114, 1991.

[B1082] Giessner, B. G., "SF_6 epoxy foam a novel electrical insulation material," *IEEE Electrical/Electronics Insulation Conference*, Publication 77 CH 123-2-EI, pp. 336–339, Sept. 1977.

[B1083] Giessner, B. G., "SF_6 foamed insulation," *EPRI*, Project 749, Final Report EL-520, 86 pages, Aug. 1977.

[B1084] Harris, A. F., "Insulating surfaces associated with high voltage metalclad SF_6 filled switchgear," *IEEE Colloquium on Breakdown and Discharge Phenomena on Insulating Surfaces in Gas Media and Vacuum*, Digest no. 1975/Z6, pp. 1/1–1/5, Nov. 1975.

[B1085] Jarmula, J., "Laboratory testings of electrical insulating materials' surface resistance to hydrogen fluoride vapours as selection criteria for SF_6-filled circuit breaker insulators," *CEIDP*, Annual Report, pp. 457–462, 1981.

[B1086] Jing, T., and Morshuis, P. H. F., "Space charge induced field variation on epoxy spacers under ac stresses in SF6 (GIS)," *Sixth International Conference on Dielectric Materials, Measurements and Applications*, Publication no. 363, pp. 178–181, 1992.

[B1087] Jing, T.; Morshuis, P. H. F.; and Kreuger, F. H.; "Surface charge accumulation and decay on a spacer stressed with dc voltages at atmospheric conditions," *Archiv fur Elektrotechnik*, vol. 74, no. 4. pp. 315–319, 1991.

[B1088] Laghari, J. R., "Spacer flashover in compressed gases," *IEEE Transactions on Electrical Insulation*, vol. EI-20, no. 1, p. 83.92, Feb. 1985.

[B1089] Laghari, J. R., and Qureshi, A. H., "Flashover studies of cylindrical spacers in SF_6,-N_2, mixtures," *IEEE Power Engineering Society Winter Meeting*, Paper A80 055-4, 7 pages, Feb. 1980.

[B1090] Laghari, J. R., and Qureshi, A. H., "Surface flashover of spacers in compressed gas-insulated systems," *IEEE Transactions on Electrical Insulation*, vol. EI-16, no. 5, p. 373, 1981.

[B1091] Maizel, E. S., "Investigation of flashover of dielectric bracings in a system of coaxial cylinders with compressed gas," *Electric Technology*, vol. 4, pp. 100–108, 1969.

[B1092] Mashikian, M. S.; Whitney, B. F.; and Freeman, J. J.; "Optimal design and laboratory testing of post-type spacers for three-phase, SF_6 insulated cables—Part I: Optimization philosophy, design and test results," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 3, pp. 914–918, May/June 1978.

[B1093] Menju, S.; Tsuchikawa, Y; and Kobayashi, N.; "Electric potential and field of conical insulators for SF_6 metalclad switchgear," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, pp. 390–398, Mar./Apr. 1972.

[B1094] Ming, Li, et al., "Surface charging of a particle-contaminated spacer in SF_6 under dc stress," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 386–389, 1992.

[B1095] Muto, S.; Mizuno, K.; and Masaki, T.; "Computer methods in field analysis, II," *Bulletin of Nagoya Institute of Technology* (Japan), vol. 24, pp. 185–191, 1972.

 --`,,`-`-`,,`,,`,`,,`---

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS

Not for Resale

[B1096] Nakakita, T., and Koyanagi, E., "Dielectric breakdown of epoxy resin plates to surface partial discharges in sulfurhexafluoride gas," *Electrical Engineering in Japan*, vol. 94, no. 3, pp. 21–27, 1974.

[B1097] Nakanishi, K., and Inami, K., "Optical measurement of flashovers along the solid spacer in SF_6 gas and an explanation of flatness of the V-T curves," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 378–381, 1992.

[B1098] Narimatsu, S., et al., "Interrupting performance of capacitive current by disconnecting switch for gas-insulated switchgear," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 2726–2732, June 1981.

[B1099] Okabe, S., et al., "Particle-contaminated spacers in SF_6 gas-insulated switchgear," *IEEE Transactions on Power Delivery*, vol. 7, no. 3, pp. 1232–1238, 1992.

[B1100] Perry, E. R., and Cronin, J. C., "Optimization of insulators for gas-insulated systems," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 2, pp. 558–564, Mar./Apr. 1973.

[B1101] Reighter, D. H., "Arc resistance testing of materials under various gaseous atmospheres," *IEEE Electrical/Electronics Insulation Conference*, Publication 77 CH 123-2-EI, pp. 346–350, Sept. 1977.

[B1102] Reighter, D. H., "Screening devices to determine resistance of insulation to arcing in gaseous atmospheres," *IEEE Power Engineering Society Summer Meeting*, Paper A 77 719-8, July 1977.

[B1103] Srivastava, K. D., and Zhou, J., "Surface charging and flashover of spacers in SF_6 under impulse voltages," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 3, pp. 428–442, June 1991.

[B1104] Tominaga, S.; Kuwahara, H.; and Hirooka, K.; "Influence of arc-decomposed SF_6 gas on cast epoxy insulators for gas-insulated switchgear," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-98, pp. 2107–2114, 1979.

[B1105] Trinh, N. G.; Rizk, F. A. M.; and Vincent, C.; "Electrostatic field optimization of the profile of epoxy spacers for compressed SF_6 insulated cables," *IEEE Power Engineering Society Winter Meeting*, Paper F80 217-0, 9 pages, Feb. 1980.

[B1106] Trinh, N. G., and Vincent, C., "Bundled-conductors for EHV transmission systems with compressed-SF_6 insulation," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 6, pp. 2198–2206, Nov./Dec. 1978.

[B1107] Tsuchihashi, M., et al., "Mechanical properties of particulate-filled epoxy resins for gas-insulated substations," *Proceedings of the 15th Electrical/Electronics Insulation Conference*, pp. 289–293, Oct. 1981.

[B1108] Varivodov, V. N., and Volpov, E. K., "An approach to the spacer design of HVDC SF_6 gas insulated equipment," *Seventh International Symposium on High Engineering*, vol. 3, pp. 41–44, 1991.

[B1109] Wang, C. X., Wilson, A., and Watts, M. W., "Surface discharge on epoxy resin insulators in SF_6 under chopped dc," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 366–369, 1992.

[B1110] Wang, C. X., Wilson, A., and Watts, M. W., "Surface flashover sustained by electrostatic surface charge on epoxy resin insulator in SF_6 (GIS insulators)," *Sixth International Conference on Dielectric Materials, Measurements and Applications*, Publication no. 363, pp. 182–185, 1992.

[B1111] Whitney, B. E, and Mashikian, M. S., "Optimal design and laboratory testing of post-type spacers for three-phase, SF_6 insulated cables—Part 2: Numerical method for controlling the electric field at spacer boundaries," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 3, pp. 919–925, May/June 1978.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1112] Wootton, R. E., and Emery, F. T., "A test for the effect of high energy arcs on the flash-over strength of insulators in compressed SF_6," *IEEE Transactions on Electrical Insulation*, vol. EI-15, no. 2, pp. 74–80, Apr. 1980.

[B1113] Wootton, R. E.; Emery, F. T.; and Cookson, A. H.; "A test for the effect of high energy arcs on the flash-over strength of insulators in compressed SF_6," *IEEE Electrical/Electronics Insulation Conference*, Publication 77CH123-2-EI, pp. 351–355, Sept. 1977.

[B1114] Xie, Jun; Chalmers, I. D.; and Farish, O.; "The influence of dc prestress on flashover of insulators in SF_6," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 370–373, 1992.

[B1115] Yoon, K. H., "Selection of insulating materials used in SF_6 circuit breakers," *IEEE Electrical/Electronics Insulation Conference*, Publication 77 CH 123-2-EI, pp. 340–345, Sept. 1977.

[B1116] Zdanowicz, L., "Effective ionization potential of arcs contaminated by impurity vapors (circuit breaker)," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 106–109, 1992.

6.2.9 Isolating and grounding devices

[B1117] Beer, H., and Richter, F., "Load break switches for metalclad SF_6 insulated 123 kV switchgear," *Siemens Review*, vol. 40, no. 3, pp. 106–109, Mar. 1973.

[B1118] Benes, O., and Mudra, J., "The effect of electrode surface on the dielectric strength of SF_6 at impulse voltages," *Electrotechnichy Obzor*, Prague, vol. 74, no. 1, pp. 17–22, Jan. 1985.

[B1119] Blahous, T., et al., "Transient overvoltages during disconnector switching in GIS: Analysis," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3088–3097, Sept. 1983.

[B1120] Boggs, S. A., et al., "Disconnect switch-induced transients and trapped charge in gas-insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 10, pp. 3593–3602, Oct. 1982.

[B1121] Boggs, S. A.; Chu, F. Y.; and Fujimoto, N.; "Disconnect switch-induced transients and trapped charge in GIS," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, Oct. 1982.

[B1122] Braun, J. M., et al., "Reliability of GIS EHV epoxy insulators: The need and prospects for more stringent acceptance criteria," *IEEE Transactions on Power Delivery*, vol. 8, no. 1, pp. 121–131, 1993.

[B1123] Dirks, R., "SF_6 switchgear with load separation switches," *Elektr. Energ. Tech.*, vol. 29, no. 3, pp. 46–48, Sept. 1984.

[B1124] Fellmann, K. H., and Imgrund, G., "Influence of model test circuits on transient phenomena during interruption of small capacitive currents with SF_6-insulated high voltage disconnectors," *ETZ Arch.* (Germany), vol. 7, no. 4, pp. 105–115, Apr. 1985.

[B1125] Feser, K., and Sun, R., "Electromagnetic impulses in high voltage GIS-substation during a disconnector operation," *International Electromagnetic Compatibility Symposium Proceedings*, pp. 140–145, 1992.

[B1126] Gorablenkow, J. M.; Kynast, E. E.; and Luehrmann, H. M.; "Switching of capacitive currents of disconnectors in gas-insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 6, pp. 1363–1370, June 1984.

[B1127] Greenwood, A. N., and Stokes, A. D., "Electric power switches," *IEEE Transactions on Plasma Science*, vol. 19, no. 6, pp. 1132–1142, Dec. 1991.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1128] Habedank, U.; Kugler, R.; and Veuhoff, F.; "Type testing of earthing switches and development of new test specification," *Proceedings of the International Symposium on Gas-Insulated Substations: Technology and Practice*, Toronto, Ontario, Canada, pp. 138–146, Sept. 1985.

[B1129] IEEE Std C37.38-1989 IEEE Standard for Gas-Insulated Metal-Enclosed Disconnecting, Interrupter, and Grounding Switches (ANSI).

[B1130] Itoh, N., et al., "Switching requirements for disconnecting switch and earthing switch of GIS," *IEEE Power Engineering Society Winter Meeting*, Atlanta, Ga., Conference Paper 81/WM143-7, Feb. 1981.

[B1131] Kugler, R., et al., "Grounding switches for gas-insulated substations: Testing capacitive and inductive switching capability," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3569–3572, Dec. 1984.

[B1132] Kunhardt, E. "Basic Topics of Current Interest to Switching for Pulse Power Applications." In *Gaseous Dielectrics IV*, edited by L. G. Christophorou and M. O. Pace, pp. 213–248. Pergamon Press, 1984.

[B1133] Maller, N. V., and Srivastava, K. D., "Effect of insulator on breakdown and time to breakdown probability distributions in SF_6 under impulse voltages," *IEEE Conference Record of the 1983 Interfacial Phenomena in Practical Insulating Systems*, Gaithersburg, Md. (New York: IEEE, 1984), pp. 73–77, Sept. 19–20, 1983.

[B1134] Mauthe, G., and Krieter, G. H., "Earthing switches in metalclad high voltage SF_6 switchgear installations," *Brown Boveri Review*, vol. 64, pp. 662–666, Nov. 1977.

[B1135] Miller, D. B., "Measurement and analysis of switching transients in gas-insulated transmission lines," *EPRI*, Final Report EL-5145, May 1987.

[B1136] Morita, T.; Tsutsumi, M.; and Nagami, K.; "Switching capabilities of SF_6 gas circuit breaker, isolator, and earthing switch," *Fuji Elect. Review*, vol. 30, no. 2, pp. 74–83, 1984.

[B1137] Narimatsu, S., "Disconnecting switch for gas-insulated switchgear, capacitive current interruption," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 2726–2732, June 1981.

[B1138] Neumann, C., and Konig, D., "The switching performance of SF_6-insulated, metal enclosed and air-insulated disconnectors—A comparison with regard to transient phenomena," *Seventh International Symposium on High Voltage Engineering*, vol. 8, pp. 123–126, 1991.

[B1139] Neumann, C., Konig, D., and Imgrund, G. "Transient Current and Voltage Behaviour During Interruption of Small Capacitive Currents with GIS-Disconnectors." In *Gaseous Dielectrics VI*, 1991, pp. 497–502.

[B1140] Nishiwaki, S., et al., "Ground fault due to restriking of SF_6-insulated disconnecting switch: Synthetic test circuits," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 219–227, Jan. 1983.

[B1141] Pfeiffer, W., and Stolz, D. "A New Approach for an Opening Switch for Repetitive Operation." In *Gaseous Dielectrics VI*, 1991, pp. 341–346.

[B1142] Rahmann, F. J., and Schemmann, B., "SF_6-insulated medium voltage switching equipment—Intersection point question resolved," *Electrizitaetswirtschaft* (Germany), vol. 83, no. 17–18, pp. 762–766, Aug. 1984.

[B1143] Schwager, H. H., "SF_6 filled hermetically sealed vacuum interrupter switch, six years field experience," *IEEE Power Engineering Society Underground Transmission and Distribution Conference*, Publication 76 CH1119-7-PWR, pp. 512–518, Sept. 1976.

[B1144] "SF_6-insulated load isolator switches for medium voltage network stations," *Electrizitaetswirtschaft*, vol. 84, no. 8, pp. 294–297, Apr. 1985.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1145] Stiborora, E.; Kopacek, M.; and Skoda, Z.; "New HV switches with SF_6 of the VF type for voltages 7.2 to 38 kV," *Electrotechnichy* (Czechoslovakia), vol. 39, no. 3, pp. 74–77, Mar. 1984.

[B1146] Sun, R., et al., "A simplified method for the determination of the maximum overvoltage factor during disconnector operation in GIS," *Seventh International Symposium on High Voltage Engineering*, vol. 8, pp. 119–122, 1991.

[B1147] Tomberger, H., and Vontobel, J., "Results and experiences with a 220 kV metalclad SF_6 gas insulated installation with special consideration to load disconnect switches," *CIGRE*, Paper 23–01, 13 pages, Aug. 1972.

[B1148] Tsybrovskii, G. G., "Comparison of switching characteristics of air, vacuum, and sulfur hexafluoride contactors," *Sov. Electr Eng*., vol. 54, no. 1, pp. 98–100, 1983.

[B1149] Wiggins, C. M., and Wright, S. E., "Switching transient fields in substations," *IEEE Transactions on Power Delivery*, vol. 6, no. 2, pp. 591–600, 1991.

[B1150] Woodworth, J. R., et al., "Laser triggering of a 500 kV gas-filled switch: A parametric study," *Journal of Applied Physics*, vol. 56, no. 5, pp. 1382–1386, Sept. 1984.

[B1151] Yanabu, S., et al., "High current interruption by SF_6 disconnecting switches in gas-insulated switchgear," *IEEE Power Engineering Society Summer Meeting*, Portland, Ore., Conference Paper 81 5M464-7, July 1981.

[B1152] Yanabu, S., et al., "Magnetic driving-type disconnecting switch for interrupting loop current in gas-insulated switchgear," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 640–648, Mar. 1984.

6.2.10 Power transformers, capacitors, and reactors

[B1153] "Advanced concepts for 1200 kV shunt reactor—Volume I: Exploration of new concepts for inductive shunt reactor designs for integration into a 1200 kV gas-insulated substation. Final Report," Westinghouse Electric Corporation, Muncie, Ind., DOE/ET/39073-Tl, Mar. 1981.

[B1154] Camilli, G.; Gordon, G. S.; and Plump, R. E.; "Gaseous insulation for high-voltage transformers," *Transactions of AIEE*, pp. 348–357, Jan. 1952.

[B1155] Chan, L., and Sum, C. L., "Operating experience of SF_6 gas-filled power transformers," 1991 *International Conference on Advances in Power System Control, Operation and Management*, IEE, vol. 1, pp. 410–414, 1991.

[B1156] Dodds, J. J., et al., "Development of gas insulated compact capacitor bank," *Seventh IEEE Transmission and Distribution Conference*, Publication CH1137-5, pp. 245–252, Apr. 1979.

[B1157] "Evaluation of advanced technologies for power transformers, NYSERDA," *General Electric Corporate Research and Development*, Schenectady, N.Y., Jan. 1981.

[B1158] Girgis, R. S., and Ko, C. D., "Calculation techniques and results of effects of GIC currents as applied to two large power transformers," *Proceedings of the 1991 IEEE Power Engineering Society Transmission and Distribution*, pp. 553–559, 1992.

[B1159] Harumoto, Y.; Yoshida, Y.; and Koan, T.; "Development of EHV large capacity gas insulated liquid cooled power transformer," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 121–124, 1991.

[B1160] Hasegawa, T., et al., "Development of a 275-kV liquid cooling-type gas-insulated transformer," *Electrical Engineering in Japan*, vol. 112, no. 1, pp. 84–92, 1992.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1161] Inoue, T., et al., "Dielectric characteristics of static shield for coil end of gas-insulated transformer," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, vol. 2, pp. 1124–1127, 1991.

[B1162] Inui, A., et al., "Dielectric characteristics of static shield for coil-end of gas-insulated transformer," *IEEE Transactions on Electrical Insulation*, vol. 27, no. 3, pp. 572–577, 1992.

[B1163] Ito, S., and Miura, Y., "Large SF_6 transformers for urban Japan," *Modern Power Systems*, vol. 12, no. 3, pp. 37, 39, 41, 1992.

[B1164] Kudo, A., et al., "Development of 275 kV gas cooled type gas insulated power transformer," *IEEE Transactions on Power Delivery*, vol. 8, no. 1, pp. 264–270, Jan. 1993.

[B1165] Kumagaya, I. S.; Kobayashi, M.; and Honda, S.; "SF_6 gas-insulated transformer," *Takoaka Rev*., vol. 31, no. 2, pp. 76–82, 1984.

[B1166] Kumagaya, I. S.; Kobayashi, M.; and Honda, S.; "SF_6 gas-insulated transformer, II," *Takoaka Rev*., vol. 31, no. 2. pp. 113–118, 1984.

[B1167] Moore, C. L.; Voytik, P.; and Hollister, R. H.; "Recent developments in gas/vapor and fire resistant transformers," *IEEE Transmission and Distribution Conference*, Publication CH 1139-5, pp. 59–67, Apr. 1979.

[B1168] Morris, J. R., II, and Philip, S. F., "A new concept for a compressed gas-insulated power transformer," *IEEE Transmission and Distribution Conference, Publication* CH1139-5, pp. 178–183, Apr. 1979.

[B1169] Mukaiyama, Y., et al., "Development of a perfluorocarbon liquid immersed prototype large power transformer with compressed SF_6 gas insulation," *IEEE Transactions on Power Delivery*, vol. 6, no. 3, pp. 1108–1116, 1991.

[B1170] Muramoto, H., et al., "Development and application of the 275 kV-300 MVA separate-cooling/ sheet-winding gas-insulated transformer," *Proceedings of the 1991 IEEE Power Engineering Society Transmission and Distribution Conference*, pp. 599–605, 1991.

[B1171] Okabe, S., et al., "Investigations of multiple reignition phenomena and protection scheme of shunt reactor current interruption in GIS substations," *IEEE Transactions on Power Delivery*, vol. 8, no. 1, pp. 197–202, 1993.

[B1172] Okazaki, M., and Inaba, T., "Development of a new multi-divided type of commutating elements for fault current limiters on distribution lines," *IEEE Transactions on Power Delivery*, vol. 6, no. 4, pp. 1498–1502, Oct. 1991.

[B1173] Reed, C. W., et al., "Partial discharge inception and breakdown studies on model sheet-wound, compressed SF_6 gas-impregnated polymer film-insulated windings," *Second International Symposium on Gaseous Dielectrics*, pp. 404–417, Mar. 1980.

[B1174] Walsh, E. J., "The use of SF_6 or C_2F_6 in oil filled transformer," *IEEE International Symposium on Gaseous Dielectrics*, Publication no. CONF-780301, pp. 276–285, Mar. 1978.

[B1175] Walsh, E. J.; Robinson, J. A.; and Wandel, R. C.; "SF_6/oil dielectric for power transformers," *EPRI*, Final Report EL-1358, Project 808-1, Mar. 1980.

6.2.11 Surge arresters

[B1176] Beloedova, I. P., et al., "Optimization of designs of surge limiters with SF_6 insulation," *Soviet Electrical Engineering*, vol. 62, no. 12, pp. 25–30, 1991.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1177] Hampton, B. F., et al., "A triggered coordinating gap for metalclad substations," *CIGRE*, Paper 33-16, 9 pages, Aug. 1978.

[B1178] Hartmann, H., and Burger, U., "Lightning arresters for metalclad SF_6 switchgear with voltages from 12.5 to 525 kV," *Brown Boveri Review*, vol. 64, pp. 667–670, Nov. 1977.

[B1179] Kalb, I. W., "Surge arrester for 1200 kV gas insulated substation," *IEEE Power Engineering Society Transmission and Distribution Conference*, 7 pages, Apr. 1979.

[B1180] Knobloch, H., et al., "Influence of the surrounding medium and service behaviour of metal oxide resistors for high voltage arresters," *IEEE Transactions on Power Delivery*, vol. 6, no. 2, pp. 680–687, Apr. 1991.

[B1181] Miller, D. B., et al., "Development of gapless metal oxide surge arresters for 362 kV gas-insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 7, pp. 2178–2183, July 1982.

[B1182] Nagai, N.; Nitta, T.; and Ujita, K.; "SF_6 gas filled surge arrester for power systems." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 4, p. 1010, July/Aug. 1978.

[B1183] Nitta, T., et al., "SF_6 gas-filled lightning arrester for 500 kV power system," *Electrical Engineering in Japan*, vol. 92-B, pp. 79–80, 1972.

[B1184] Potter, M. E., and Sokoly, T. O., "Development of metal-oxide varistors for gas-insulated surge arresters," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 7, pp. 2217–2220, July 1982.

[B1185] "Research center conducts full-scale tests on MPR-396 surge arresters for gas-insulated substations," *Hi Tension News*, vol. 45, no. 12, pp. 6–8, Dec. 1976.

[B1186] Rizk, F. A. M., "Critical switching impulse strength of long air gaps: Modelling of air density effects," Proceedings of the 1991 *IEEE Power Engineering Society Transmission and Distribution Conference*, pp. 890–897, 1991.

[B1187] Suzuki, T., and Ohmachi, H., "Development of a new type SF_6 gas lightning arrester," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 6, p. 1805, Nov./Dec. 1973.

[B1188] Zhang, W., and Wang, S., "Optimized protection scheme for 500 kV GIS against lightning surge," *Seventh International Symposium on High Voltage Engineering*, vol. 8, pp. 237–240, 1991.

6.2.12 Terminations

[B1189] Arkell, C. A.; Galloway, S. J.; and Gregory, B.; "Supertension cable terminations for metalclad SF_6-insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 5, pp. 1021–1029, May 1982.

[B1190] Carlson, G. L., and Hickman, W. M., "Improved leak-test method for SF_6 pressurized bushing gaskets," *Doble Client Conference*, sec. 4, pp. 301–311, Apr. 1976.

[B1191] "Frank B. Black Research Center reports successful development of high voltage cable termination for gas-insulated substations," *Hi Tension News*, vol. 46, no. 2, pp. 6–7, Feb. 1977.

[B1192] Graybill, H. W., et al., "Termination of high pressure oil cables in SF_6 gas insulated mini-substation equipment," *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 5, pp. 1669–1694, Sept./Oct. 1974.

[B1193] Hill, E. H., "Report on silicone repairs by utilities of leaking SF_6 bushings," *Doble Client Conference*, sec. 4, pp. 201–206, Apr. 1979.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1194] Ishikawa, M., et al., "An approach to the suppression of sheath surge induced by switching surges in a GIS/power cable connection system," *IEEE Power Engineering Society Winter Meeting*, Paper F80 277–4, 8 pages, Feb. 1980.

[B1195] Masepohl, J. C., and Martinkus, J., "69 kV Slip-on mini-sub SF_6 termination," *IEEE Power Engineering Society Underground Transmission and Distribution Conference*, Publication 76 CH 1119–7-PWR, pp. 373–377, Sept. 1976.

[B1196] Parvopassu, P., et al., "150 kV EPM cable connections between transformers and SF_6 insulated switchgear for five substations in Rome," *IEEE Power Engineering Society Summer Meeting*, Paper F76 383–0, July 1976.

[B1197] Swoish, R. F., et al., "The environmental and technical aspects of terminating external HV to UHV connections at substations," *CIGRE*, Paper 23–08, 10 pages, Aug. 1976.

[B1198] Upton, C. W., and Torok, J. S., "SF bushing leakage—The problems and solutions," *Doble Client Conference*, sec. 4, pp. 201–206, Apr. 1976.

[B1199] Wagenaar, L. B., "Bushing for oil to SF_6," *Electrical Review*, vol. 199, no. 17, pp. 46–49, Oct. 29, 1976.

6.2.13 Equipment design

[B1200] Alden, L., and Arnesson, I, "ASEA center functioned, all-round switchgear," *ASEA Journal* (Sweden), vol. 58, no. 1, pp. 4–9, 1985.

[B1201] Blower, R. W., "Factors in the design of sulphur-hexafluoride switchgear for distribution systems," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 9, pp. 2753–2761, Sept. 1984.

[B1202] Boggs, S. A.; Ford, G. L.; and Madge, R. C.; "Coupling devices for the detection of partial discharges in gas-insulated switchgear," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3969–3973, Aug. 1981.

[B1203] Dakin, T. W., "Application of epoxy resins in electrical apparatus," *IEEE Transactions on Electrical Insulation*, vol. EI-9, no. 4, Dec. 1974.

[B1204] Duplay, C., "SF_6 for medium voltage finds its feet," *Mod. Power Systems*, vol. 4, no. 2, pp. 55–57, Feb. 1984.

[B1205] Friedrich, R. E., "Requirements for gas-insulated equipment through 1980," *Proceedings of the American Power Conference*, Chicago, Ill., vol. 37, pp. 1128–1135, Apr. 1975.

[B1206] "Gas insulation technology and products," *Takaoka Review* (Japan), vol. 35, no. 2, pp. 113–117, 1988.

[B1207] Grasselt, H.; Ecknig, W.; and Polster, H. J.; "Applications of gas chromatography for the development of SF_6-insulated switchgear and equipment," *Elektrie*, vol. 32, pp. 369–371, 1978.

[B1208] Hoyer, P.; Schemmann, B.; and Lubben, S. F.; "Gas-insulated switchgear for distribution voltages—The answer to more stringent requirements for operational and environmental conditions," *CIRED 1985, Eighth International Conference on Electricity Distribution*, EEI Publication no. 250, pp. 28–32, May 20–24, 1985.

[B1209] Hubler, E., et al, "Comparative evaluation of epoxy resin systems for SF_6 insulated substation components," *Proceedings of the IEEE Insulation Symposium*, Xian, China, Paper CH2115-4/85, 1985.

[B1210] Ishida, A., et al., "550 kV Gas-insulated switchgear from the Shimmikawa substation of the Chubu Electric Power Company," *Mitsubishi Denki Giho* (Japan), vol. 57, no. 6, pp. 31–35, 1983.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1211] Kato, F.; Ogawa, H.; and Aoki, T.; "Recent development in railway substation system and equipment," *Toshiba Rev., Int. Ed.* (Japan), no. 13, pp. 14?–18, Jan./Feb. 1981.

[B1212] Kawabata, H., and Ose, K., "History and development trend of Fuji SF_6 gas-insulated equipment," *Fuji Elect. Review*, vol. 30, no. 2, pp. 46–52, 1984.

[B1213] Kodama, T., et al., "72.5–170 kV Three-phase encapsulated SF_6 gas-insulated switchgear," *Fuji Elect. Review*, vol. 30, no. 2, pp. 53–60, 1984.

[B1214] Kolbe, W., "Effects of arcing faults on SF_6 metalclad equipment," Doctorate diss., Technical University, Darmstadt, Germany, 1976.

[B1215] Kort, F., and Zumbach, E., "Three-phase metalclad SF_6-insulated 123 kV switchgear," *BBC Nachr*, vol. 66, no. 8, pp. 300–308, 1984.

[B1216] Lister, C. A., "Vacuum, SF_6, and air-break contactors from medium voltage controllers," *IEEE Conference Record, 1984 Annual Pulp and Paper Industry Technical Conference*, Toronto, Canada, pp. 28–36, June 19–22, 1984.

[B1217] Martin, G. O., "SF_6 gas technology as used in medium voltage switchgear," *Certif. Eng.*, vol. 57, no. 7, pp. 112–115, July 1984.

[B1218] Mazza, G., and Marzzoleni, B., "1000 kV Gas-insulated switchgear," *Energy Elettr* (Italy), vol. 60, no. 12, pp. 486–495, Dec. 1983.

[B1219] McCarthy, B., et al., "The design of a coaxial Blumlein generator for fast transient flashover studies in GIS," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 1, pp. 410–413, 1992.

[B1220] Mitsui, T., et al., "Development of Fib287Optic voltage sensors and magnetic-field sensors," *IEEE Transactions on Power Delivery*, vol. PWRD-2, no. 1, pp. 87–93, Jan. 1987.

[B1221] Murakami, Y., and Menju, S., "Fundamental techniques in gas-insulated apparatus," *Toshiba Review*, vol. 117, p. 5, Sept. 1978.

[B1222] Mushiga, M., et al., "Cubicle-type SF_6 gas-insulated switchgear for Nippon Benkan Kogyo Co., Ltd.," *Takoaka Rev.* (Japan), vol. 31, no. 3, pp. 109–112, 1984.

[B1223] Nikiforov, M. G., et al., "Megavolt range pulse voltage generators in compressed SF_6 gas," *Seventh International Symposium on High Voltage Engineering*, vol. 5, pp. 13–16, 1991.

[B1224] Okuda, H., et al., "Control of SF_6 discharge gap switch by XeCl Excimer laser," *Electrical Engineering in Japan*, vol. 111, no. 4, pp. 46–51, 1991.

[B1225] Okutsu, Naohiro, et al., "Pattern recognition of vibrations in metal enclosures of gas-insulated equipment and its application," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 2733–2739, June 1981.

[B1226] Ott, H. P., "SERCOS-in service at Davos District Electric Power Utility," *Sprecher Energie Review*, no. 1, pp. 7–8, 1992.

[B1227] Ruffieux, S., "SF_6 medium voltage circuit breakers—Self-extinction has proved its worth," *Brown-Boveri Review*, vol. 71, no. 1–2, pp. 62–67, Jan./Feb. 1984.

[B1228] Stahan, I., "Are SF_6 switchgear assemblies pressure vessels or not?" *Energya* (Yugoslavia), vol. 33, no. 2, pp. 137–142, 1984.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1229] Syau, T.; Venkatraman, P.; and Baliga, B. J.; "Comparison of ultralow specific on-resistance UMOSFET structures," *IEEE Transactions on Electron Devices*, vol. 39, no. 11, pp. 2672–2673, Nov. 1992.

[B1230] Szente-Varga, H. P., "550-kV SF_6 Gas-insulated switchgear for the Itaipu hydropower station," *Brown Boveri Review*, vol. 68, no. 3–4, pp. 157–159, Mar./Apr. 1981.

[B1231] Tedford, D.; Campbell, L. C.; and Pender, J. T.; "Modern research and development in SF_6 switchgear," *Electronics and Power*, vol. 29, no. 10, p. 719, Oct. 1983.

[B1232] Thuries, E., et al., "Breaking new ground in SF_6 technology," *Modern Power Systems*, vol. 13, no. 1, pp. 43, 45–46, 1993.

[B1233] Tsuchihashi, M., et al., "Mechanical properties of particulate-filled epoxy resins for gas-insulated substations," *Proceedings of the 15th Electrical/Electronics Insulation Conference*, Chicago, Ill., Conference Paper, pp. 289–293, Oct. 1981.

[B1234] Tunnicliffe, P. R., "Accelerator research and engineering," *AECL Symposium on Engineering Development in Nuclear Power*, Chalk River, Canada, pp. 67–74, 1971.

[B1235] Walldorf, S. P., and Gnadt, P. A., "Development of 1200 kV compressed-gas-insulated transmission and substation equipment in the United States," *IEEE Transactions on Power Delivery*, vol. PWRD-2, no. 2, pp. 374–383, Apr. 1987.

[B1236] Wuthrich, H. R., and Ott, H. P., "Advanced metalclad switchgear equipment," *CIRED*, vol. 1, pp. 1.4/1–6, 1993.

[B1237] Zelingher, S., "EHV SF_6-insulated lines: Parameter determination based on system performance criteria," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 4515–4523, Nov. 1981.

6.2.14 Bushings

[B1238] "17th PICA Conference," *IEEE Transactions on Power Delivery*, vol. 7, no. 2, pp. 546–1049, Apr. 1992.

[B1239] Ardito, A., et al., "Accurate modeling of capacitively graded bushings for calculation of fast transient overvoltages in GIS," *IEEE Transactions on Power Delivery*, vol. 7, no. 3, pp. 1316–1327, 1992.

[B1240] Elkins, D. L., et al., "Transients during 138 kV SF_6 breakers switching of low inductive currents," *Industry Applications Society 38th Annual Petroleum and Chemical Industry Conference*, IEEE, Record of Conference Papers, pp. 65–70, 1991.

[B1241] *IEE Colloquium on Structural Use of Composites in High Voltage Switchgear/Transmission Networks* (Digest no. 223), 1992.

[B1242] IEEE Std C37.123-1991 IEEE Guide to Specification for Gas-Insulated Substation Equipment (ANSI).

[B1243] Kato, K., et al., "Distribution automation systems for high quality power supply," *IEEE Transactions on Power Delivery*, vol. 6, no. 3, pp. 1196–1204, July 1991.

[B1244] Lause, R. E., "In-house procedure rebuilds 765 kV SF_6 circuit breaker bushings at a low cost," *Transmission and Distribution*, vol. 43, no. 11, pp. 76–77, 1991.

[B1245] Linderholm, S., "Capacitance-graded bushings with insulation of oil-impregnated paper," *ASEA Journal*, vol. 54, no. 4, pp. 79–84, 1981.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1246] Miri, A. M.; Schaub, B.; and Zhang, W.; "Dynamic simulation of capacitively graded GIS-bushings on their static potential distribution," *Seventh International Symposium on High Voltage Engineering*, vol. 8, pp. 131–134, 1991.

[B1247] Muhr, M., and Pack, S., "Fast transient overvoltages at a GIS-bushing," *Seventh International Symposium on High Voltage Engineering*, vol. 8, pp. 127–130, 1991.

[B1248] Rishworth, A. B., "Should existing pressure vessel regulations apply to gas filled electrical equipment—An electrical engineer's viewpoint," *IEEE Transactions on Energy Conversion*, vol. 6, no. 2, pp.259–266,1991.

[B1249] Yamagiwa, T.; Kamata, Y.; and Yoshioka, Y.; "Dielectric characteristics of gas-insulated bushings in air under dry and wet conditions," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 2746–2751, June 1981.

6.3 General

6.3.1 Direct current application

[B1250] Allibone, T. E., and Saunderson, J. C., "The measurement of dc voltages up to 1 MV using spheregaps and rod-gaps," *Second International Symposium on Gaseous Dielectrics*, pp. 367–374, Mar. 1980.

[B1251] Aranta, Y., and Shimada, M., "The development of ±500 kV dc SF_6 gas-insulated switchgear," *Mitsubishi Electric, Adv*. (Japan), vol. 29, pp. 10–11, Dec. 1984.

[B1252] Chan, C. C.; Pace, M. O.; and Christophorou, L. G.; "DC breakdown strengths of some multicomponent gas mixtures in concentric cylinder geometries," *Second International Symposium on Gaseous Dielectrics*, pp. 149–159, Mar. 1980.

[B1253] Cooke, C. M., et al., "Compressed gas insulation for advanced HVDC transmission equipment," *International Conference on Large High Voltage Electric Systems*, Paris, France, Sept. 1982.

[B1254] Dale, S. J., "Performance of a technical and economic feasibility study of an HVDC compressed gas-insulated transmission line," Westinghouse Electric Corporation, Trafford, Pa., Final Report, Dec. 1983.

[B1255] Endo, F, et al., "Dielectric characteristics of SF_6 gas for application to HVDC system," *IEEE Transactions on Power Apparatus and Systems*, vol. 99, no. 3, pp. 847–855, May/June 1980.

[B1256] Ewasyshyn, F., and Kuffel, E., "Effect of temperature on direct voltage breakdown characteristics of uniform field and rod-plane gaps in compressed SF6," *IEEE Power Engineering Society Winter Meeting*, Paper A 78 185-1, Jan. 1978.

[B1257] Fischer, F. E.; Glassons, A.; and Hingorani, N. G.; "Gas insulated HVDC converter station," *World Electrotechnical Congress*, June 1977.

[B1258] Fischer, F. E.; Glassons, A.; and Hingorani, N. G.; "HVDC link to test compact terminals," *Electrical World*, pp. 40–42, Feb. 1, 1977.

[B1259] Hazel, R. L. "DC Breakdown and Anode Corona Characteristics of Sphere and Rod-Plane Gaps Insulated With Compressed Sulphur Hexafluorid." Ph.D. diss., University of Windsor, 1974.

[B1260] Hingorani, N. G., et al., "Compact gas insulated HVDC terminals EPRI prototype dc link," *CIGRE*, Paper 14-06, 15 pages, Aug. 1978.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1261] Hirano, T., "Effects of high pressure SF_6 dissolved in an insulating oil in dc conduction currents and ac partial discharges," *Journal of Applied Physics*, vol. 55, no. 1, p. 9, Jan. 1984.

[B1262] Lee, H. H.; Egashira, T.; and Hara, M.; "Improvement of particle-initiated dc flashover characteristics by using electrode and surface shapes in SF_6 gas," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, pp. 529-532, 1992.

[B1263] Lyapin, A. G.; Popkov, V. I.; and Shevtsov, E. N.; "Positive dc point-to-plane dielectric strength of compressed gases," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 169–171, Sept. 1975.

[B1264] Lyapin, A. G.; Popkov, V. I.; and Shevtsov, E. N.; "The range and criterion of similarity of dc corona on hyperboloids against plane in pressurized air and SF_6," *IEE Fourth International Conference on Gas Discharges*, Publication no. 143, pp. 250–252, Sept. 1976.

[B1265] Matsumura, S., et al., "Development of HVDC thyristor valve insulated and cooled by compressed SF_6 gas," *IEEE Power Engineering Society Winter Meeting*, New York, N.Y, Technical Papers, Jan./Feb. 1983.

[B1266] Matsumura, S., et al., "New approach to SF_6 gas insulated HVDC converter station," *IEEE Power Engineering Society Winter Meeting*, New York, N.Y., Technical Papers, Jan./Feb. 1983.

[B1267] Menju, S., and Takahashi, K., "DC dielectric strength of a SF_6 gas insulated system," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 1, pp. 217–224, Jan./Feb. 1978.

[B1268] Miyachi, I., and Naganawa, H., "Spiral arc in SF_6 facilitating dc interruption," *IEE Third International Conference on Gas Discharges*, Publication no. 118, pp. 521–524, Sept. 1974.

[B1269] Nakanishi, K. "High Voltage DC Gas Insulation—A World-Wide Review." In *Gaseous Dielectrics VI*, 1991, pp. 433–448.

[B1270] Nakata, R., "Controlled particle scavenging technique for use in HVDC SF_6 gas bus." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 6, p. 1763, Nov./Dec. 1976. Paper presented at *IEEE Power Engineering Society Summer Meeting*, Paper A 76 410-1, July 1976.

[B1271] Nakata, R., et al., "An underground high voltage direct current transmission line." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 93, no. 4, p. 1011, July/Aug. 1974.

[B1272] Nitta, T., and Nakanishi, K., "Charge accumulation on insulating spacers for HVDC GIS," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 3, pp. 418–427, 1991.

[B1273] Ouyang, M.; Baker, M. A.; and Garrity, T. F; "Novel design concepts of a compressed gas HVDC transmission line," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 7, pp. 2194–2202, July 1982.

[B1274] Ouyang, M.; Carlson, L. E.; and Baker, M. A.; "A ±600 kV HVDC gas insulated transmission line," *Proceedings of the Symposium on Urban Applications of HVDC Power Transmission*, Philadelphia, Pa., pp. 167–183, Oct. 1983.

[B1275] Reddy, C. N., and Paul, P., "Breakdown strength of synthetic solid dielectric immersed in high pressure gaseous mediums and subjected to direct voltages," *IEEE International Symposium on Electrical Insulation*, Publication 78CH1287-2-EI, pp. 172–175, June 1978.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1276] Rizk, F. A. M.; Masetti, C.; and Comsa, R. P; "Particle dynamics and breakdown in SF_6 insulated systems under high direct voltage," *IEEE International Symposium on Electrical Insulation*, Publication 781CH1287-2-El, pp. 146–148, June 1978.

[B1277] Rizk, F. A. M.; Masetti, C.; and Comsa, R. P.; "Particle-initiated breakdown in SF_6 insulated systems under high direct voltage," *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 3, pp. 825–836, May/June 1979.

[B1278] "Technical and economic feasibility study of an HVDC compressed gas insulated transmission line," Final Technical Report, Aluminum Co. of America, Alcoa Center, Pa., Apr. 1985.

[B1279] Van Brunt, R. J.; Hilten, J. S.; and Silver, D. P.; "Partial-discharge pulse height distributions and frequencies for positive and negative dc corona in SF_6 and SF_6-N_2 mixtures," *Second International Symposium on Gaseous Dielectrics*, pp. 303–311, Mar. 1980.

[B1280] Vijh, A. K., "The nature of metal-electrodes/SF_6 reactions in SF_6 decomposition due to direct-current interruption under simulated circuit-breaker condition," *IEEE Transactions on Electrical Insulation*, vol. 2, no. 4, pp. 157–160, Dec. 1976.

6.3.2 Insulation coordination and surge protection

[B1281] Airey, D. R., "Axial and radial heat transport in high temperature SF_6 arc," *Journal of Physics D*., vol. 12, 1979.

[B1282] Albiez, M., and Leijon, M., "PD-measurement in GIS with electrical field sensor and acoustic sensor," *Seventh International Symposium on High Voltage Engineering*, vol. 7, pp. 185–188, 1991.

[B1283] Anderl, H. W.; Wagner, C. L.; and Dodds, T. H.; "Insulation coordination for gas insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. 92, no. 5, pp. 1922–1930, Sept./Oct. 1973.

[B1284] Anderson, D. L., and Spaeren, P., "Insulation co-ordination and experience with metal enclosed SF_6 substations in Norway," A.I.M. International Meeting, 7 pages, Nov. 1979.

[B1285] Anjo, K., et al., "Development of SF_6 gas gap for protection of 500 kV metal-clad switchgears of line entrance," *CIGRE*, Paper 33-01, 8 pages, Aug. 1976.

[B1286] Arakelyan, V. G., and Demina, V. I., "Determining the elementary-gas leakage from electrical-engineering equipment," *Soviet Electrical Engineering*, vol. 63, no. 5, pp. 72–79, 1992.

[B1287] Bernard, G., and Le Roy, G., "Lightning performance of metalclad substations protected by spark-gaps—Part 1: Validation of field tests." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 1, p. 5, Jan./Feb. 1979.

[B1288] Bernard, G., and Le Roy, G., "Lightning performance of metalclad substations protected by spark-gaps—Part 2: Statistical approach and economic criterion," *IEEE Power Engineering Society Summer Meeting*, Paper A79 424-3, 7 pages, July 1979.

[B1289] Boeck, W., and Pettersson, K., "Fundamentals and specific data of metal-enclosed substations for the insulation coordination," *CIGRE*, Paper 23-03, 14 pages, Aug. 1978.

[B1290] Bolin, P. C., et al., "Manufacture and insulation of a three conductor SF_6 insulated transmission line," *IEEE Power Engineering Society Transmission and Distributions Conference and Exposition*, Minneapolis, Minn., Sept. 1981.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1291] Burger, U., "Overvoltage protection for totally enclosed SF_6 switchgear and CGI cables," *Brown Boveri Review*, vol. 61, no. 4, pp. 179–186, Apr. 1974.

[B1292] Camilli, G.; Gordon, G. S.; and Plump, R. E.; "Gaseous insulation for high-voltage transformers," *Transactions of AIEE*, pp. 348–357, Jan. 1952.

[B1293] Carsimamovic, S., and Mahmutcehajic, R., "Computation of very fast transients in 400 kV gas insulated substations caused by disconnector switching," *Sixth Mediterranean Electrotechnical Conference Proceedings, IEEE*, vol. 2, pp. 1416–1420, 1991.

[B1294] Chalmers, I. D., et al. "An Electro Optic Method for Transient Field Measurement in GIS." In *Gaseous Dielectrics VI*, 1991, pp. 587–592.

[B1295] CIGRE, "Lightning protection of stations," TF 33.01.02 Progress Report, *CIGRE SC 33 Colloquium*, 25 pages, June 1975.

[B1296] Cooper, J. H., "A study to determine the basic insulation level requirements for a prototype 1200 kV CGIT cable system," DOE/ET-2061-1, 25 pages, July 1979.

[B1297] Coventry, P. F., and Wilson, A. "Fast Transients in Gas Insulated Substations—An Experimental and Theoretical Evaluation." In *Gaseous Dielectrics VI*, 1991, pp. 503–508.

[B1298] Cronin, J. C.; Colclaser, R. G.; and Lehman, R. F.; "Transient lightning overvoltage protection for a 500 kV gas-insulated substation," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 1, pp. 68–77, Jan./Feb. 1978.

[B1299] Doepken, H. C., Jr., "Gaseous insulation and compressed gas insulated power cables," *Underground Engineering*, vol. 2, no. 2, pp. 21–23, Feb./Mar. 1971.

[B1300] Dwarakanath, K., et al., "Fast transient generator—For studies of insulation materials and systems," *Seventh International Symposium on High Voltage Engineering*, vol. 5, pp. 9–11, 1991.

[B1301] Eriksson, R., et al., "Overvoltage protection and insulation coordination of metal enclosed SF_6 substations," *CIGRE SC 33 Colloquium*, 35 pages, June 1975.

[B1302] Eriksson, R., and Holmborn, H., "Insulation coordination of gas-insulated substations," *International Symposium on Gaseous Dielectrics*, Publication no. CONF-78O301, pp. 314–337, Mar. 1978.

[B1303] Gerhold, J., "Electrical insulation in superconducting power systems," *IEEE Electrical Insulation Magazine*, vol. 8, no. 3, pp. 14–20, May/June 1992.

[B1304] Harris, A. F. W., "Application for composites to high voltage SF_6 switchgear," *IEE Colloquium on Structural Use of Composites in High Voltage Switchgear/Transmission Networks*, Digest no. 223, pp. 5/1–2, 1992.

[B1305] Heinemann, Th., and Vis, P., "Insulation co-ordination with gas insulated metal-clad substations," *A.I.M. International Meeting*, 5 pages, Nov. 1979.

[B1306] Hogg, P., and Schmidt, W., "Adoption of a reduced insulation level for metalclad high-voltage SF_6 switchgear," *CIGRE*, Paper 23-01, 10 pages, Aug. 1978.

[B1307] Ishii, T., et al. "Insulating Characteristics of Small SF_6 Gas Gaps Under Lightning Impulse Voltages." In *Gaseous Dielectrics VI*, 1991, pp. 261–266.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1308] Itaka, K.; Araki, T.; and Hara, T.; "Study on insulation design of compact gas insulated transmission line," *Conference Record of the 1985 International Conference on Properties and Applications of Dielectric Materials*, IEEE, Xian, China, vol. 1, pp. 358–361, June 1985.

[B1309] Kawamura, T., and Ozawa, J. "Insulation Coordination in Gas Insulated Switchgear Against Lightning Overvoltages." In *Gaseous Dielectrics VI*, 1991, pp. 481–488.

[B1310] Kobayashi, T., et al., "Development of compact 500 kV 8000 A gas insulated transmission line—Study on insulation design," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 11, pp. 3154–3164, Nov. 1984.

[B1311] Koepfinger, J. L.; Bacvarov, D.; and Rocamora, R. G.; "The surge protection of an SF_6 gas-insulated substation supplied by pipe-type cables," *IEEE Power Engineering Society Winter Meeting*, Paper F 78 208–1, Jan. 1978.

[B1312] Lamontagne, G.; Do, X. D.; and Mukhedkar, D.; "Lightning performance of a compact substation." Abstract (C75-162-3) in *IEEE Transactions on Power Apparatus and Systems*, vol. 94, no. 4, p. 1100, July/ Aug. 1975.

[B1313] Leijon, M.; Ming, L.; and Hoff, P.; "SF_6 gas pressure influence on acoustical signals generated by partial discharges in GIS," *Seventh International Symposium on High Voltage Engineering*, vol. 7, pp. 197–200, 1991.

[B1314] Masaki, N., et al., "66/77-kV C-GIS using composite insulation in SF_6 gas," *Electrical Engineering in Japan*, vol. 112, no. 2, pp. 58–70, 1992.

[B1315] Matsumura, S., and Nitta, T., "Surge propagation in gas-insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 3047–3054, June 1981. Presented at *IEEE Power Engineering Society Summer Meeting*, Paper SM 658–5, 6 pages, July 1980.

[B1316] Miller, D. B., and Harrison, P. M., "Measurement and modelling of switching transients in gas-insulated transmission lines," *Conference Proceedings, IEEE SOUTHEASCON '87*, Tampa, Fla., vol. 2, pp. 456–460, Apr. 1987.

[B1317] Mitani, M., "Analysis of lightning surge phenomena and examination of insulation coordination in a three-core type gas insulated bus," *IEEE Power Engineering Society Summer Meeting*, Paper A79 401-1, 8 pages, July 1979.

[B1318] Miyagawa, M., et al., "Barrier effect under nonuniform field in atmospheric pressure SF_6 gas," *Electrical Engineering in Japan*, vol. 111, no. 7, pp. 60–67, 1991.

[B1319] Moller, K., "Some remarks on insulation design and co-ordination of gas insulated substations," *A.I.M. International Meeting*, 10 pages, Nov. 1979.

[B1320] Mukaiyama, Y., et al., "Application of fault location system in power substations," *IEEE Transactions on Power Delivery*, vol. 8, no. 1, pp. 48–55, 1993.

[B1321] Murano, M.; Kawaguchi, Y.; and Kojima, S.; "Lightning surge phenomena on electric power system with SF_6 gas-insulated apparatus," *IEEE Transactions on Power Apparatus and Systems*, vol. 91, no. 4, p. 1730, July/Aug. 1972.

[B1322] Nagaoka, N.; Ueno, S.; and Sugahara, K.; "Surge analysis of the tank of a gas-insulated line using lumped constant circuits," *Electrical Engineering in Japan*, vol. 112, no. 5, pp. 78–87, 1992.

[B1323] Niemeyer, L., and Chu, F. Y., "SF_6 and the atmosphere," *IEEE Transactions on Electrical Insulation*, vol. 27, no. 1, pp. 184–187, Feb. 1992.

 Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1324] Nitta, T., et al., "Factors controlling surface flashover in SF_6 gas-insulated systems," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-97, no. 3, pp. 959–968, May 1978.

[B1325] Nojima, K., et al. "Electromagnetic Interference With Control Equipment by GIS Switching Surges." In *Gaseous Dielectrics VI*, 1991, pp. 467–473.

[B1326] Ogi, H., et al., "Fault diagnosis system for GIS using an artificial neural network," *Proceedings of the First International Forum on Applications of Neural Networks to Power Systems*, pp. 112–116, 1991.

[B1327] Oh-Hara, J., et al., "Line entrance protection of 500 kV gas insulated substations by SF_6 spark gaps," *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 6, pp. 2425–2433, Nov./Dec. 1978.

[B1328] Olsen, K., et al., "Lightning overvoltages in SF_6 installations, risk of failures analysis," *CIGRE*, Paper 33–01, 13 pages, Aug. 1978.

[B1329] Osmokrovic, P., et al., "Influence of GIS parameters on the Topler Constant," *IEEE Transactions on Electrical Insulation*, vol. 27, no. 2, pp. 214–220, 1992.

[B1330] Pack, S., "A coaxial transient wave model to simulate very fast transients (in GIS)," *Seventh International Symposium on High Voltage Engineering*, vol. 8, pp. 107–110, 1991.

[B1331] Pettersson, K., et al., "Overvoltage protection of metal-enclosed SF_6 substations considering steep surges," *CIGRE*, Paper 33–05, 10 pages, Aug. 1978.

[B1332] Pfleiderer, R., "A study to investigate the basic switching impulse insulation level requirements for a 1200 kV CGIT cable system," *DOE/ET*, 2061–2, 32 pages, July 1979.

[B1333] Pillai, A., "Sulphur-hexafluoride (SF_6)—Medium for insulation and interruption in HV and EHV applications," *Electrical India*, vol. 19, no. 22, pp. 5–8, Nov. 1979.

[B1334] Popkov, V.I.; Lyapin, A. G.; and Shcherbina, O. V.; "Gas insulated power transmission lines," *Izvestiya Akademii Nauk SSSR, Energetika i Transport* (USSR), no. 1, , pp. 98–106, Jan./Feb. 1973.

[B1335] Rickman, J.; Ryan, H. M.; and Milne, D.; "Performance aspects of solid support insulation in SF_6 high voltage switchgear," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 21–24, 1991.

[B1336] Schramm, H. H., and Trapp, N., "Gas insulated switchgear resistant to internal arcing," *Power Technology International*, pp. 97–99, 1992.

[B1337] Simms, J. R., "Lightning overvoltage protection of SF_6 gas-insulated switchgear," International *Conference on Lightning and Power Systems*, EEI Publication no. 236, June 1984.

[B1338] Suzuki, K.; Saito, S.; and Yoshida, S.; "Power cable insulation," *IEEE Transactions on Electrical Insulation*, vol. El-21, no. 6, pp. 945–952, Dec. 1986.

[B1339] Thiel, H. G., and Rutten, U., "Modelling of a high current arc as energy source in computational fluid dynamics," *Proceedings of the Tenth International Conference on Gas Discharges and Their Applications*, vol. 2, pp. 932–935, 1992.

[B1340] Tranen, J. D., "A probabilistic method for lightning protection of EHV SF_6 substations." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 2, p. 331, Mar./Apr. 1979.

[B1341] Tranen, J. D., et al., "Lightning protection requirements of SF_6 substation determined by hybrid simulator," *American Power Conference*, vol. 39, pp. 1288–1294, 1977.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1342] Wahlstrom, B.; Holmborn, H.; and Schei, A.; "Overvoltage protection of metal enclosed SF_6 substations: Insulation co-ordination philosophy and surge arrester characteristics," *CIGRE*, Paper 33–03, 15 pages, Aug. 1976.

[B1343] Wetzer, J. M.; van Houten, M. A.; and van der Laan, P. C. T. "Prevention of Breakdown Due to Overvoltages Across Interruption of GIS Enclosure." In *Gaseous Dielectrics VI*, 1991, pp. 531–536.

[B1344] Yanabu, S.; Murayama, Y; and Matsumoto, S.; "SF_6 insulation and its application to HV equipment," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 3, pp. 358–366, 1991.

[B1345] Yegorov, A. A., and Syromyatnikov, B. D., "Computer-aided PD-measurements in GIS," *Seventh International Symposium on High Voltage Engineering*, vol. 7, pp. 189–192, 1991.

[B1346] Yoshida, T., et al., "Increase of breakdown voltage due to composite insulation in SF_6 gas," *Electrical Engineering in Japan*, vol. 111, no. 6, pp. 36–46, 1991.

6.3.3 Gas handling and monitoring

[B1347] Aschoff, A. F., and Shoulders, W. E., "Hygrometer best for measuring moisture in SF_6," *Electrical World*, p. 80, Apr. 5, 1965.

[B1348] ASTM D2284-88, Test Method for Acidity of Sulfur Hexafluoride.

[B1349] ASTM D2029-81 (Reaff 1986), Test Methods for Water Vapor Content of Electrical Insulating Gases by Measurement of Dew-Point.

[B1350] ASTM D2472-92, Specification for Sulfur Hexafluoride.

[B1351] Barrault, M. R., "Acoustic and other SF_6 density measurement methods applied to sealed medium voltage equipment," *CIRED 1985*, *Eighth International Conference on Electricity Distribution*, Brighton, England, May 1985.

[B1352] Barrett, S. D., "The A to Z of SF_6," *Electric Light and Power*, pp. 33–41, Dec. 1972.

[B1353] Bell, R., et al., "SF_6 dielectric fill gas gauge," $_{EPRI}$, Final Report EI-747, Project 656-1, 80 pages, Apr. 1978.

[B1354] Boggs, S. A., "Partial discharges in gas-insulated switchgear: Detection using coupling devices," *IEEE*, vol. T-PAS, pp. 3969–3973, Aug. 1981.

[B1355] Chu, E Y., "Procedures for dealing with solid arcing by-products from gas-insulated substations," *Canadian Electric Association*, Final Report 128-T-239, Apr. 1985.

[B1356] Cooke, C. M., "Test electrodes for measuring the intrinsic insulating strength of gases," *Second International Symposium on Gaseous Dielectric*, pp. 323–331, Mar. 1980.

[B1357] Cosgrave, J. A., et al., "Non-invasive optical fibre acoustic monitoring of partial discharges within GIS," *Sixth International Conference on Dielectric Materials, Measurements and Applications*, pp. 274–277, 1992.

[B1358] Dwyer, F. J., and Miners, K. B., "SF_6 gas analysis—An effective means of saving time and money," *Proceedings of the Southeastern Electric Exchange Annual Conference*, Apr. 1982.

[B1359] Gantt, E. D., "Operation and moisture-detection and removal features of SF_6 mobile gas-handling systems," *Doble Client Conference*, sec. 10, pp. 1101–1106, Apr. 1974.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1360] Glander, W. J., "Handling SF_6 arc products in high-voltage equipment," *Doble Client Conference*, sec. 10, pp. 201–203, Apr. 1977.

[B1361] Grill, B., and Wasserstrom, A., "Reclaiming SF_6 gas," *Doble Client Conference*, sec. 10, pp. 201–212, Apr. 1976.

[B1362] IEC376: 1971 Specification and acceptance of new sulphur hexafluoride.

[B1363] IEC376A: 1973 First supplement: Section Thirteen—Mineral oil content.

[B1364] IEC376B: 1974 Second supplement: Clause 26.

[B1365] IEC480: 1974 Guide to the checking of sulphur hexafluoride (SF_6) taken from electrical equipment.

[B1366] Kaminaga, K., et al., "Detection of conductive particles in gas insulated transmission line using acoustic emission sensor," *Proceedings of the 19th Symposium on Electrical Insulating Materials*, Osaka, Japan, pp. 137–140, Sept./Oct. 1986.

[B1367] Leep, D. A., and Van Brunt, R. J., "Safety considerations for handling SF_6 used in electrical equipment," *National Bureau of Standards*, Washington, D.C., NBSIR 80–2063, June 1980.

[B1368] Lutz, F., "Calculation methods of metal enclosed switchgear overpressure due to internal arcs," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 4230–4236, Nov. 1982.

[B1369] Mastrioanni, M. J., "SF_6 analysis of the key to maintenance," *Electrical World*, vol. 194, no. 9, pp. 83–84, Dec. 1980.

[B1370] Mastroianni, M. J., and Jackson, R. B., "SF_6 gas analysis service," *Doble Client Conference*, sec. 10A, pp. 1–7, Apr. 1980.

[B1371] Meier, A.; Ottischnig, R.; and Stolarz, W; "High voltage SF_6-insulated switchgear-gas-monitoring, maintenance and servicing," *Brown Boveri Review*, vol. 59, no. 4, pp. 163–168, Apr. 1972.

[B1372] Miners, K. B., and Mastroianni, M., "SF_6 gas analysis of in-service GIS, results and interpretations," *Proceedings, Workshop on User Experience with GIS*, EPRI, Report EL-2189, Dec. 1981.

[B1373] Okutsu, Naohiro, "Vibrations in metal enclosures of gas-insulated equipment used for fault prediction, pattern recognition methods," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 2733–2739, June 1981.

[B1374] Pankuch, Joseph, "Handling of arc contaminated SF_6 gas in a failed circuit breaker," *Duquesne Light Company Report*, 1975.

[B1375] Pryor, B. M., "Dielectric performance of gas-insulated switchgear and possible methods of on-line monitoring," *IEE Colloquium on Insulating Diagnostics—Methods for Determining Quality, Remnant Life and Proof Testing*, pp. 5/1–5/2, 1991.

[B1376] Sasaki, E. S., and Hartl, J. C., "A solid state gas density monitor for gas-insulated substation equipment," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 7, pp. 1921–1927, July 1982.

[B1377] Schmidt, J. L., and Harper, W. E., "SF_6 gas conditioner/analyzer keeps mini-subs on line longer," *Allis-Chalmers Engineering Review*, vol. 39, no. 2, pp. 8–11, 1974.

[B1378] "SF_6 handler streamlines CB maintenance," *Electrical World*, pp. 60–61, Nov. 1, 1971.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1379] Sverak, J. G., et al., "Safe substation grounding—Part 2," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 10, pp. 4006–4023, Oct. 1982.

[B1380] Tominaga, S., et al., "SF_6 gas analysis techniques and its application of internal conditions in SF_6 gas equipment," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-100, no. 9, pp. 4196–4206, Sept. 1981.

[B1381] Vigreux, J., "Application of condition monitoring techniques in gas insulated substations," *Electra*, no. 134, pp. 46–60, 1991.

[B1382] Yuen, D. C. M., and Chan, S. H., "UHF partial discharge monitoring of 400 kV GIS at Castle Peak substation," *1991 International Conference on Advances in Power System Control, Operation and Management*, IEE, vol. 1, pp. 415–419, 1991.

6.3.4 Grounding

[B1383] Dick, E. P., et al., "Transient ground potential rise in gas-insulated substations—Problem identification and mitigation," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 10, pp. 3610–3619, Oct. 1982.

[B1384] Dodds, T. H., and Spindle, H. E., "Grounding of gas insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. 94, no. 4, pp. 1183–1191, July/Aug. 1975.

[B1385] Ford, G.L., and Boggs, S.A., "Transient high voltages on the ground enclosure of gas-insulated transmission equipment," *Proceedings of the Second International Symposium on Gaseous Dielectrics*, Knoxville, Tenn., pp. 349–358, Mar. 1980.

[B1386] Ford, G. L.; Boggs, S. A.; and Chu, F. Y.; "Transient groundrise in SF_6 substations investigated," *Transmission and Distribution*, vol. 31, no. 8, pp. 46–48, Aug. 1979.

[B1387] Ford, G. L., and Geddes, L. A., "Transient ground potential rise in gas-insulated substations—Assessment of shock hazard," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 10, pp. 3620–3629, Oct. 1982.

[B1388] Fujimoto, N., et al., "Transient ground potential rise in gas-insulated substations–Experimental studies," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 10, pp. 3603–3609, Oct. 1982.

[B1389] Graybill, H. W., "Grounding gas-insulated substations," *Transmission and Distribution*, vol. 27, no. 10, pp. 52–54, Oct. 1975.

[B1390] Harrington, R. J., and El-Faham, M. M., "Proposed methods to reduce transient sheath voltage rise in gas insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-104, no. 5, pp. 1199–1206, May 1985.

[B1391] Kawaguchi, Y.; Sakata, K.; and Menju, S.; "Effect of a grounded cylinder enclosure on the breakdown gradient of rod gaps in SF_6," *IEEE Transactions on Power Apparatus and Systems*, vol. 90, no. 3, pp. 1079–1085, May/June 1971.

[B1392] "Measurement and analysis of switching transients in gas-insulated transmission lines," *EPRI*, Report EL-5145, May 1987.

[B1393] Neilson, J. B., "Energy measurement of transient ground rise pulses," *International Symposium on Gas-Insulated Substations*, Toronto, Canada, Sept. 1985.

[B1394] Sverak, J. G., "Grounding design for safety," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 4281–4390, Sept. 1981.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

6.3.5 Reliability and safety

[B1395] Blanc, J. Y., et al., "Reliability of conception and operation for SF_6-insulated MV equipment," *CIRED*, vol. 1, pp. 1.6/1–6, 1993.

[B1396] Boggs, S. A.; Chu, F. Y.; and Mashikian, M.; "Gas-insulated substation reliability: Present status and future trends," *EPRI*, Final Report EL-4422, Feb. 1986.

[B1397] "Current-transformer safety: Is SF_6 the answer?," *Electrical World*, vol. 205, no. 1, pp. 41–42, 1991.

[B1398] Easterly, C. E., et al., "Health effects of dielectric gases: Preliminary report," *Oak Ridge National Laboratory Report*, TM-8353, Aug. 1982.

[B1399] "Gas-insulated substation reliability: Present status and future trends," *EPRI*, Report EL-4422, Feb. 1986.

[B1400] Graybill, H. W., "Safety and reliability considerations in compact substations," *American Power Conference*, vol. 34, pp. 1053–1056, Apr. 1972.

[B1401] Griffin, G. D., et al. "In Vitro Toxicity Screening of Dielectric Gases Using Mammalian Cells." In *Gaseous Dielectrics III*, edited by L.G. Christophorou, pp. 420–426. Pergamon Press, 1982.

[B1402] Griffin, G. D., et al., "On the toxicity of sparked SF_6," *IEEE Transactions on Electrical Insulation*, vol. EI-18, no. 5, pp. 551–552, Oct. 1983.

[B1403] Griffin, G. D.; Easterly, C. E.; and Walsh, E. J.; "Assessment of potential health effects of dielectric gases," *Second International Symposium on Gaseous Dielectrics*, pp. 439–449, Mar. 1980.

[B1404] Jandrell, I. R.; Reynders, J. P.; and Van Coller, J. M.; "Consideration of the transient skin effects in co-axial systems and an analysis of this effect in various types of conductor," *Seventh International Symposium on High Voltage Engineering*, vol. 8, pp. 143–146, 1991.

[B1405] Laicman, J., and Skoda, F., "The reliability of metal-enclosed substations," *A.I.M. International Meeting*, 4 pages, Nov. 1979.

[B1406] Lester, D., "General considerations on the toxicity of gaseous dielectrics," *AIEE Transactions*, pp. 1183–1185, Dec. 1957.

[B1407] Lester, D., and Greenburg, L. A., "The toxicity of SF_6," *Arch. of Industrial Hygiene, Occupational Medicine*, vol. 2, p. 348, 1950.

[B1408] Lewis, R. J., and Tatken, R. L., "Registry of toxic effects of chemical substances," *National Institute for Occupational Safety and Health Publication*, 1982.

[B1409] Lindsay, C., and Hick, M. A., "Experience with SF_6 gas-insulated substations and proposals for improved reliability," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 9, pp. 2596–2604, Sept. 1984.

[B1410] Merenda, J. J., "Testing and evaluation of chemical hazards under the Toxic Substances Control Act," *Second International Symposium on Gaseous Dielectrics*, pp. 460–466, Mar. 1980.

[B1411] Sasamoto, S., et al., "Manufacturing engineering and reliability improvement for gas-insulated switchgear," *Mitsubishi Denki Giho* (Japan), vol. 57, no. 9, pp. 18–22 (in Japanese), 1983.

[B1412] Sauers, I., et al., "Aspects of environmental effects of dielectric gases," *Second International Symposium on Gaseous Dielectrics*, pp. 429–438, Mar. 1980.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1413] Schels, W., "SF_6 medium-voltage circuit-breaker switchgear reliability improvement through a new gas chamber system," *CIRED*, vol. 1, no. 25, pp. 1.5/1–5, 1993.

[B1414] Specht, H., and Brubach, F., "Inhalation of sulphur hexafluoride," *Science*, vol. 114, p. 662, 1951.

[B1415] Swindler, D. L., "A comparison of vacuum and SF_6 technologies at 5 kV through 38kV," *Industrial and Commercial Power Systems Technical Conference 1984*, Atlanta, Ga., Conference Record (New York: IEEE), pp. 116–122, May 1984. Also published in *Record of Conference Papers, 30th Annual Petroleum and Chemical Industry Conference*, Denver, Colo. (New York: IEEE), pp. 205–212, Sept. 1983. Also published in *EEE Transactions on Industrial Applications*, vol. IA-20, no. 5, pp. 1355–1363, Sept./Oct. 1981.

[B1416] Teresaka, K., et al., "Reliability test for 500 kV GIS," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 7, pp. 2292–2299, July 1982.

[B1417] Theoret, A., and Gilbert, R., "Occupational hazards and other problems relating to the use of SF_6 in metalclad substations," *Canadian Electrical Engineering Journal*, vol. 4, pp. 24–28, 1976.

[B1418] Trochimowica, H. J., "The toxicology of certain gaseous fluorocarbons," *Second International Symposium on Gaseous Dielectrics*, pp. 450–459, Mar. 1980.

[B1419] Ushio, T., et al., "Reliability assurance of 550 kV gas insulated switchgear," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 410–413, Mar. 1978.

[B1420] Van Roggen, A.; Pugh, P. F.; and Brand, K. P.; "On the toxicity of SF_6-insulating gas," *IEEE Transactions on Electrical Insulation*, vol. EI-18, p. 93, 1983.

[B1421] Veda, T., et al., "Investigation on the reliability of large interrupting capacity SF_6 gas-circuit breakers with few breaks," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-104, no. 1, pp. 143–149, Jan. 1985.

[B1422] Wock, S., "Discussion: On the toxicity of SF_6-insulating gas," *IEEE Transactions on Electrical Insulation*, vol. EI-19, Apr. 1984.

[B1423] Yamamoto, M., et al., "New short-circuit testing facilities to cope with the recent development of GIS," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-104, no. 1, pp. 150–156, Jan. 1985.

6.3.6 Testing and maintenance

[B1424] Bellaschi, P. L., "Introduction to the symposium on the design of SF_6 substations for field testing and maintenance," *Doble Client Conference*, sec. 5, pp. 901A–911A, Apr. 1975.

[B1425] Boeck, W., and Frohlich, K., "GIS disconnector testing," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 9–12, 1991.

[B1426] Boersma, R., "An approach to testing at site and expansion of maintenance of metal enclosed switchgear," *A.I.M. International Meeting*, 6 pages, Nov. 1979.

[B1427] Boggs, S. A., "Resonant surge test for SF_6 switchgear," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 1881–1884, Apr. 1981.

[B1428] Boggs, S. A., "SF_6 field acceptance tests—A utility view," *Transmission and Distribution*, vol. 29, no. 8, pp. 24–26, 56–57, Aug. 1977.

[B1429] Boggs, S. A., et al., "Fault and partial discharge location systems for gas-insulated transmission lines," *EPRI*, Final Report EL-3313, Dec. 1983.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1430] Boggs, S. A.; Chu, F. Y.; and Ford, G. L.; "Improved fault location for gas insulated switchgear," *Transmission and Distribution*, vol. 32, no. 7, pp. 32, 34–37, July 1980.

[B1431] Boggs, S. A.; Ford, G. L.; and Chu, F. Y.; "Partial discharge location in gas-insulated switchgear," *Second International Symposium on Gaseous Dielectrics*, pp. 358–366, Mar. 1980.

[B1432] Boggs, S. A.; Ford, G. L.; and Harvey, S. M.; "Applications of high technology electronics to testing and operating of gas-insulated substations," *Proceedings of the 15th Electrical/Electronics Insulation Conference*, Chicago, Ill., Conference Paper, pp. 294–297, Oct. 1981.

[B1433] Boggs, S. A., and Kirby, P., "A resonant surge field test for SF_6 switchgear," *IEEE Power Engineering Society Summer Meeting*, Paper 80 SM 536-3, July 1979.

[B1434] Bolin, P. C., and Hopkins, M. D., "Constraints on fault repair of GIS," *Proceedings of International Symposium on Gas-Insulated Substations*, Toronto, Canada, Sept. 1985.

[B1435] Brand, U., and Amsinck, R., "High voltage test equipment and systems for on-site testing," *Certif. Eng*., vol. 57, no. 11, pp. 195–200, Nov. 1984.

[B1436] Brano, U., "Power frequency testing of GIS with SF_6 insulated testing transformer," *A.I.A. International Meeting*, 5 pages, Nov. 1979.

[B1437] Braun, J. M., and Chu, F. Y., "Novel low-cost SF_6 arcing by-product detectors for field use in GIS," *IEEE Power Engineering Society Summer Power Meeting*, Vancouver, B.C., Canada, Conference Paper 85 SM369-4, July 1985.

[B1438] Carlson, G. J., et al., "Fault sensors in SF_6 equipment," *Proceedings of the American Power Conference*, Chicago, Ill., vol. 42, pp. 615–619, Apr. 21–23, 1980.

[B1439] "Code of Practice for the Maintenance of Electrical Switchgear for Voltages Up to and Including 145 kV," British Standards Institution, no. BS5405, pp. 26–31, 1976.

[B1440] Cooper, J. H.; South, W. H.; and Shimshock, J. F.; "Field test experience and diagnostic techniques on 1200 kV GIS components," *CIGRE*, Paper 23-07, 1984.

[B1441] Cronin, J. C., "Experience in design and testing of gas-insulated systems," *International Symposium on Gaseous Dielectrics*, no. CONF-780301, pp. 116–137, Mar. 1978.

[B1442] Cronin, J. C., et al., "Optimization of single conductor gas-insulated transmission system." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 97, no. 4, p. 1010, July/Aug. 1978.

[B1443] de la Rosa, R., et al., "Experiences on short circuit synthetic testing techniques in Mexico," *Third Biennial Symposium on Industrial Electric Power Applications*, pp. 157–164, 1992.

[B1444] Diebold, G., and McFadden, D., "Noise reduction in EPRI discharge flow studies," *Rev. Sci. Instrum.*, vol. 50, p. 157, 1979.

[B1445] Diessner, A., and Luxa, G., "High-voltage testing of SF_6 insulated substations at site," *A.I.M. International Meeting*, 7 pages, Nov. 1979.

[B1446] "Discussion of papers presented at the symposium on the design of SF_6 substations for field testing and maintenance," *Doble Client Conference*, sec. 5, pp. 901G–908G, Apr. 1975.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1447] Doin, Y., et al., "The control of humidity in GIS—Quality control aspect," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 125–128, 1991.

[B1448] Duda, M. P., and McDermid, W. M., "Site insulation tests on a 230 kV SF_6 gas insulated substation," *Doble Client Conference*, sec. 9, pp. 201–218, Apr. 1979.

[B1449] Erni, H., and Wetzel, R., "Testing facilities for high-voltage equipment at the Oerlikon Works in Zurich," *Brown Boveri Review*, vol. 64, no. 5, pp. 314–318, May 1977.

[B1450] Ferguson, M. L., "Doble testing procedures for SF_6 breakers in gas-insulated and conventional substations," *Doble Client Conference*, sec. 5, pp. 501–515, Apr. 1978.

[B1451] Ferguson, M. L., "Testing of 800 kV SF_6 gas circuit breaker," *Doble Client Conference*, sec. 5, pp. 301–310, Apr. 1980.

[B1452] Feser, K., "High voltage testing of metal-enclosed gas-insulated substations on-site with oscillating switching impulse voltages," *Second International Symposium on Gaseous Dielectric*, pp. 332–340, Mar. 1980. Also presented at *A.I.M. International Meeting*, 7 pages, Nov. 1979.

[B1453] Feser, K., "On site high voltage testing of SF_6 installations with oscillating switching impulse voltages," Translated from *Bulletin ASE*, 8 pages, 1977.

[B1454] Feser, K., "On-site testing of SF_6 insulated substations," *Transactions of the South African Institute of Electrical Engineering*, vol. 72, pt. 2, pp. 39–41, Feb. 1981.

[B1455] Feser, K., et al., "On-site dielectric testing of GIS: Theoretical and practical considerations," *IEEE Transactions on Power Delivery*, vol. 6, no. 2, pp. 615–625, 1991.

[B1456] Garrity, T. F., and Vora, J. P., "The future testing needs of gas-insulated substations," *Second International Symposium on Gaseous Dielectrics*, pp. 389–399, Mar. 1980.

[B1457] Gayet, P., et al., "Research into a voltage test procedure for site testing of metalclad substations with maximum efficiency," *CIGRE*, Paper 23–05, 1984.

[B1458] Graybill, H. W., "Dielectric testing of gas-insulated substations," *Doble Client Conference*, sec. 5, pp. 901C–909C, Apr. 1975.

[B1459] Graybill, H. W.; Cronin, J. C.; and Field, E. J.; "Testing of gas insulated substations and transmission systems," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-93, no. 1, pp. 404–413, Jan./Feb. 1974.

[B1460] Hadore, P., and Hux, G., "Maintenance concept for Sprecher Energie SF_6 gas-insulated circuit breakers," *Sprecher Energie Review*, no. 1, pp. 18–19, 1992.

[B1461] Harper, W. E., "Gas insulated subs can be maintained on line," *Electric Light and Power*, pp. 36–37, Aug. 25, 1975.

[B1462] Harper, W. E., "On-line maintenance of compact substations," *American Power Conference*, vol. 39, pp. 1148–1156, Apr. 1975.

[B1463] Hauschild, W., et al., "Selection of the time parameters of oscillating impulse voltages for on-site testing of gas-insulated switchgear (GIS)," *Plasma Phys.* (Germany), vol. 25, no. 4, pp. 329–335, 1985.

 Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1464] Haznadar, Z.; Carsimamovic, S.; and Mahmutcehajic, R.; "More accurate modeling of gas insulated substation components in digital simulations of very fast electromagnetic transients," *1991 Power Industry Computer Application Conference Papers*, IEEE, pp. 260–267, 1991.

[B1465] Headley, P., "Testing requirements for composite insulators for HV switchgear," *IEE Colloquium on Structural Use of Composites in High Voltage Switchgear/Transmission Networks*, Digest no. 223, pp. 4/1–4/5, 1992.

[B1466] IEEE Substations Committee, "Partial discharge testing of gas insulated substations," *IEEE Transactions on Power Delivery*, vol. 7, no. 2, pp. 499–506, 1992.

[B1467] Konig, D., et al., "Partial discharge measurements of SF_6 insulated HV metal-enclosed switchgear on site: A study based on fundamentals and experiences available up to now," *CIGRE*, Paper 23–09, 17 pages, Aug. 1980.

[B1468] Kopejtkova, D., "Voltage testing of encased VHV switchboards with SF_6 insulation on site after mounting," *Electrotechnichy Obzor* (Czechoslovakia), vol. 73, no. 3, pp. 152–159, Mar. 1984.

[B1469] Krenicky, A.; Stelzer, R.; and Zeller, N.; "Maintenance of gas-insulated, high-voltage switchgear and SF_6 outdoor circuit breaker," *Brown Boveri Review*, vol. 67, pp. 244–250, Apr. 1980.

[B1470] Kugler, R.; Luehrmann, H. M.; and Veuhoff, F.; "Switching tests on grounding switches for gas-insulated substations," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-103, no. 12, pp. 3569–3572, Dec. 1984.

[B1471] Kurosawa, K., et al., "Diagnostic technique for electrical power equipment using fluorescent fiber," *Proceedings of the International Society for Optical Engineering*, vol. 1368, pp. 150–156, 1991.

[B1472] Kusumoto, S., et al., "Diagnostic technique of gas-insulated substation by partial discharge detection," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-99, no. 4, pp. 1456–1465, July/Aug. 1980.

[B1473] Kuwahara, H., et al., "Implications of long-term field testing of gas-insulated equipment," *Second International Symposium on Gaseous Dielectrics*, pp. 341–348, Mar. 1980.

[B1474] Kuwahara, H., et al., "Internal inspection and maintenance of gas-insulated switchgear in the field," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 843–851, Apr. 1983.

[B1475] Larrue, H., "Work conditions for maintenance, repairs and extension of metalclad SF_6 insulated substations," *CIGRE*, Electra, no. 69, pp. 33–41, Mar. 1980.

[B1476] Leibold, A. A., "Testing, protection, and maintenance of gas-insulated substations (GIS)," *Doble Client Conference*, sec. 5, pp. 901D–912D, Apr. 1975.

[B1477] Lockyer, G. D., "Cleanup of SF_6 gaseous by-products," *EPRI*, Final Report EL80-8-LD, 1980.

[B1478] Mastroianni, M., "SF_6 analysis is the key to maintenance," *Electrical World*, Dec. 1980.

[B1479] Milligan, R. E., and Nilsson, S., "Digital fault data acquisition and recording in substations," *Control of Power Systems Conference and Exposition*, IEEE, College Station, Tex., p. 154, Mar. 1977.

[B1480] Moeller, J., "Metal-clad test transformer for SF_6 insulated switchgear," *International High Voltage Symposium*, pp. 161–165, Sept. 1975.

[B1481] Morri, K., et al., "Environmental improvements of recent substations and their technical aspects," *CIGRE*, Paper 23–06, 12 pages, Aug. 1980.

[B1482] Muller, H. G., "Testing of metal enclosed HV substations," *CIGRE*, Electra, no. 42, pp. 7–29, Oct. 1975.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

[B1483] Nakamura, E., et al., "Development of fault section detecting system for gas insulated transmission lines," *IEEE Transactions on Power Delivery*, vol. PWRD-1, no. 1, pp. 19–26, Jan. 1986.

[B1484] Nannery, P. R., and Matulic, R., "Testing and maintenance of SF_6 gas-insulated substations and transmission lines," *Doble Client Conference*, sec. 9, pp. 601–615, Apr. 1976.

[B1485] Nigol, O., "Location of leaks in gas filled underground cables," *IEEE Transactions on Power Apparatus and Systems*, vol. 89, no. 7, pp. 1440–1443, Sept./Oct. 1970.

[B1486] "Overpotential testing of gas-insulated substations," *Doble Client Conference*, sec. 9, pp. 701–703, Apr. 1975.

[B1487] Patrunky, H., and Olsen, W., "Service experience and maintenance procedures," *International Symposium on Gas-Insulated Substations*, Toronto, Canada, Sept. 1985.

[B1488] Pearson, J. S.; Hampton, B. F.; and Sellars, A. G.; "A continuous UHF monitor for gas-insulated substations," *IEEE Transactions on Electrical Insulation*, vol. 26, no. 3, pp. 469–478, June 1991.

[B1489] Perry, M. P., "Fault location in gas insulated conductors using magnetic sensors," *IEEE Transactions on Power Apparatus and Systems*, vol. 99, no. 3, pp. 1543–1547, May/June 1980.

[B1490] Petersen, C. H.; Brand, U.; and Leibold, A. A.; "Power frequency field testing of gas-insulated substations." Abstract in *IEEE Transactions on Power Apparatus and Systems*, vol. 95, no. 6, p. 1759, Nov./Dec. 1976.

[B1491] Pigini, A., et al.; "Influence of the test conditions and procedure of the dielectric strength of SF_6 Configurations," *A.I.M. International Meeting*, 7 pages, Nov. 1979.

[B1492] "Record of Conference Papers," *Industry Applications Society 38th Annual Petroleum and Chemical Industry Conference*, IEEE, 1991.

[B1493] Reid, R., "Field testing of 345 kV gas-insulated substation," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 2689–2694, May 1981.

[B1494] Reid, R.; Scaturro, A. J.; and Wilkes, R. B.; "Experience with field testing of Consolidated Edison 49th Street 345 kV gas-insulated substation," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 2689–2694, May 1981.

[B1495] Reid, R.; Scaturro, A. J.; and Wilkes, R. B.; "Experiences with field testing of Consolidated Edison 49th Street metal clad SF_6 insulated switching station," *IEEE Power Engineering Society Winter Meeting*, Paper F 79 191-8, 5 pages, Jan. 1979.

[B1496] Rickley, A. L., and Osborne, S. H., Jr., "HVB puffer-type SF_6 circuit breakers (Doble Test Procedures)," *Doble Client Conference*, sec. 5, pp. 401–405, Apr. 1980.

[B1497] Rizzetto, S.; Fujimoto, N.; and Stone, G. C.; "System for the detection and location of partial discharges using x-rays," *Conference Record of the IEEE International Symposium on Electrical Insulation*, Cambridge, Mass., pp. 262–266, June 1988.

[B1498] Rollo, J. T., and Swan, G. A. H., "Operational, safety, site testing and maintenance requirements for HV, SF_6 metalclad switchgear," *CIGRE*, Paper no. 23–01, 8 pages, Aug. 1974.

[B1499] Rosskopf, Th. V., "Testing and measuring of HV metal enclosed substations at site," *A.I.M. International Meeting*, 7 pages, Nov. 1979.

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1500] Ryan, H. M.; Milne, D.; and Powell, C. W.; "Site testing and the evaluation of a technique to differentiate between a gas or spacer flashover in SF_6 GIS," *Proceedings of the International Symposium on Gas-Insulated Substations*, Sept. 1984.

[B1501] Sasaki, E. W., and Hartl, J. C., "A solid state gas density monitor for gas-insulated substation equipment," *IEEE Transactions on Power Apparatus and Systems*, vol. PAS-101, no. 7, pp. 1921–1927, July 1982.

[B1502] Schmidt, W.; Hogg, P.; and Eidinger, A.; "On site high voltage testing of SF_6 metalclad switchgear installations and compressed gas insulated cable," *Brown Boveri Review*, vol. 64, pp. 656–661, Nov. 1977.

[B1503] "Servicing gas insulated bus made easy with new technique," *Electric Light and Power*, pp. 42–44, Feb. 1979.

[B1504] "SoCal Edison recommends max testing of gas-insulated mini-sub components," *Electric Light and Power*, p. 31, Feb. 1978.

[B1505] Spindle, H. E., "Maintenance of gas-insulated substations," *American Power Conference*, vol. 34, pp. 1047–1052, Apr. 1972.

[B1506] Swoish, R. F., "Testing CGI equipment 69 kV and above," *American Power Conference*, vol. 34, pp. 1047–1052, Apr. 1972.

[B1507] Tominaga, S., "Short line fault tests on 245 kV/40kA puffer-type gas circuit breaker by direct and synthetic test methods," *IEEE Transactions on Power Apparatus and Systems*, vol. T-PAS, pp. 563–571, Feb. 1981.

[B1508] Tominaga, S., et al., "Dynamic behavior of metal enclosure for gas insulated substations during ground faults and their immediate location by mechanical means," *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 4, pp. 1283–1290, July/Aug. 1979.

[B1509] "Ultra high voltage gas cable undergoes tests," *Modern Power Systems* (U.S.), vol. 2, no. 8, pp. 77, 79, Sept. 1982.

[B1510] Vertikov, V. P., and Kuleshov, V. A., "A technology of diagnosing and monitoring SF_6 insulation in a high-voltage GIS," *Proceedings of the Third International Conference on Properties and Applications of Dielectric Materials*, IEEE, vol. 1, pp. 533–537, 1991.

[B1511] Vieira, C. S., et al. "The Application of Infrared Absorption Spectroscopy in Gas-Insulated Equipment Diagnostics." In *Gaseous Dielectrics VI*, 1991, pp. 539–544.

[B1512] Vishnevskii, Y. I.; Arshanskii, I. Sh.; and Syromyatnikov, B. D.; "Sealed high-voltage units with SF^6 insulation for high-voltage testing of factory assembled switchgear with measurement of characteristics of partial discharges," *Soviet Electrical Engineering*, vol. 62, no. 11, pp. 48–51, 1991.

[B1513] Vishnevsky, Y. I., et al., "GIS high-voltage test procedures with partial discharge measurements," *Seventh International Symposium on High Voltage Engineering*, vol. 3, pp. 37–40, 1991.

[B1514] Vostracky, Z., "Type tests of the switching ability of new SF_6 circuit breaker, type VSV 420.k.p. SKODA Plzen, in the short-circuit station VUSE Praha-Bechovice, Asiatic," *Electrotechnichy Obzor*, vol. 73, no. 12, pp. 682–688, Dec. 1984.

[B1515] Wieseler, D. L., "Optimize moisture tests for gas circuit breakers," *Electrical World*, pp. 25–27, Oct. 30, 1967.

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

[B1516] Wittle, J. K., et al., "Fault detection sensors for gas-insulated equipment," *EPRI*, Report no. EL-2249, Feb. 1982.

[B1517] Yamagiwa, T., et al., "Development of preventive maintenance system for highly reliable gas insulated switchgear," *IEEE Transactions on Power Delivery*, vol. 6, no. 2, pp. 840–848, 1991.

[B1518] Young, C. P., "Maintenance experiences with Westinghouse type SF_6 gas insulated hot tank circuit breakers," *Doble Client Conference*, sec. 5, pp. 501–510, Apr. 1980.

6.4 Index of authors

-A-	[B] Entry Number
Abbott, P. M.	1
Abdel-Salam, M.	152, 347
Abdel-Salem, A.	48
Abdellah, M.	257
Abell, D. S.	858,917
Abul-Shohoud, W.	48
Afzelius, R. W.	348
Agostino, R.	49
Aguilar, J.	563
Ahearn, A. J.	466
Airey, D. R.	1,50,51,52,53,54,918,1281
Akbar, M.	153
Aked, A.	229
Akimov, V. V.	1054
Akiyama, H.	2,467
Aksenov, Yu P.	405
Albiez, M.	1282
Alden, L.	1200
Alexander, R. W.	671
Ali, K.	152
Allaart, A. J.	564,919
Allibone, T. E.	1250
Amalric, J.	406,407
Amato, J. V.	951
Amsinck, R.	1435
Anderl, H. W.	1042,1283

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Anderson, D. L. 1284
Anderson, W. E. 329
Ando, N. 827,843
Anis, H. 154,155,156,252,253,315,349,388,881
Anjo, K. 1285
Antonov, A. V. 157
Aoki, N. 408
Aoki, T 605,1211
Aoshima, Y. 323
Arai, K. 217
Arakelyan, V. G. 1286
Araki, H. 23
Araki, T 753,754,813,1308
Aranta, Y. 1251
Ardito, A. 1239
Arkell, C. A. 1189
Arnesen, A. 129,294,295
Arnesson, I. 1200
Arrighi, R. 859
Arshanskii, L. Sh. 1512
Arvay, G. J. 566
Aschoff, A. F. 1347
Ashbaugh, P G. 56
Azer, A. A. 158
Azumi, K. 567

-B-

Babcock, L. M. 58
Bachmaier, A. 920
Bachmann, B. 672
Bacvarov, D. 1311
Baer, G. P. 860,861
Bahder, G. 862
Baker, A. 59
Baker, A. E. 458
Baker, M. A. 1273,1274
Bakos, J. S. 155

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Baldo, G.	469
Baliga, B. J.	1229
Banks, A. D. J.	943
Barber, J. C.	921
Bargigia, A.	409,470,568,922
Baron, B.	3
Barrault, M. R.	1351
Barrett, S. D.	1352
Bartakova, B.	1055
Bates, G.	946
Bauer, A. W.	471
Baumgartner, R. G.	159,472,473
al-Bawy, I.	160,194,1056,1078
Beaty, E.	60
Becher, W.	474
Beehler, J. E.	569
Beer, H.	570,571,1117
Belanger, B. C.	755
Bell, R.	1353
Bell, W. R.	262
Bellaschi, P. L.	1424
Belmadani, B.	410, 411
Beloedova, I. P.	1176
Benes, O.	1118
Benson, S. W.	412
Berg, D.	161, 213
Berger, G.	923
Berger, S.	350, 351
Bergqvist, H. W.	348
Beringhaus, C. W.	699
Berkebile, L. E.	924, 925
Bernard, G.	61, 952, 1287, 1288
Bernstein, H. J.	555
Beroual, A.	926, 927
Bhalla, M. S.	62
Bigelow, E. C.	993

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Binns, D. F.	63, 64, 65, 162, 1057
Blackburn, T. R.	163, 164, 286, 1058
Blahous, T.	1119
Blair, D. T. A.	66, 67
Blanc, J. Y.	1395
Blower, R. W.	1201
Bobikov, V. E.	1059
Bobo, J. C.	1060
Boeck, W.	475, 572, 1289, 1425
Boersma, R.	573, 1426
Boeuf, J. R.	68
Boggs, S. A.	4, 7, 8, 165, 476, 801, 1120, 1121, 1202, 1354, 1385, 1386, 1396, 1427, 1428, 1429, 1430, 1431, 1432, 1433
Bogner, A.	920
Bohme, H.	518
Bolin, P. C.	736, 756, 757, 834, 863, 1290, 1434
Bolton, A. C.	618
Bondon, L. A.	758
Borin, V. N.	5, 6, 574
Bortnik, I. M.	69, 166, 575, 759
Boswell, R. W.	1058
Bott, J. E.	70, 412
Boudene, C.	413
Boulloud, A.	106
Boyd, H. A.	71, 167
Brah, D. B.	1045
Brand, K. P.	352, 1420
Brand, U.	1435, 1490
Brandt, T. F.	1061
Brano, U.	1436
Branston, D. W.	144
Braun, D.	928
Braun, J. M.	168, 183, 317, 1062, 1063, 1069, 1081, 1122, 1437
Brechtken, D.	477
Breisacher, R.	135
Brengsbo, E.	279

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Brockman, R. 1064
Broschk, H. O. 929
Brown, G. W. 353, 414
Browne, F. 238
Browne, T. E., Jr. 72, 109, 110, 138
Brubach, F. 1414
Bruno, G. 415
Buchsbaum, J. A. 700
Buck, K. E. 576
Bui, A. 169
Buret, F. 926, 927
Burger, U. 1178, 1291

-C-

Calvino, B. J. 930, 931
Camarero, R. 1031
Camilli, G. 73, 74, 1046, 1154, 1292
Campbell, L. C. 932, 1231
Capezzuot, P. 415
Cappel, R. J. 699
Carlson, G. J. 836, 1438
Carlson, G. L. 1047, 1190
Carlson, L. E. 1274
Carsimamovic, S. 1293, 1464
Carter, S. L. 933
Casanovas, A. M. 411
Casanovas, J. 411
Castelli, D. 577
Castonguay, J. 75, 170, 171, 172, 442
Centurioni, L. 173
Chakrabarti, A. K. 174, 333, 416
Chalmers, I. D. 76, 175, 289, 417, 1114, 1294
Chalmers, P. 83
Chan, C. C. 531, 532, 1252
Chan, L. 1155
Chan, S. H. 1382
Chantry, P. J. 148, 478

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Chapman, A.	934
Chapman, J. J.	73
Charrier, J.	106
Chatterton, P. A.	209
Chee-Hing, D. J.	176, 1065
Chen, C. L.	478
Chenoweth, T. E.	1066
Cherneera, L. I.	77
Cherukupalli, S. E.	1067
Chierichetti, C.	577
Cho, Y. O.	1068
Choi, B. J.	1068
Christophorou, L. G.	78, 134, 183, 215, 276, 329, 384, 420, 421, 429, 439, 446, 454, 455, 462, 479, 480, 481, 511, 526, 531, 532, 542, 544, 1132, 1252, 1401
Chu, F. Y.	7, 8, 177, 178, 179, 180, 181, 182, 183, 317, 418, 419, 420, 482, 483, 674, 675, 676, 1063, 1069, 1121, 1323, 1355, 1386, 1396, 1430, 1431, 1437
Clark, T. F.	677, 691
Cohen, E. H.	9
Colclaser, R. G.	1298
Collier, R. T.	678, 679
Compton, R. N.	80
Comsa, R. P.	158, 1276, 1277
Conangla, A.	772
Cook, G. H.	1057
Cooke, C. M.	69, 81, 235, 354, 355, 356, 357, 358, 824, 856, 1070, 1071, 1253, 1356
Cookson, A. H.	10, 81, 184, 185, 186, 187, 188, 244, 358, 359, 360, 361, 362, 363, 364, 365, 366, 369, 403, 484, 761, 762, 763, 764, 765, 766, 767, 798, 865, 1066, 1113
Cooper, C. D.	80
Cooper, E. A.	680
Cooper, J. H.	1296, 1440
Corbett, J. T.	768
Cosgrave, J. A.	485, 1357
Coufal, O.	11
Coventry, P	1297
Craggs, J. D.	62, 82, 249
Cramarossa, F.	415
Crichton, B. H.	83, 367, 486

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Crichton, G. C. 71, 167

Cronin, J. C. 12, 353, 414, 769, 770, 771, 772, 773, 774, 819, 835, 866, 883, 1100, 1298, 1441, 1442, 1459

Crouch, A. G. 1072

Crucius, M. 1073

Cuk, N. 582

Czech, F. 775

-D-

Daimon, G. 609

Dakin, T. W. 421, 1074, 1203

Dale, S. J. 13, 188, 195, 196, 342, 368, 369, 557, 776, 777, 778, 779, 1075, 1254

Dallachy, J. L. 932

Daragan, C. L. 63

Dauby, B. 935

Davidson, J. C. 84, 487

de Heus, A. A. 583

de la Rosa, R. 1443

de Metz-Noblat, B. 1076

De Tourrell, C. H. 854, 1077

Deakin, T. W. 343

Delsing, R. 573

DeMaris, S. 867

Demina, V. I. 1286

Deschamps, L. 780

DeSteese, J. G. 782

Dethlefsen, R. 773

Diaz, R. R. 469

Dick, E. P. 1383

Diebold, G. 1444

Diessner, A. 14, 370, 860, 1445

Dincer, M. S. 15, 85

Dirks, R. 937, 1123

Do, X. D. 1312

Dobsa, J. 791

Doctor, S. R. 105

Dodds, J. J. 189, 938, 1156

 Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Dodds, T. H. 584, 1283, 1384
Doepken, H. C., Jr. 371, 783, 784, 785, 786, 787, 788, 817, 834, 873, 899, 1299
Doin, Y 1076, 1447
Dolezal, M. 939
Dominelli, N. 422
Doughty, F. E. 679
Dubanton, C. 16
Duda, M. P. 1448
Dudukovic, P. R. 86
Dufournet, D. 940, 941
Dunz, Th. 190
Duplay, C. 1204
Dutton, J. 60, 87, 88, 191, 489
Dwarakanath, K. 1300
Dwyer, F. J. 1358

-E-

Easterly, C. E. 1398, 1403
Ecknig, W 1207
Edelson, D. 89, 423, 424
Egashira, T. 211, 1262
Eibech, R. E. 425
Eidinger, A. 789, 790, 791, 792, 793, 794, 1502
El-Faham, M. M. 595, 1390
Elkins, D. L. 1240
Emanuel, A. E. 899
Emery, F. T. 403, 1112, 1113
Endo, F. 1255
Englander-Golden, P. 128
Eriksson, R. 949, 1301, 1302
Erme, M. 90
Erni, H. 1449
Eteiba, M. 372
Everson, D. 942
Ewasyshyn, F. 1256

-F-

Fang, M. T. C. 943, 1001

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Farish, O.	160, 193, 194, 195, 196, 216, 308, 361, 362, 363, 364, 367, 382, 487, 503, 1056, 1078, 1114
Farouk, A. M.	1079
Fehsenfeld, F. C.	91
Feldman, E. V.	464, 558
Felici, N.	493
Fellmann, K. H.	1124
Felsenthal, P.	197
Ferguson, M. L.	1450, 1451
Fernandes, V. R.	705
Fernandez, J. H.	563
Ferschl, L.	944
Feser, K.	297, 1125, 1452, 1453, 1454, 1455
Fidler, A.	11
Field, E. J.	1459
Finer, E. G.	92
Fischer, A.	45
Fischer, F. E.	682, 796, 897, 1257, 1258
Fischer, T. N., Jr.	426, 683
Fisher, F. A.	1047
Fisher, W. H.	797, 798, 799
Fitzgerald, J. P.	868
Flamm, D. L.	49
Fleming, S. P.	377
Floessel, C. D.	775, 792, 793
Floessel, K.	890
Flugum, R. W.	585
Foord, T. R.	198
Ford, G. L.	181, 674, 1202, 1385, 1386, 1387, 1430, 1431, 1432
Fox, W. B.	545,546
Franca, W. J.	800
Frantz, R. A.	684
Freeman, J. J.	1092
Frees, L. C.	199
Friedrich, A. E.	983
Friedrich, R. E.	586, 945, 946, 1205

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Frind, G. 947, 948
Frohlich, K. 949, 1425
Frost, L. S. 30, 31, 93, 126, 200, 1003, 1004
Frowein, E. A. 587
Fruth, B. 527
Fujimoto, N. 4,476, 801, 1080, 1081, 1121, 1388, 1497
Fujimoto, T. 588
Fujinami, H. 47,201
Fujiwara, Y. 27, 149, 272
Fukuda, S. 94, 202, 802, 803, 804

-G-

Gabris, F. 209
Gacek, Z. 3,900
Gaigg, W. 665
Galloway, S. J. 1189
Ganger, E. B. 373, 374, 494
Gantt, E. D. 1359
Garbar, E.D. 495, 496
Garrity, T. F. 124, 585, 589, 685, 755, 764, 1040, 1273, 1456
Garzon, R. D. 95, 950, 951
Gaupp, O. 1018
Gayet, P. 1457
Geary, E. F. 869
Geddes, L. A. 1387
Geitel, K. 590
George, D. W. 203
Gerhold, J. 1303
Gervais, Y. 274
Giesselmann, G. 204
Giessner, B. G. 1082, 1083
Gilbert, R. 75, 172, 1417
Gillies, D. A. 806
Gilmozzi, G. 591
Ginno, M. 205
Girard, A. 952
Girgis, R.S. 1158

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Glander, W. J.	1360
Glassons, A.	1257, 1258
Gleizes, A.	497, 498, 953, 954
Glidden, S. C.	499
Gnadt, P. A.	1235
Gockenbach, E.	206, 375, 500
Goff, R. W.	427
Gokmen, A.	15
Goldman, A.	207
Goldman, M.	207
Gorablenkow, J.	29, 1126
Gordin, B. I.	892
Gordon, G. S.	1154, 1292
Gothard, J. V.	687
Goyette, R.	901
Graaf, H. P.	18
Graber, W.	955
Graf, R.	956
Graneau, P.	807
Grant, D. M.	957
Grasselt, H.	1207
Graybill, H. W.	376, 592, 688, 808, 870, 1192, 1389, 1400, 1458, 1459
Green, D. R.	871
Greenburg, L. A.	1407
Greenwood, A. N.	1127
Gregory, B.	1189
Gregory, H.	210
Gremmel, H.	593
Griffin, G. D.	208, 428, 429, 1401, 1402, 1403
Grill, B.	1361
Grob, R.	501
Gromier, A.	594
Grzan, J.	901
Guenther, A.	516
Guilloux, C.	958
Guoxiang, X.	217

Copyright © 1993 IEEE All Rights Reserved

--`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS

Not for Resale

Gurtzel, P. 959
Guruprasad, C. S. 502
Guzman, E. 540
Gysel, T. 955

-H-

Habedank, U. 689, 960, 1128
Hadore, P. 1460
Haginomori, E. 961
Hake, M. R. 682
Hale, C. K. 690
Hallested, R. 962
Hamano, S. 963
Hamouda, E. A. 209
Hampton, B. F. 19, 210, 308, 377, 503, 809, 810, 1177, 1488
Hand, C. L. 902
Handel, R. D. 872
Hannay, N. B. 466
Hanrahan, J. M. 504
Hara, M. 211, 378, 1262
Hara, T. 404, 1308
Harper, W. E. 691, 964, 1377, 1461, 1462
Harrington, R. J. 595, 1390
Harris, A. F. 1084, 1304
Harris, F. M. 88, 191, 489
Harris, R. K. 92
Harrison, P. M. 1316
Hartl, J. C. 1376, 1501
Hartmann, H. 1178
Harumoto, Y. 624, 1159
Harvey, S. M. 1432
Hasegawa. T. 1160
Hashoff, L. 591
Haszman, A. 596
Hata, H. 813
Hathaway, G. H. 692, 693, 734
Hauge, O. 694

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Hauschild, W.	260, 1463
Hawley, R.	448
Hayashi, H.	20
Hayashi, M.	404
Hayashi, T.	754
Hazel, R. L.	212, 1259
Haznadar, Z.	1464
Headley, P.	1465
Heberlein, G. E.	884
Hedman, L.	903
Heighes, J.	1052
Heinemann, Th.	1305
Heiss, W.	597
Henry, G.	811
Henry, J. C.	965
Hermann, W.	966, 967
Hernandez, J. L.	540
Herrmann, G.	695
Hertz, W.	505, 968
Hess, D. P.	969
Hess, R.	598
Heylen, A. E. D.	506
Hibino, M.	818
Hick, M. A.	1409
Hickman, W. M.	213, 1190
Hidaka, K.	21
Hiesinger, H.	214
Hildebrand, D. L.	507
Hill, E. H.	1193
Hilten, J. S.	1279
Hingorani, N. G.	1257, 1258, 1260
Hirano, T.	1261
Hirasawa, K.	970
Hirasawa, Y.	634
Hirata, K.	635
Hirooka, K.	22, 430, 461, 1104

Copyright © 1993 IEEE All Rights Reserved

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS

Not for Resale

Hoerauf, R. G. 971
Hoff, P. 1313
Hogg, P. 599, 622, 913, 1022, 1306, 1502
Hogg, R. 600
Hollinger, A. 431
Hollister, R. H. 1167
Holmberg, R. W. 432
Holmborn, H. 1302, 1342
Holt, P. A. 436, 437
Homburg, V. 379
Honaga, Y. 851
Honda, H. 635
Honda, M. 215
Honda, S. 1165, 1166
Hood, R. J. 64
Hopkins, M. D. 368, 1434
Horisberger, W. 622
Houlgate, R. G. 1072
Howard, P. R. 97
Hoyer, P. 1208
Hubler, E. 1209
Hudis, M. 98
Hudson, A. A. 433
Hughes, D. B. 191, 489
Hunziker, R. 672
Hux, G. 972, 1460

-I-

Ibrahim, O. E. 216, 367
Ibuki, K. 23
Ichikawa, K. 217
Ikeda, C. 380, 814
Ikeda, Shimichi 973
Ikeda, T. 603
Imgrund, G. 1124, 1139
Inaba, T. 99, 1172
Inami, K. 1097

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Inamoto, K. 670
Inamura, S. 613
Innerling, J. J. 1048
Inoue, T. 1161
Inui, A. 1162
Ishida, A. 1210
Ishii, T. 218, 1307
Ishikawa, M. 812, 904, 1194
Itaka, K. 813, 814, 826, 1308
Ito, S. 1163
Itoh, N. 1130
Iwata, K. 974

-J-

Jackson, G. 508
Jackson, R. B. 815, 1370
Jacobs, T. A. 70
Jacobsen, R. S. 705
Jakob, T. 975, 1010
James, D. R. 509, 510, 511
James, M. F. 56
Jandrell, I. R. 512, 1404
Janssen, F. J. J. G. 434
Jarmula, J. 219, 1085
Jeffs, E. 816
Jegou, Y. 780
Jing, T. 1086, 1087
Johansen, I. 129, 220
Johnson, B. L. 817, 873
Johnson, W. A. 696
Jones, E. A. 517
Jones, G. J. 88, 976
Jones, G. R. 934

-K-

Kalb, I. W. 1179
Kamata, Y. 1249
Kamatani, A. 117, 991

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Kaminaga, K. 381, 1366
Kan, M. 999
Kane, R. E. 977
Kanno, Y. 24
Kano, K. 1049
Kansog, J. D. C. 697
Karlsson, P. W. 221, 280
Karner, H. C. 379
Karrenbauer, H. 604
Kataoka, K. 742
Kato, F. 605, 1211
Kato, K. 1211
Kato, Y. 606
Kawabata, H. 1212
Kawaguchi, Y. 222, 1321, 1391
Kawamoto, T. 401
Kawamura, H. 818
Kawamura, T. 1309
Kawasaki, T. 223
Kawashima, K. 717
Kekez, M. M. 304
Kennedy, J. J. 607, 679, 698, 699
Khalaffala, K. 224, 225
Kharitonov, F. Ya. 435
Kieffer, J. 608, 811
Kikkawa, T. 706
Kikuchi, T. 609
Kilar, L. A. 819, 874
Kim, K. S. 1068
Kind, D. 820
Kinsinger, R. E. 100
Kirby, P. 1433
Kita, K. 41, 850
Kleine-Tebbe, K. A. 576
Klement, W. 794
Klewe, K. C. 226

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Kline, L. E.	513
Klumb, F. R.	875
Kneubuhl, F. K.	299, 300
Knobloch, H.	960, 978, 1180
Knudsen, N. H.	101
Ko, C. D.	1158
Koan, T.	1159
Kobayashi, A.	979
Kobayashi, M.	1165, 1166
Kobayashi, N.	1093
Kobayashi, S.	25, 1050
Kobayashi, T.	821, 1310
Kodama, T.	1213
Koehler, H. C.	897
Koepfinger, J. L.	1311
Koglin, B. B.	668
Kohler, W.	297
Kojima, S.	1321
Kolbe, W.	1214
Koltunowicz, W.	470
Kominiak, L. A.	700
Konig, D.	477, 514, 593, 1138, 1139, 1467
Kopacek, M.	1145
Kopainsky, J.	102, 352, 980
Kopejtkova, D.	1468
Korasli, C.	345, 382
Koreman, C. G. A.	1038
Korner, G.	981
Kort, F.	1215
Kothmann, R. E.	765
Kouno, T.	21, 123, 999
Koyanagi, E.	1096
Krafft, N.	654
Kramer, J. M.	610
Kranz, H. G.	515
Krauss, H.	1051

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Krenck, P. 103
Krenicky, A. 905, 1469
Kreuger, F. H. 822
Krieter, G. H. 1134
Kristiansen, M. 516
Kroon, P. J. 823
Kruger, K. 475
Krump, J. 1055
Krump, R. 515
Krznaric, Z. 611, 701
Kudo, A. 1164
Kuffel, E. 201, 212, 224, 225, 227, 1256
Kugel, H. 527
Kugler, R. 1128, 1131, 1470
Kuleshov, V. A. 1510
Kulik, P. 590, 612
Kulsetas, J. 436, 437
Kumagaya, I. S. 1165, 1166
Kumai, K. 408
Kunhardt, E. 1132
Kurimoto, A. 228, 229
Kurosawa, K. 1471
Kurosawa, Y. 633
Kuroyanagi, Y. 754, 876
Kusumoto, S. 1472
Kuwahara, H. 229, 230, 270, 383, 461, 613, 1104, 1473, 1474
Kynast, E. E. 1126
Kypreos, G. 702

-L-

Lagemann, R. T. 517
Lager, P. 614
Laghari, J. R. 232, 233, 1088, 1089, 1090
Laicman, J. 1405
Lamontagne, G. 1312
Lampe, J. 384, 439
Lann, J. S. 104

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Lannes, W. J.	741
Lapen, R. J.	765
Larigaldie, S.	503
Larocque, R.	171
Larrue, H.	1475
Laskowski, L.	615, 703, 709
Latour-Slowikowska, H.	384, 385, 438, 439
Lause, R. E.	1244
Lautenschlaeger, H.	234, 235, 824, 906
Law, C. K.	7, 8, 181, 182, 674
Lawrence, R. C.	105
Lazo, T. C.	329
Le Ny, R.	106
Le Roy, G.	1287, 1288
Leadon, R. E.	107
Lebeda, J.	280
Lee, D. I.	486
Lee, H. H.	211, 1262
Lee, Z. Y.	108, 236, 237
Leeds, W.	109, 238, 616, 982, 983
Leep, D. A.	462, 1367
Legros, W. P.	239
Lehman, R. F.	1298
Lehmann, K.	562
Lehmann W.	861
Leibold, A.	374, 646, 1476, 1490
Leijon, M.	1282, 1313
Leitl, A.	282
Lembo, F.	615, 703
Leonhardt, G.	593, 668
Lesnowski, J. J.	617
Lester, D.	1406, 1407
Lewis, R. J.	1408
Li, H. M.	289
Li, Z. Z.	163, 164, 286
Liao, W.	74

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Lieberman, R. W. 93, 200, 240, 241, 242
Lieske, M. 907
Lightle, D. 130
Lincoln, M. C. 743
Linderholm, S. 1245
Lindsay, C. 1409
Lingal, H. J. 110
Lippert, T. 518
Lister, C. A. 1216
Lockyer, G. D. 1477
Lohmann, V. W. 618, 684
Lorenz, D. 591
Lowke, J. J. 240, 241, 242, 984
Lubben, S. F. 1208
Luehrmann, H. M. 1126, 1470
Lundgaard, L. E. 519
Lutz, F. 419, 1368
Luxa, G. 111, 860, 1445
Lyapin, A. G. 157, 538, 839, 1263, 1264, 1334
Lyman, J. L. 112
Lynch, B. R. 487

-M-

MacAlpine, J. M. K. 243, 244
Macleod, N. M. 66, 67
Maczka, W. J. 619
Madge, R. C. 801, 1202
Mahmutcehajic, R. 1293, 1464
Maier, G. 628
Maizel, E. S. 1091
Major, L. B. 837
Malik, N. H. 245, 246, 247, 248
Malkin, P. 952
Maller, N. V. 1133
Manion, J. 113, 520
Mann, R. F. 887
Mansoor, F. F. 65, 162

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Marchal, Y. 493
Mark, D. A. 697
Marks, J. A. 704
Marsun, R. 620
Martin, D. 985
Martin, E. C. 105
Martin, G. O. 1217
Martinkus, J. 1195
Martins, H. J. A. 705
Marzzoleni, B. 1218
Masaki, N. 1314
Masaki, T. 1095
Masepohl, J. C. 1195
Masetti, C. 1276, 1277
Mashikian, M. 330, 331, 1092, 1111
Massey, R. M. 420
Massone, J. 474
Mastroianni, M. 185, 1369, 1370, 1372, 1478
Mateuchev, A. 888
Mathis, R. A. 511
Matsuda, S. 621
Matsumoto, S. 21, 1344
Matsumura, S. 986, 1265, 1266, 1315
Matsusaka, H. 706
Matsuura, K. 119, 386
Mattia, J. 707
Matulic, R. 685, 708, 709, 877, 898, 1484
Maury, E. 710
Mauthe, G. 440, 622, 987, 988, 1134
Mazurin, I. M. 538
Mazza, G. 930, 1218
Mazzoleni, B. 989
McAdam, D. W. 56
McAffee, K. B. 424
McCabe, A. K. 990
McCarthy, B. 1219

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

McCluhan, F. J. 878
McDermid, W. M. 1448
McDonald, R. S. 441
McFadden, D. 1444
McGeehan, J. P. 114
McIntyre, N. S. 1063
McNeal, P. I. 36
Mears, W. H. 115
Meek, J. M. 82, 249
Meier, A. 1371
Meier, H. 300
Meinders, G. J. 964
Memita, N. 879
Menju, S. 222, 250, 629, 1093, 1221, 1267, 1391
Menon, K. V. 711, 712, 735
Merenda, J. J. 1410
Milde, H. 262
Miller, D. B. 825, 1135, 1181, 1316
Milligan, R. E. 1479
Milne, D. 130, 1335, 1500
Milsore, P. K. 521
Minaguchi, D. 251, 851
Miners, K. 741, 815, 1358, 1372
Ming, L. 1094, 1313
Minkwitz, R. E. 715
Miri, A. M. 1246
Misaki, T. 116, 826
Mitani, M. 1317
Mitchel, G. 442
Mitiche, A. M. 953
Mitsui, T. 1220
Miura, Y. 1163
Miyachi, I. 1268
Miyagawa, M. 1318
Miyamoto, T. 117, 991
Mizukami, T. 826

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Mizuno, K.	1095
Modica, A. P.	443
Moeller, J.	1051, 1480
Moller, K.	1319
Moore, C. L.	1167
Moran, J. A., Jr.	774
Morant, M. M.	239
Morcos, M. M.	252, 253, 254, 255, 256, 387, 388, 881
Morello, A.	828
Morgan, J. D.	257
Morgan, V. T.	389
Mori, E.	717
Mori, S.	829, 830, 882, 908
Mori, T.	465
Morii, K.	624, 718, 992, 1481
Morita, T.	1136
Morris, J. R., II	1168
Morrow, R.	258, 259, 389
Morshuis, P. H. F.	1086, 1087
Mosch, W.	260
Motschmann, H.	505
Mudra, J.	1118
Muhr, M.	1247
Mukaiyama, Y.	444, 522, 1169, 1320
Mukhedkar, D.	274, 1312
Mulcahy, M. J.	261, 262, 523
Muller, B.	477, 625
Muller, H. G.	626, 1482
Muller, W.	627
Munch, R.	524
Munk-Nielsen, T.	125, 263
Munzinger, K.	628
Murakami, Y.	629, 1221
Muramoto, H.	525, 1170
Murano, M.	118, 1321
Murase, H.	26

Copyright © 1993 IEEE All Rights Reserved

-- `,,`-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS

Not for Resale

Murayama, Y. 630, 1344
Murthy, A. R. 450
Mushiga, M. 1222
Muto, S. 1095

-N-

Nabuaki, K. 119
Nagai, N. 1182
Nagamatsu, H. T. 993
Nagami, K. 1136
Naganawa, H. 1268
Nagaoka, N. 1322
Nakagawa, Y. 1043
Nakakita, T. 1096
Nakamura, E. 1483
Nakanishi, K. 264, 265, 909, 994, 1097, 1269, 1272
Nakata, R. 910, 1270, 1271
Nakayama, H. 445
Nakayama, S. 400, 457
Nannery, P. R. 1484
Narbut, P. 120
Narimatsu, S. 1098, 1137
Natsui, K. 266, 995, 1044
Natsume, F. 119
Nawrowski, R. 831
Nears, W. H. 425
Neilson, J. B. 1393
Nemoto, B. 631
Netzel, P. C. 1061
Neumann, C. 1138, 1139
Nicol, J. 832
Niemeyer, L. 190, 267, 287, 446, 526, 527, 1323
Nigol, O. 1485
Nijland, H. A. H. 632
Nikiforov, M. G. 1223
Nikolas, J. T. 680
Nilsson, S. 1479

Copyright © 1993 IEEE All Rights Reserved

--``,,-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Nishida, I.	633, 634
Nishijima, K.	268
Nishikawa, H.	997
Nishimoto, K.	833
Nishiwaki, S.	1140
Nissan, A. H.	447
Nitta, T.	27, 121, 265, 269, 270, 271, 272, 310, 390, 391, 528, 1182, 1183, 1272, 1315, 1324
Noeske, H. O.	28, 100, 998
Noffle, R. E.	546
Nojima, K.	1325
Nokayama, S.	320
Nossier, A.	448
Noto, F.	122

-O-

Oda, T.	529
Ogawa, H.	605, 1211
Ogi, H.	1326
Oh-Hara, J.	1327
Ohmachi, H.	1187
Oishi, K.	635
Oishi, M.	631, 719
Okabe, S.	123, 999, 1099, 1171
Okazaki, M.	1172
Okuda, H.	1224
Okuda, S.	273
Okuno, M.	1000
Okutsu, Naohiro	1225, 1373
Olivier, G.	274
Olsen, K.	1328
Olsen, W.	571, 720, 907, 1487
Ono, M.	633
Ophel, T. R.	449
Orr, J. S.	66, 67
Osborne, S. H., Jr.	1496
Ose, K.	1212

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Osmokrovic, P. 1329
Ott, H. P. 1226, 1236
Ottischnig, R. 988, 1371
Ouyang, M. 392, 1273, 1274
Owens, J. B. 34, 726
Ozawa, J. 275, 1309

-P-

Pace, M. O. 183, 329, 429, 439, 455, 462, 480, 530, 531, 532, 636, 1132, 1252
Pack, S. 29, 1247, 1330
Padma, D. K. 450
Pai, R. Y. 124, 276
Pankuch, Joseph 1374
Parekh, H. 393
Parisielle, R. 710
Park, K. Y. 1001
Parvopassu, P. 1196
Paszek, G. 900
Patrunky, H. 1487
Paul, P. 1275
Pearson, J. S. 1488
Pedersen, A. 125, 221, 263, 277, 278, 279, 280, 394, 395
Pedersen, B. O. 10, 186, 766, 767, 834
Pelletier, J. M. 533
Pender, J. T. 1231
Pennel, P. M. 534
Pereira, M. J. 800
Perkins, J. F. 30, 31, 126, 932, 1002, 1003, 1004
Perrissin, G. 965
Perry, E. R. 835, 838, 883, 1100
Perry, M. P. 836, 837, 1489
Pesavento, G. 469
Petersen, C. H. 1490
Peterson, A. R. 504
Pettersson, K. 1289, 1331
Pettinga, J. A. J. 911
Pezzi, P. 931

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Pfeiffer, W. 32, 204, 281, 282, 283, 284, 396, 535, 1141
Pfender, E. 285
Pfleiderer, R. 925, 1332
Philip, S. F 536, 1168
Philippovich, V 596
Philosophos, J. 113, 127, 520
Phung, B. T. 163, 164, 286
Picard, A. 537
Piechocki, A. 959
Pigini, A. 470, 1491
Pillai, A. 1333
Pinnekamp, F. 287, 446
Piscioneri, J. N. 838
Pitchford, L. 60
Plechaty, L. 1005, 1039
Plump, R. E. 74, 1154, 1292
Pohl, M. C. 451
Polster, H. J. 1207
Poltev, A. I. 151
Ponder, J. Z. 1061
Pons, A. 954
Poole, D. 628, 644
Popkov, V. I. 157, 538, 839, 1263, 1264, 1334
Posmure, F. 939
Potter, M. E. 1184
Pounds, C. G. 637
Powell, C. W. 1500
Premur, K. 722
Prescott, L. E. 947
Priest, G. 306
Proud, J. M. 197
Pryor, B. M. 1375
Pugh,P. 840, 1420

-Q-

Qiu, Y. 288, 289, 539
Qureshi, A. H. 233, 246, 247, 248, 1089, 1090

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

-R-

Radgen, H.	638
Radwan, R.	152, 290, 291
Ragaller, K.	967
Rahmann, F. J.	1142
Raimbault, J.	724
Rain, P.	292
Raju, G. R.	85
Rapp, D.	128
Rappange, A.	1007, 1018
Rebbapragada, R. V.	639
Reddy, C. N.	1275
Reed, C. W.	1173
Rees, V.	576, 981
Reggio, M.	1031
Reid, R.	1493, 1494, 1495
Reighter, D. H.	548, 1101, 1102
Reilly, M. J.	731
Reimers, T. D.	726,884
Rein, A.	129, 293, 294, 295, 436, 437, 694
Reinhardt, P. W.	80
Reinhardt, R.	1020
Rengu, Zhang	296
Reynders, J. P.	332, 512, 1404
Rhodes, G.	685
Rich, J. A.	948
Richards, P. H.	52, 53, 203
Richter, F.	1117
Rickley, A. L.	1496
Rickman, J.	1335
Rimpp, F.	614, 642, 727, 728
Riquel, G.	190
Rishworth, A. B.	1248
Rizk, F. A. M.	33, 841, 1105, 1186, 1276, 1277
Rizzetto, S.	1497
Robert, T.	954

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Roberts, P. 643
Robinson, J. A. 1175
Robinson, M. 113, 127, 520
Robledo-Martinez, A. 540
Rocamora, R. G. 1311
Roe, D. M. 1024
Roguski, A. T. 1008
Roidt, R. M. 136, 137, 138, 1021
Rollier, C. 965
Rollo, J. T. 1498
Rong, X. 297
Rosenthal, E. 115
Rosskopf, Th. V. 1499
Roth, A. W. 34
Rothhardt, L. 298
Rovelli, S. 930
Ruegsegger, W. 299,300
Ruffieux, S. 1227
Rusck, S. 336, 337, 402
Rutgers, W. R. 1037, 1038
Rutten, U. 1339
Ryan, H. M. 130, 301, 302, 313, 339, 397, 1335, 1500

-S-

Saba, S. 742
Safar, Y. A. 248
Safigianni, A. 912
Saito, S. 1338
Sakai, M. 528
Sakai, T. 452
Sakakibara, T. 131
Sakata, K. 222, 1391
Sakuma, S. 23, 528
Salma, M. M. 291
Salvetti, M. 568
Samm, R. 353, 414, 764, 842
Samuelsson, R. 398, 399

--`,,`-`-`,,`,,`,`,,`---
Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Sangkasaad, S. 303, 541
Sasaki, E. S. 1376
Sasaki, E. W. 1501
Sasaki, K. 634
Sasamoto, S. 1411
Sato, H. 827, 843
Sauers, I. 453, 454, 455, 481, 542, 543, 1412
Saunderson, J. C. 1250
Savic, P. 304
Scarpa, P. 1009
Scaturro, A. J. 1494, 1495
Schade, E. 102, 975, 1010
Schaefer, G. 516
Schaub, B. 1246
Schaumann, R. 644, 975, 1010
Schei, A. 1342
Schels, W. 1413
Schemmann, B. 132, 1142, 1208
Scherer, H. N., Jr. 729
Schmidt, J. L. 1377
Schmidt, K. D. 913,988
Schmidt, R. L. 844, 845, 885
Schmidt, W. 35, 133, 283, 544, 599, 890, 1306, 1502
Schmitz, U. 905
Schmitz, W. 645, 646
Schoetzau, H. J. 299, 1020
Schramm, H. H. 1336
Schroeder, D. A. 730
Schuhman, H. 514
Schulz-Guide, E. 305
Schumb, V. C. 306
Schwab, A. 780
Schwager, H. H. 1143
Schwalb, E. 1011
Schwarz, R. 379
Schweinler, H. C. 134

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Scott, J. C.	731
Seethapathy, R.	1069
Sekiya, Y.	307
Sellars, A. G.	308, 1488
Sengupta, S. S.	254
Shah, J. K.	1012
Shaw, B. J.	648
Shay, G. A.	1013
Shcherbina, O. V.	839, 1334
Sheer, R. E., Jr.	993
Shevstov, E. N.	1263, 1264
Shibuya, Y.	27, 265, 271, 309, 310
Shimada, M.	1251
Shimshock, J. F.	1440
Shimura, I.	1036
Shindo, H.	122
Shiota, H.	733
Shipp, D. D.	971
Shirai, M.	22
Shoulders, W. E.	1347
Siddagangappa, M. C.	311, 456
Sidler, H.	573
Siegel, B.	135
Silver, D. A.	846
Silver, D. P.	1279
Simms, J. R.	1337
Sinka, J. V.	115
Skipper, D. J.	36
Skoda, F.	1405
Skoda, Z.	1145
Slamecka, E.	625
Sletten, A. M.	195, 196
Sletthaug, J.	694
Slowikowski, J.	384, 439
Smardzewski, R. R.	545, 546
Smit, J.	1014

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Smith, R. T.	566
Smith, W. G.	755
Soerlei, Z.	155
Sokoly, T. O.	1184
Solin, P. C.	899
Somerville, I. C.	312, 382
Sommerman, G. M. L.	364
Sonderegger, G.	905
South, W. H.	1440
Spaeren, P.	1284
Sparks, W. W.	693, 734
Specht, H.	1414
Spence, G.	313
Spencer, E. M.	847
Spendal, E.	684, 735
Spindle, H. E.	150, 649, 667, 736, 1015, 1040, 1384, 1505
Spriggs, K. R.	314
Spyrou, S. M.	455
Srivastava, K. D.	37, 38, 156, 174, 252, 253, 254, 255, 256, 315, 316, 333, 349, 387, 388, 393, 416, 881, 1065, 1103, 1133
St-Jean, G.	1016
St. Onge, H.	1077
Stahan, I.	1228
Stegmuller, I. K.	1017
Steiner, K.	737
Stelzer, R.	1018, 1469
Stepenkov, V. V.	496
Steppat, A.	978
Stevanova, M.	11
Stevenson, J. B.	671
Stiborora, E.	1145
Stokes, A. D.	1019, 1127
Stolarz, W.	596, 695, 1371
Stolpe, J.	887, 888
Stolz, D.	1141
Stone, G. C.	476, 547, 1497

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Stopar, S. J. 650
Strachan, D. C. 934
Strasser, H. 599, 645, 913
Streit, G. E. 58
Strom, A. 72, 109, 110, 238
Stuckless, H. 183, 317
Studniarz, S. A. 1074
Sturzenegger, C. 1020
Sudhakar, C. E. 37, 38
Sugahara, K. 1322
Sugiyama, S. 318
Sum, C. L. 1155
Sun, R. 1125, 1146
Supplee, G. W. 738, 889, 914
Suzuki, K. 1338
Suzuki, T. 319, 320, 400, 457, 1187
Sverak, J. G. 1379, 1394
Swan, G. A. H. 1498
Swanson, B. W. 136, 137, 138, 1021
Swarbrick, R. 321
Swift, J. D. 52, 53
Swindler, D. L. 1415
Swoish, R. F. 868, 1197, 1506
Syau, T. 1229
Syromyatnikov, B. D. 496, 1345, 1512
Szente-Varga, H. P 35, 587, 651, 652, 653, 654, 739, 740, 890, 1022, 1230

-T-

Tahiliani, V. 458, 548, 636, 675, 741
Takagi, T. 39, 655, 656, 742, 848
Takahashi, I. 1023
Takahashi, K. 1267
Takahashi, Y. 322
Takano, T. 386
Takuma, T. 40, 41, 47, 139, 140, 141, 142, 143, 323, 401, 849, 850
Tamura, M. 1024
Tanabe, T. 657

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Tanizawa, K.	851
Tatken, R. L.	1408
Taylor, D. J.	743
Taylor, S.	1025
Tedford, D. J.	83, 229, 312, 417, 486, 743, 1231
Teich, T. H.	42, 144
Teresaka, K.	1416
Thakar, H. C.	610
Theophilus, G. D.	233
Theoret, A.	75, 172, 1417
Thiel, H. G.	1339
Thom, J.	175
Thorburn, R.	324
Thuries, E.	659, 1232
Tieszen, K.	902
Tikhodeev, N. N.	892
Tobazeon, R.	292
Toda, H.	660
Tokes, J.	661
Tokoro, K.	744
Tokuyama, S.	459
Tomberger, H.	1147
Tominaga, S.	460, 461, 549, 1026, 1027, 1028, 1036, 1104, 1380, 1507, 1508
Tong, L.	1041
Torok, J. S.	1198
Torshin, Y. V.	43
Tozer, B. A.	226
Tranen, J. D.	1340, 1341
Trapp, N.	1336
Traylor, L. E.	938
Trepanier, J. Y.	1029, 1030, 1031
Trinh, N. G.	326, 327, 442, 854, 1105, 1106
Tripoten, I. G.	1059
Trochimowica, H. J.	1418
Troger, H.	572, 625
Trump, J.	145, 306, 370, 817, 855, 856, 873, 1070

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Tsanakas, D. 912
Tsubaki, T. 609
Tsuchihashi, M. 1107, 1233
Tsuchikawa, Y. 1093
Tsuchiya, Y. 745, 1032
Tsukushi, M. 1044
Tsuneyasu, I. 268
Tsutsumi, M. 1136
Tsybrovskii, G. G. 1148
Tuma, D. T. 1033
Tunnicliffe, P. R. 1234
Tuoho, E. J. 910
Turban, G. 537

-U-

Uchida, K. 893
Ueda, Yoshiro 1034
Ueno, S. 1322
Ujita, K. 1182
Ulriksen, Th. 295
Upton, C. W. 1198
Urwin, R. J. 54
Ushio, T. 746, 1035, 1036, 1419

-V-

Vallino, M. 568
Van Brunt, R. J. 311, 328, 329, 330, 331, 456, 462, 550, 1279, 1367
Van Coller, J. M. 1404
van der Laan, P. C. T. 1343
van der Sluis, L. 1037, 1038
van der Zel, G. L. 332
Van Deventer, G. C. 822
Van Doan, P. 953
van Heeswijk, R. G. 174, 316, 333, 393, 416, 552
van Houten, M. A. 1343
Van Noy, J. H. 947
Van Roggen, A. 1420
Van Slambrouck, T. 334

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

Varivodov, V. N. 551, 1054, 1108
Veda T. 1421
Velazquez, R. 1071
Venkatraman, P. 1229
Vertikov, V. P. 166, 1510
Veuhoff, F. 1128, 1470
Vieira, C. S. 1511
Vigreux, J. 494, 659, 663, 710, 747, 1060, 1381
Vijh, A. K. 335, 1280
Vincent, C. 854, 1105, 1106
Vis, P. 1305
Vishnevsky, Y. I. 1512, 1513
Vlastos, A. E. 336, 337, 402
Voisin, G. 594, 608
Volker, P. 396
Volpov, E. K. 1054, 1108
von Olshausen, R. 1064
Vontobel, J. 664, 665, 1147
Vora, J. P. 585, 1456
Vosahlik, V. 1055
Voss, G. 597
Vostracky, Z. 1005, 1039, 1514
Vouros, P. 338
Voytik, R 1167
Vujovic, V. 748

-W-

Waddington, F. B. 1052
Wagenaar, L. B. 13, 1199
Wagner, C. L. 1040, 1042, 1283
Wahlstrom, B. 1342
Walldorf, S. P. 1235
Walsh, E. J. 1174, 1175, 1403
Wandel, R. C. 1175
Wang, C. X. 1109, 1110
Wang, E. 1041
Wang, H. T. 552

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Wang, S.	1188
Wang, You Lin	44
Wasserstrom, A.	1361
Watanabe, T.	40, 41, 141, 142, 143, 323, 401, 850
Watanabe, Y.	666, 894, 895
Watson, P. W.	646
Watson, W. L.	301, 302, 339
Watts, M. W.	340, 1109, 1110
Weck, K. H.	45
Wegener, J.	614, 720
Wert, A. C.	682
West, J. R.	896
Wetzel, R.	1449
Wetzer, J. M.	1343
Whitehead, D. L.	667
Whitney, B. F.	1092, 1111
Wiegart, N.	341
Wieland, A.	668
Wieseler, D. L.	1515
Wiggins, C. M.	1149
Wilkes, R. B.	1494, 1495
Wilkins, R. L.	146, 553
Williams, J. A.	796, 808, 897
Williams, P E	554
Williamson, A.	676
Wilmshurst, J. K.	555
Wilson, A.	1109, 1110, 1297
Wittle, H.	505
Wittle, J. K.	1516
Wock, S.	147, 1422
Wohlmuth, M.	46
Wolf, J.	204
Woodworth, J. R.	1150
Wootton, R. E.	148, 187, 342, 358, 365, 366, 369, 403, 463, 556, 557, 1112, 113
Works, C. N.	161,343
Wray, K. L.	464, 558

 Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS Not for Resale

Wright, S. E. 1149
Wu, J. L. 951
Wuthrich, H. R. 1236

-X-

Xie, Jun 1114

-Y-

Yamada, N. 149, 272, 310
Yamagata, Y. 559
Yamagiwa, T. 1249, 1517
Yamamato, H. 826
Yamamoto, M. 1423
Yamamoto, O. 404
Yamashita, H. 465
Yamashita, Y. 624
Yamauchi, A. 1053
Yanabu, S. 1151, 1152, 1344
Yashima, M. 47
Yeckley, R. N. 1042
Yegorov, A. A. 1345
Yeoman, F. A. 1066
Yializis, A. 227, 344
Yildirim, F. 345
Yoda, B. 380
Yoon, K. H. 150, 798, 799, 1115
Yoshida, S. 1338
Yoshida, T. 1346
Yoshida, Y. 669, 1159
Yoshikawa, I. 670
Yoshimitsu, T. 320, 400, 457
Yoshimura, N. 122
Yoshioka, Y. 1043, 1044, 1249
Yoshizawa, T. 560
Young, C. P. 1518
Yuen, D. C. M. 1382
Yumoto, M. 452
Yunping, Feng 346

Copyright © 1993 IEEE All Rights Reserved

--``,,-`-`,,`,,`,`,,`---

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS
Not for Resale

-Z-

Zaengl, W. S.	42, 562
Zalesskii, A. M.	151
Zava, M. B.	752
Zdanowicz, L.	1116
Zelingher, S.	898, 1237
Zeller, N.	1469
Zengin, V.	561
Zhang, W.	1188, 1246
Zhao, M.	1041
Zhou, J.	1103
Ziber, K.	151
Zimmer, V.	32, 284
Zimmerman, N. J.	342, 557
Zipfl, P.	32, 284
Zumbach, E.	1215

--`,,`-`-`,,`,,`,`,,`---

Copyright © 1993 IEEE All Rights Reserved

Copyright The Institute of Electrical and Electronics Engineers, Inc.
Provided by IHS under license with IEEE
No reproduction or networking permitted without license from IHS

Not for Resale