To: Current Holders of NEMA ICS 2-2000
From: NEMA Communications Department
Date: May 23, 2002
Subject: Addendum/Errata to Part 2 of NEMA ICS 2-2000

Setting Standards for Excellence

Part 2 of the present publication of NEMA ICS 2-2000, *Industrial Control and Systems: Controllers, Contactors and Overload Relays Rated 600 Volts,* has the following addendum and errata pages:

ADDENDUM PAGES:

MG1 & ICS2 LRA up to 500 HP

Revised Locked-Rotor Current Ratings in NEMA ICS 2 Part 2 Based on NEC 2002 and NEMA MG 1

Single Phase Locked-Rotor Current as Published in NEMA MG 1-1993 (paragraphs 12.33 and 12.34) and NEC 2002 (Table 430.151(A)) versus Single Phase LRA published in NEMA ICS 2-2000 (Part 2)

Single Phase Locked-Rotor Current as extrapolated from NEMA MG 1-1993 (paragraphs 12.33 and 12.34), NEC 2002 and NEMA ICS 2-2000 (Part 2)

ERRATA PAGES:

Table 2-4-1, Horsepower (HP) and Locked-Rotor Current (LRA) Ratings for Three-Phase, Single-Speed Full-Voltage Magnetic Controllers for Limited Plugging and Jogging-Duty (Replaces Table 2-4-1 on Page 2-14)

Table 2-4-2, Horsepower (HP) and Locked-Rotor Current (LRA) Ratings for Single-Phase Full-Voltage Magnetic Controllers for Limited Plugging and Jogging-Duty, 50 or 60 HZ (Replaces Table 2-4-2 on page 2-14)

Table 2-4-3, Horsepower (HP) and Locked-Rotor Current (LRA) Ratings for Three-Phase, Single-Speed Full-Voltage Magnetic Controllers for Plug-Stop, Plug-Reverse or Jogging-Duty (Replaces Table 2-4-3 on page 2-15)

Table 2-4-4, Horsepower (HP) and Locked-Rotor Current (LRA) Ratings for Single-Phase Full-Voltage Magnetic Controllers for Plug-Stop, Plug-Reverse, or Jogging-Duty, 50 or 60 HZ (Replaces Table 2-4-4 on page 2-15)

Table 2-4-5, Horsepower (HP) and Locked-Rotor Current (LRA) Ratings for Three-Phase, Reduced-Voltage Magnetic Controllers for Limited Plugging and Jogging-Duty (Replaces Table 2-4-5 on page 2-16)

Table 2-4-6, Horsepower (HP) and Locked-Rotor Current (LRA) Ratings for Single-Phase Reduced-Voltage Magnetic Controllers for Limited Plugging and Jogging-Duty, 50 or 60 HZ (Replaces Table 2-4-6 on page 2-16)

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-7, Horsepower (HP) and Locked-Rotor Current (LRA) Ratings for WYE-Delta Magnetic Controllers for Either Open or Closed Transition (Replaces Table 2-4-7 on page 2-17)

Table 2-4-9, Current Ratings for Limited Plugging and Jogging Full-Voltage Polyphase Magnetic Controllers for Motors Suitable for Part-Winding Starting (Replaces Table 2-4-9 on page 2-18)

Table 2-4-11, Current Ratings for Limited Plugging and Jogging Reduced-Voltage Polyphase Magnetic Controllers for Motors Suitable for Part-Winding Starting (Replaces Table 2-4-11 on page 2-19)

Please insert the attached Addendum and Errata pages into your standard.

Thank you for your attention in this matter.

--`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Addendum and Errata
Part 2 of the present publication of

NEMA Standards Publication ICS 2-2000

Industrial Control and Systems Controllers: Contactors and Overload Relays Rated 600 Volts

Published by

National Electrical Manufacturers Association
1300 North 17th Street, Suite 1847
Rosslyn, Virginia 22209

www.nema.org

© Copyright 2003 by the National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS

Not for Resale

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety–related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale




Figure 1 of Addendum
MG 1 AND ICS 2 LRA UP TO 500 HP

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 1 of Addendum
REVISED LOCKED-ROTOR CURRENT RATINGS IN NEMA ICS 2 PART 2
BASED ON NEC 2002 AND NEMA MG 1

Three Phase Locked-Rotor Current
as Published in NEMA MG 1-1993 (Paragraph 12.35.1, 12.36, Table 12-1), NEC 2002 (Table 430.151(B), and NEMA ICS 2-2000 (Part 2)

HP	200V			230V			380V		400V	460V			575V		
	MG1	NEC	ICS2	MG1	NEC	ICS2	MG1	ICS2	MG1	MG1	NEC	ICS2	MG1	NEC	ICS2
1.5	46	46	46	40	40	30	27	30	26	20	20		16	16	
2	58	57.5		50	50		34		32	25	25	25	20	20	20
3	74	73.6	74	64	64	64	43		41	32	32		26	25.6	
5	106	105.8		92	92		61	64	58	46	46	53	37	36.8	42
7.5	146	146	151	127	127	107	84		80	64	63.5		51	50.8	
10	186	186.3	255	162	162		107	107	102	81	81	88	65	64.8	70
15	267	267		232	232	255	154		146	116	116		93	93	121
25	420	420	500	365	365		243	255	231	183	183	210	146	146	168
30	500	500		435	435	500	289		275	218	218		174	174	
40	667	667	835	580	580		387		368	290	290		232	232	291
50	834	834		725	725	835	482	500	458	363	363	418	290	290	334
75	1248	1248	1670	1085	1085		722	835	686	543	543		434	434	578
100	1668	1668		1450	1450	1670	965		917	725	725	835	580	580	668
150	2496	2496	3340	2170	2170		1441	1670	1369	1085	1085		868	868	1155
200	3335	3335		2900	2900	3340	1927		1831	1450	1450	1670	1160	1160	1334
300	5060		5020	4400		5000				2200	2200	2510	1760	1760	2000
350	5865			5100		5020				2550	2550		2040	2040	
400	6670			5800						2900	2900	3340	2320	2320	2670
450	7475			6500		7500				3250	3250		2600	2600	
500	8338		8660	7250		8660				3625	3625		2900	2900	

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 1 of Addendum
REVISED LOCKED-ROTOR CURRENT RATINGS IN NEMA ICS 2 PART 2
BASED ON NEC 2002 AND NEMA MG 1
(continued)

Three Phase Locked-Rotor Current
as Extrapolated from NEMA MG 1-1993 (Paragraph 12.35.1, 12.36, Table 12-1)
and as Published in NEMA ICS 2-2000 (Part 2)

HP	200V		230V		380V		400V	460V		575V	
	MG1	ICS2	MG1	ICS2	MG1	ICS2	MG1	MG1	ICS2	MG1	ICS2
250					2409	2510	2288				
300					2891	3340	2746				
450					4336	5000	4119				
500					4818	5020	4577				
600	10005		8700		5781		5492	4350		3480	4000
700	11673		10150		6745		6407	5075	5020	4060	
750	12506	13000	10875		7226		6865	5438		4350	
800	13340		11600	13400	7708	8660	7323	5800		4640	
900	15008		13050		8672		8238	6525	7500	5220	6000
1000	16675		14500		9635	13000	9153	7250	8660	5800	6930
1500	25013	23200	21750	23200	14453		13730	10875	13000	8700	10400
1600	26680		23200		15416		14645	11600	13400	9280	10700
2000	33350		29000		19270	23200	18307	14500		11600	
3000	50025		43500		28905		27460	21750	23200	17400	18500

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2 of Addendum
SINGLE PHASE LOCKED-ROTOR CURRENT
AS PUBLISHED IN NEMA MG 1-1993 (PARAGRAPHS 12.33 AND 12.34)
AND NEC 2002 (TABLE 430.151(A)) VERSUS SINGLE PHASE LRA
PUBLISHED IN NEMA ICS 2-2000 (PART 2)

HP	115 V					230 V					
	MG1			NEC	ICS2	MG1				NEC	ICS2
	O	N	L			O	N	L	M		
1/3	50	31			50	25	18				
½	50	45	45	58.8	53	25	25	25		29.4	
1		80	80	96	80		45	45		48	43
1-1/2				120	93			50	40	60	
2				144	150			65	50	72	60
3				204	250			90	70	102	135
5				336	300			135	100	168	150
7 – ½				480	500			200	150	240	250
10				600						300	300

Table 3 of Addendum
SINGLE PHASE LOCKED-ROTOR CURRENT
AS EXTRAPOLATED FROM NEMA MG 1-1993 (PARAGRAPHS 12.33 AND 12.34), NEC 2002
AND NEMA ICS 2-2000 (PART 2)

HP	Volt	MG1		NEC	ICS2
		L	M		
15	230	390	300	450	500

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Errata for
Table 2-4-1
HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR THREE-PHASE, SINGLE-SPEED FULL-VOLTAGE MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY

Size of Controller	Continuous Current Rating (Amperes)	At 200V 60 Hz		At 230V 60 Hz		At 400V 50 Hz		At 460V 60 Hz		At 575V 60 Hz		Service-Limit Current rating* (Amperes)
		HP	LRA	HP	LRA	HP	LRA	HP	LRA	HP	LRA	
00	9	1.5	46	1.5	40	1.5	26	2	25	2	20	11
0	18	3	73.6	3	64	5	58	5	46	5	36.8	21
1	27	7.5	146	7.5	127	10	102	10	81	10	64.8	32
2	45	10	186.3	15	232	25	231	25	183	25	146	52
3	90	25	420	30	435	50	458	50	363	50	290	104
4	135	40	667	50	725	75	686	100	725	100	580	156
5	270	75	1248	100	1450	150	1369	200	1450	200	1160	311
6	540	150	2496	200	2900	300	2746	400	2900	400	2320	621
7	810			300	4400			600	4350	600	3480	932
8	1215			450	6500			900	6525	900	5220	1400
9	2250			800	11600			1600	11600	1600	9280	2590

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Errata for
Table 2-4-2
HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR SINGLE-PHASE FULL-VOLTAGE MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY, 50 OR 60 HZ

Size of Controller	Continuous Current Rating (Amperes)	115 Hz		230V 60 Hz		Service-Limit Current rating* (Amperes)
		HP	LRA	HP	LRA	
00	9	1/3	50	1	48	11
0	18	1	96	2	72	21
1	27	2	144	3	102	32
1P	36	3	204	5	168	42
2	45	3	204	7.5	240	52
3	90	7.5	480	15	450	104

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Errata for
Table 2-4-3
HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS
FOR THREE-PHASE, SINGLE-SPEED FULL-VOLTAGE MAGNETIC CONTROLLERS
FOR PLUG-STOP, PLUG-REVERSE OR JOGGING-DUTY

Size of Controller	Continuous Current Rating (Amperes)	At 200V 60 Hz		At 230V 60 Hz		At 400V 50 Hz		At 460V 60 Hz		At 575V 60 Hz		Service-Limit Current rating* (Amperes)
		HP	LRA	HP	LRA	HP	LRA	HP	LRA	HP	LRA	
0	18	1.5	46	1.5	40	1.5	26	2	25	2	20	21
1	27	3	73.6	3	64	5	58	5	46	5	36.8	32
2	45	7.5	146	10	162	15	146	15	116	15	93	52
3	90	15	267	20	290	30	275	30	218	30	174	104
4	135	25	420	30	435	50	458	60	435	60	348	156
5	270	60	1001	75	1085	125	1147	150	1085	150	868	311
6	540	125	2087	150	2170	250	2288	300	2200	300	1760	621

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Errata for
Table 2-4-4
HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR SINGLE-PHASE FULL-VOLTAGE MAGNETIC CONTROLLERS FOR PLUG-STOP, PLUG-REVERSE, OR JOGGING-DUTY, 50 OR 60 HZ

Size of Controller	Continuous Current Rating	At 115 Hz		At 230V 60 Hz		Service-Limit Current Rating*
	Amperes	HP	LRA	HP	LRA	Amperes
0	18	1/2	58.8	1	48	21
1	27	1	96	2	72	32
1P	36	1-1/2	120	3	102	90
2	45	2	144	5	168	52
3	90	5	336	10	300	104

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Errata for
Table 2-4-5
HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR THREE-PHASE, REDUCED-VOLTAGE MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY

Size of Controller	Continuous Current Rating (Amperes)	At 200V 60 Hz		At 230V 60 Hz		At 400V 50 Hz		At 460V 60 Hz		At 575V 60 Hz		Service-Limit Current Rating* (Amperes)
		HP	LRA	HP	LRA	HP	LRA	HP	LRA	HP	LRA	
1	27	7.5	146	7.5	127	10	102	10	81	10	64.8	32
2	45	10	186.3	15	232	25	231	25	183	25	146	52
3	90	25	420	30	435	50	458	50	363	50	290	104
4	135	40	667	50	725	75	686	100	725	100	580	156
5	270	75	1248	100	1450	150	1369	200	1450	200	1160	311
6	540	150	2496	200	2900	300	2746	400	2900	400	2320	621
7	810			300	4400			600	4350	600	3480	932
8	1215			450	6500			900	6525	900	5220	1400
9	2250			800	11600			1600	11600	1600	9280	2590

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Errata for
Table 2-4-6
HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR SINGLE-PHASE REDUCED-VOLTAGE MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY, 50 OR 60 HZ

Size of Controller	Continuous Current Rating (Amperes)	115 Hz		230V 60 Hz		Service-Limit Current Rating* (Amperes)
		HP	LRA	HP	LRA	
1	27	2	144	3	102	32
1P	36	3	204	5	168	42
2	45	3	204	7.5	240	52
3	90	7.5	480	15	450	104

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Errata for
Table 2-4-7
HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS
FOR WYE-DELTA MAGNETIC CONTROLLERS FOR EITHER OPEN OR CLOSED TRANSITION

Size of Controller	Continuous Current Rating (Amperes)	Contactor Size			At 200V 60 Hz		At 230V 60 Hz		At 400 V 50 Hz		At 460V 60 Hz		At 575V 60 Hz		Service Limit Current Rating*
		1M & 2M	2 & 1S	2S	HP	LRA	HP	LRA	HP	LRA	HP	LRA	HP	LRA	
1YD	47	1	1		10	186.3	10	162	15	146	15	116	15	93	55
2YD	78	2	2		20	334	25	365	40	368	40	290	40	232	90
3YD	156	3	3		40	667	50	725	75	686	75	543	75	434	179
4YD	135	4	4		60	1001	75	1085	150	1369	150	1085	150	868	270
5YD	270	5	5		150	2496	150	2170	250	2288	300	2200	300	1760	538
6YD	540	6	6		300	5060	350	5100	500	4577	700	5075	700	4060	1075
7YD	810	7	7		500	8338	500	7250	800	7323	1000	7250	1000	5800	1610
8YD	1215	8	8		750	12506	800	11600	1000	9153	1500	10875	1500	8700	2420
9YD	2250	9	9		1500	25013	1500	21750	2000	18307	3000	21750	3000	17400	4480

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Errata for
Table 2-4-9
CURRENT RATINGS FOR LIMITED PLUGGING AND JOGGING FULL-VOLTAGE POLYPHASE MAGNETIC CONTROLLERS FOR MOTORS SUITABLE FOR PART-WINDING STARTING

Size of Controller	Continuous Current Rating per Winding* Amperes	Contactor Size 1M & 2M	Locked-Rotor Rating per Winding Amperes at					Service Limit Current Rating Per Winding, Amperes*
			60 Hz 200V	60 Hz 230V	50 Hz 400 V	60 Hz 460V	60 Hz 575V	
1PW	27	1	146	127	102	81	64.8	32
2PW	45	2	186.3	232	231	183	146	52
3PW	90	3	420	435	458	363	290	104
4PW	135	4	667	725	686	725	580	156
5PW	270	5	1248	1450	1369	1450	1160	311
6PW	540	6		2900	2746	2900	2320	621
7PW	810	7		4400	4119	4350	3480	932
8PW	1215	8		6500		6525	5220	1400
9PW	2250	9		11600		11600	9280	2590

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Errata for
Table 2-4-11
CURRENT RATINGS FOR LIMITED PLUGGING AND JOGGING REDUCED-VOLTAGE POLYPHASE MAGNETIC CONTROLLERS FOR MOTORS SUITABLE FOR PART-WINDING STARTING

Size of Controller	Continuous Current Rating per Winding* Amperes	Contactor Size		Locked-Rotor Rating per Winding Amperes at					Service Limit Current Rating per winding, Amperes*
		Line (1M and 2M)	Acceler-ating	60 Hz 200V	60 Hz 230V	50 Hz 400 V	60 Hz 460V	60 Hz 575V	
1PW	27	1	1	146	127	102	81	64.8	32
2PW	45	2	2	186.3	232	231	183	146	52
3PW	90	3	3	420	435	458	363	290	104
4PW	135	4	4	667	725	686	725	580	156
5PW	270	5	4	1248	1450	1369	1450	1160	311
6PW	540	6	5		2900	2746	2900	2320	621
7PW	810	7	6		4400	4119	4350	3480	932
8PW	1215	8	7		6500		6525	5220	1400
9PW	2250	9	8		11600		11600	9280	2590

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

< This page is intentionally left blank. >

© Copyright 2003 by the National Electrical Manufacturers Association.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

NEMA Standards Publication ICS 2-2000

Industrial Control and Systems Controllers,
Contactors and Overload Relays Rated 600 Volts

Published by:

National Electrical Manufacturers Association
1300 North 17th Street
Rosslyn, Virginia 22209

© Copyright 2001 by the National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS

Not for Resale

--`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS

Not for Resale

THIS STANDARD CONSISTS OF THE FOLLOWING PARTS:

Part 1	General Standards for Manual and Magnetic Controllers
Part 2	AC Noncombination Magnetic Motor Controllers Rated 600 Volts
Part 3	Nonmagnetic Motor Controllers
Part 4	Overload Relays
Part 5	DC General-Purpose Constant-Voltage Controllers
Part 6	AC Combination Motor Controllers
Part 7	Magnetic Lighting Contactors
Part 8	Disconnect Devices for Use in Industrial Control Equipment
Annex A	Maintenance of Motor Controllers After a Fault Condition

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS

Not for Resale

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

CONTENTS

PART 1
GENERAL STANDARDS FOR MANUAL AND MAGNETIC CONTROLLERS

1. GENERAL 1-1
1.1 Referenced Standards 1-1
1.2 Scope 1-2
1.3 Normative References 1-2
2. DEFINITIONS 1-2
3. CLASSIFICATION OF MANUAL AND MAGNETIC CONTROLLERS 1-2
3.1 Class A Controllers 1-2
3.2 Class B Controllers 1-2
3.3 Class V Controllers 1-3
4. CHARACTERISTICS AND RATINGS 1-3
5. PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION 1-3
5.1 Maintenance 1-3
5.2 Marking 1-3
6. SERVICE AND STORAGE CONDITIONS 1-3
7. CONSTRUCTION 1-3
7.1 Sizes of Terminals for External Power Connections 1-3
7.2 Mechanical Interlocking of Manual and Magnetic Contactors 1-4
7.3 Electrical Interlocking of Magnetic Contactors 1-4
8. PERFORMANCE REQUIREMENTS AND TESTS 1-4
8.1 Make and Break Design Test 1-4
8.2 Range of Coil Operating Voltage 1-4
8.3 Short-Time Capability Tests 1-4
8.4 Temperature Rise Test of Coils and Current-Carrying Parts 1-5
9. APPLICATION 1-5
9.1 Estimated short-circuit performance. 1-5
9.2 Control-Circuit Transformers 1-5

Part 2
AC NONCOMBINATION MAGNETIC MOTOR CONTROLLERS RATED 600 VOLTS

1. GENERAL 2-1
1.1 Scope 2-1
1.2 Normative References 2-1
2. DEFINITIONS 2-1
3. CLASSIFICATION 2-1
3.1 Classification by Starting Methods 2-1
3.2 Full-Voltage Controllers 2-1

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

3.3 Part-Winding Controllers 2-1
3.4 Full-Voltage Two-Speed Motor Controllers 2-2
3.5 Reduced-Voltage Controllers 2-2
4. CHARACTERISTICS AND RATINGS 2-5
4.1 Horsepower and Current Ratings 2-5
4.2 Short-Circuit Current Ratings 2-8
4.3 Nonmotor Load Applications Ratings of the Contactor Portion of the Controllers 2-8
5. PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION 2-9
5.1 General Maintenance 2-9
5.2 Maintenance After a Fault 2-9
6. SERVICE AND STORAGE CONDITIONS 2-9
7. CONSTRUCTION 2-9
7.1 Control Transformer Overcurrent Protection 2-9
7.2 Terminals and Connections 2-9
7.3 Location of Overload Relay Contacts in Circuit 2-10
8. PERFORMANCE REQUIREMENTS AND TESTS 2-11
8.1 General 2-11
8.2 Performance Tests 2-11
8.3 Short-Time Operating Capability 2-11
8.4 Short-Time Surge Capability 2-11
8.5 Design Test for Short-Circuit Current Ratings for Noncombination Controllers 2-12
9. APPLICATION 2-12
9.1 Selection of Pushbuttons for Use with Magnetic Controllers 2-12
9.2 Nonmotor Load Applications 2-12
9.3 Capacitor Applications 2-12
9.4 Controller Comparisons 2-13

PART 3
NONMAGNETIC MOTOR CONTROLLERS

1. GENERAL 3-1
1.1 Scope 3-1
1.2 Normative References 3-1
2. DEFINITIONS 3-1
3. CLASSIFICATION 3-2
4. CHARACTERISTICS AND RATINGS 3-2
4.1 Horsepower and Current Ratings of Manually Operated and Motor-Operated Controllers 3-2
4.2 Ratings of Drum Controllers 3-2
4.3 Contact Ratings of Pressure, Temperature, and Liquid-Level Motor Controllers 3-3
4.4 Ratings of Resistors for Motor Secondary Circuits 3-3

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

5. PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION 3-3
6. SERVICE AND STORAGE CONDITIONS 3-3
7. CONSTRUCTION 3-3
7.1 Current Carrying Capacity of Resistors 3-3
7.2 Face-Plate Type Controllers 3-3
7.3 Drum Controller Conduit Connections 3-3
8. PERFORMANCE REQUIREMENTS AND TESTS 3-3
9. APPLICATION 3-4

PART 4
OVERLOAD RELAYS

1. GENERAL 4-1
1.1 Scope 4-1
1.2 Normative References 4-1
2. DEFINITIONS 4-1
3. CLASSIFICATION 4-3
3.1 Inverse-Time Overload Relays 4-3
3.2 Instantaneous Overload Relays 4-3
4. CHARACTERISTICS AND RATINGS 4-3
4.1 Overload Relay Types 4-3
4.2 Overload Relay Current Rating 4-4
4.3 Overload Relay Time-Current Characteristics 4-4
4.4 Overload Relay Limit of Self Protection 4-4
4.5 Overload Relay Ambient Temperature Sensitivity 4-5
4.6 Control-Circuit Contact Ratings 4-5
4.7 Solid-State Control Circuit Ratings 4-5
4.8 Solid-State Overload Relays with External Control Power Source 4-5
4.9 Line Current Relationship in Polyphase Circuits 4-5
5. PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION 4-5
5.1 Identification of Interchangeable Current Elements and Product Information 4-5
5.2 Identification of Overload Relays Using Fixed or Noninterchangeable Current Elements 4-6
5.3 Preventive Maintenance Guide 4-6
6. SERVICE AND STORAGE CONDITIONS 4-6
7. CONSTRUCTION 4-6
7.1 Selectable Functions and Settings 4-6
7.2 Trip Indication 4-6
7.3 Resetting 4-6
8. PERFORMANCE REQUIREMENTS AND TESTS 4-7
8.1 Verification Test for Overload Relay Current Rating and Time-Current Characteristics 4-7

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

8.2 Verification Test for Limit of Self-Protection 4-8
8.3 Verification Test for Overload Relay Ambient Temperature Sensitivity 4-9
8.4 Overload Relay Short-Time Capability 4-9
8.5 Control-Circuit Output 4-9
8.6 Electrical Noise Test for Solid-State Devices 4-9
8.7 Impulse Withstand Test for Solid-State Devices 4-9
8.8 Operating Memory Test for an Inverse-Time Overload Relay 4-9
9. APPLICATION 4-10
9.1 Current Rating and Time-Current Characteristics 4-10
9.2 Limit of Self Protection 4-10
9.3 Ambient Temperature Sensitivity 4-10
9.4 Cautions on the Use of Automatic Reset 4-10
9.5 Polyphase Motors Under Single-Phase Operating Conditions 4-11
9.6 Coordination with Fault-Current Protection 4-11
9.7 Application with Current Transformers 4-11
9.8 Control-Circuit Contact Rating 4-11
9.9 Short-Duration Overcurrent Effect 4-11
9.10 Overload Relay Limitations 4-11

PART 5
DC GENERAL-PURPOSE CONSTANT-VOLTAGE CONTROLLERS

1. GENERAL 5-1
1.1 Scope 5-1
1.2 Normative References 5-1
2. DEFINITIONS 5-1
3. CLASSIFICATION 5-1
3.1 Types of Full-Voltage Class B Magnetic Controllers 5-1
3.2 Reduced-Voltage Class B Magnetic Controllers for General-Purpose Applications 5-1
3.3 For Motors Having a 2 to 1 or Less Speed Range by Field Control 5-2
3.4 For Motors Having a Speed Range in Excess of 2 to 1 by Field Control 5-2
4. CHARACTERISTICS AND RATINGS 5-3
4.1 Horsepower Ratings of DC Drum Switches 5-3
4.2 Horsepower Ratings of Full-Voltage Manually Operated DC Controllers 5-3
4.3 Horsepower Ratings of Full-Voltage DC Magnetic Controllers 5-3
4.4 Horsepower Ratings of Reduced-Voltage DC Magnetic Controllers 5-3
5. PRODUCT INFORMATION, INSTALLATION, AND MAINTENANCE 5-3
6. SERVICE AND INSTALLATION CONDITIONS 5-3
7. CONSTRUCTION 5-4
7.1 Manual Controllers 5-4

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

7.2 Manual Speed Regulators 5-4
7.3 Resistor Classification for Manual Controllers 5-4
8. PERFORMANCE REQUIREMENTS AND TESTS 5-4
8.1 Short-Time Surge Capability for Class B Controllers 5-4
8.2 Circuit Opening Test 5-4
9. APPLICATION 5-4

PART 6
AC COMBINATION MOTOR CONTROLLERS

1. GENERAL 6-1
1.1 Scope 6-1
1.2 Normative References 6-1
2. DEFINITIONS 6-1
3. CLASSIFICATION 6-1
4. CHARACTERISTICS AND RATINGS 6-2
4.1 Ratings of Combination Motor Controllers 6-2
4.2 Oil Pump Controllers 6-2
4.3 Irrigation Pump Controllers 6-2
4.4 Short-Circuit Current Ratings of Class A Combination Motor Controllers 6-2
5. PRODUCT MARKING, INSTALLATION AND MAINTENANCE INFORMATION 6-2
5.1 Preventive Maintenance Guide 6-2
5.2 Specific Maintenance Instructions 6-2
5.3 Maintenance of Combination Motor Controllers After a Fault Condition 6-2
6. SERVICE AND STORAGE CONDITIONS 6-3
7. CONSTRUCTION 6-3
7.1 Components of Combination Motor Controllers 6-3
7.2 Enclosures 6-3
7.3 AC Automatic Combination Oil Field Controllers 6-4
7.4 AC Automatic Combination Irrigation Pump Controllers 6-5
8. PERFORMANCE REQUIREMENTS AND TESTS 6-6
8.1 Design Test for Short-Circuit Current Ratings for Combination Controllers 6-6
9. APPLICATION 6-6

PART 7
MAGNETIC LIGHTING CONTACTORS

1. GENERAL 7-1
1.1 Scope 7-1
1.2 Normative References 7-1
2. DEFINITIONS 7-1
3. CLASSIFICATION 7-1

--`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

4. CHARACTERISTICS AND RATINGS 7-1
5. PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION 7-1
6. SERVICE AND STORAGE CONDITIONS 7-1
7. CONSTRUCTION 7-2
8. PERFORMANCE REQUIREMENTS AND TESTS 7-2
8.1 Design Tests 7-2
8.2 Short-Time Capability 7-2
9. APPLICATIONS 7-2

PART 8
DISCONNECT DEVICES FOR USE IN INDUSTRIAL CONTROL EQUIPMENT

1. GENERAL 8-1
1.1 Scope 8-1
1.2 Application Basis 8-1
1.3 Normative References 8-1
2. DEFINITIONS 8-1
3. CLASSIFICATION 8-2
4. CHARACTERISTICS AND RATINGS 8-3
4.1 Circuit breaker ratings 8-3
4.2 Molded-case switch ratings 8-3
4.3 Motor-circuit switch ratings 8-3
4.4 Rated insulation voltage 8-4
5. PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION 8-4
5.1 Marking 8-4
5.2 Exception 8-5
5.3 Other Disconnect Devices for Motor Service 8-5
5.4 Marking Limitations 8-5
5.5 Operating Handles Sold Separately 8-5
6. SERVICE AND STORAGE CONDITIONS 8-5
7. CONSTRUCTION 8-5
7.1 Clearances and Creepage Distances 8-5
7.2 Minimum Air Gap in Open Position 8-6
7.3 Mechanical Design of Operating Handle and Mechanism 8-6
7.4 External Operating Handles for Disconnect Devices 8-6
7.5 Status Indication 8-6
7.6 Operating Mechanism for Disconnect Devices 8-7
7.7 Mechanical Interlock with Door(s) 8-7
7.8 Padlocking Provisions 8-7
7.9 Additional Construction Requirements for Disconnect Devices 8-7

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

7.10 Fuse Mounting 8-7
8. PERFORMANCE REQUIREMENTS AND TESTS 8-8
8.1 Circuit-Breaker and Molded-Case Type Tests 8-8
8.2 Motor-Circuit Switch Type Tests 8-8
9. APPLICATIONS 8-8
9.1 Application of Circuit Breakers 8-8
9.2 Protection of Nonfused Motor-Circuit Switches 8-8
9.3 Safety Procedure for Verifying Deenergized Condition 8-9

Annex A – (Informative)
MAINTENANCE OF MOTOR CONTROLLERS AFTER A FAULT CONDITION

A.1 INTRODUCTION A-1
A.2 PROCEDURES A-1
A.2.1 Enclosure A-1
A.2.2 Disconnect Devices A-1
A.2.3 Terminals and Internal Conductors A-2
A.2.4 Motor Starter A-2
A.2.5 Return to Service A-2

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Foreword

This Standards Publication was prepared by a technical committee of the NEMA Industrial Automation Control Products and Systems Section. It was approved in accordance with the bylaws of NEMA and supersedes the indicated NEMA Standards Publication. This Standards Publication supersedes ICS 2-1993

This Standards Publication provides practical information concerning ratings, construction, test, performance and manufacture of industrial control equipment. These standards are used by the electrical industry to provide guidelines for the manufacture and proper application of reliable products and equipment and to promote the benefits of repetitive manufacturing and widespread product availability.

NEMA Standards represent the result of many years of research, investigation and experience by the members of NEMA, its predecessors, its Sections and Committees. They have been developed through continuing consultation among manufacturers, users, and national engineering societies and have resulted in improved serviceability of electrical products with economies to manufacturers and users.

One of the primary purposes of this Standards Publication is to encourage the production of reliable control equipment which, in itself, functions in accordance with these accepted standards. Some portions of these standards, such as electrical spacings and interrupting ratings, have a direct bearing on safety; almost all of the items in this publication, when applied properly, contribute to safety in one way or another.

Properly constructed industrial control equipment is, however, only one factor in minimizing the hazards which may be associated with the use of electricity. The reduction of hazard involves the joint efforts of the various equipment manufacturers, the system designer, the installer and the user. Information is provided herein to assist users and others in the proper selection of control equipment.

The industrial control manufacturer has limited or no control over the following factors which are vital to a safe installation:

a. Environmental conditions
b. System design
c. Equipment selection and application
d. Installation
e. Operating practices
f. Maintenance

This publication is not intended to instruct the user of control equipment with regard to these factors except insofar as suitable equipment to meet needs can be recognized in this publication and some application guidance is given.

This Standards Publication is necessarily confined to defining the construction requirements for industrial control equipment and to providing recommendations for proper selection for use under normal or certain specific conditions. Since any piece of industrial control equipment can be installed, operated, and maintained in such a manner that hazardous conditions may result, conformance with this publication does not by itself assure a safe installation. When, however, equipment conforming with these standards is properly selected and is installed in accordance with the National Electrical Code and properly maintained, the hazards to persons and property will be reduced.

To continue to serve the best interests of users of Industrial Control and Systems equipment, the Industrial Automation Control Products and Systems Section is actively cooperating with other standardization organizations in the development of simple and more universal metrology practices. In this publication, the U.S. customary units are gradually being supplemented by those of the modernized metric system known as the International Systems of Units (SI). This transition involves no changes in standard dimensions, tolerances, or performance specifications.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

NEMA Standards Publications are subject to periodic review. They are revised frequently to reflect user input and to meet changing conditions and technical progress. Proposed revisions to this Standards Publication should be submitted to:

Vice President, Engineering Department
National Electrical Manufacturers Association
1300 North 17th Street, Suite 1847
Rosslyn, Virginia 22209

This standards publication was developed by the Industrial Automation Control Products and Systems Section. Section Approval of the standard does not necessarily imply that all section members voted for its approval or participated in its development. At the time it was approved, the Section was composed of the following members:

ABB Control, Inc.—Wichita Falls, TX
AEG Automation Systems Corporation—Pittsburgh, PA
Allen-Bradley Company—Milwaukee, WI
Amerace Electronics Components—Punta Gorda, FL
Automatic Switch Company—Florham Park, NJ
Balluff, Inc.—Florence, KY
USD Products, Bussman, Div. of Cooper Ind.—Chicago, IL
CEGELEC Automation—Macon, GA
Eaton Corporation, Cutler-Hammer Products—Milwaukee, WI
Echelon—Palo Alto, CA
Electrical Power Systems, Inc.—Tulsa, OK
Electro Switch Corporation—Weymouth, MA
Elliott Control Company—Hollister, CA
Emerson Electric Company—Grand Island, NY
Entrelec, Inc.—Irving, TX
Firetrol, Inc.—Cary, NC
Furnas Electric Company—Batavia, IL
GE—Plainville, CT
General Equipment & Manufacturing Company, Inc.—Louisville, KY
Gettys Corporation—Racine, WI
Giddings & Lewis, Inc.—Fond du Lac, WI
Harnischfeger Corporation—Milwaukee, WI
Honeywell, Inc.—Ft. Washington, PA
Hubbell Incorporated—Madison, OH
Joslyn Clark Controls, Inc.—Lancaster, SC
Killark-Stahl, Inc.—St. Louis, MO
Klockner-Moeller Corporation—Franklin, MA
Lexington Switch & Controls—Madison, OH
Master Controls Systems, Inc.—Lake Bluff, IL
Metron, Inc.—Denver, CO
Micro Switch (Div. of Honeywell)—Freeport, IL
Omron Electronics, Inc.—Schaumburg, IL
Onan Corporation—Minneapolis, MN
OZ Gedney, Unit of General Signal Corp.—Brooklyn, NY
Pepperl & Fuchs, Inc.—Twinsburg, OH
Phoenix Contact, Inc.—Harrisburg, PA
Reliance Electric Company—Cleveland, OH
Russelectric, Inc.—Hinngham, MA
Siemens Energy & Automation, Inc.—Alphrata, GA
Square D Company—Palatine, IL
R. Stahl, Inc.—Woburn, MA

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Texas Instruments, Inc.—Attleboro, MA
Toshiba International Corporation—Houston, TX
Turck, Inc.—Minneapolis, MN
Zenith Controls, Incorporated—Chicago, IL

DISCLAIMER

The standards or guidelines presented in a NEMA standards publication are considered technically sound at the time they are approved for publication. They are not a substitute for a product seller's or user's own judgment with respect to the particular product referenced in the standard or guideline, and NEMA does not undertake to guarantee the performance of any individual manufacturer's products by virtue of this standard or guide. Thus, NEMA expressly disclaims any responsibility for damages arising from the use, application, or reliance by others on the information contained in these standards or guidelines.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Part 1
GENERAL STANDARDS FOR MANUAL AND MAGNETIC CONTROLLERS

1 GENERAL

1.1 Referenced Standards

The following standards contain provisions, which through reference in this text, constitute provisions of this NEMA Standards Publication. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below.

American National Standards Institute
11 West 42nd Street
New York, NY 10036

C37.90-1989 *Relays and Relay Systems Associated with Electrical Power Apparatus*

U.S. Government Printing Office
Mail Stop: SSOP,
Washington, DC 20402-9328

Code of Federal Regulations *Occupational Safety and Health Standards (OSHA)*

29 CFR 1910.147 *Control of Hazardous Energy Sources (Lockout/Tagout)*

National Electrical Manufacturers Association
1300 North 17th Street, Suite 1847
Rosslyn, VA 22209

AB 1-1999 *Molded Case Circuit Breakers*

AB 3-1996 *Molded Case Circuit Breakers and Their Application*

ICS 1-2000 *Industrial Control and Systems General Requirements*

ICS 1.3-1986 (R 2001) *Preventive Maintenance of Industrial Control and Systems Equipment*

ICS 6-1993 (R2001) *Enclosures for Industrial Control and Systems*

KS 1-1996 *Enclosed and Miscellaneous Distribution Equipment Switches (600 Volts Maximum)*

MG 1-1999 *Motors and Generators*

MG 2-1989 (R1999) *Safety Standard for Construction and Guide for Selection, Installation, and Use of Electric Motors and Generators*

Underwriters Laboratories Inc.
333 Pfingsten Road
Northbrook, IL 60062

UL 508-1999 *Industrial Control Equipment (17th Ed)*

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

National Fire Protection Association
1 Batterymarch Park
Quincy, MA 02269

ANSI/NFPA 70-1999 *National Electrical Code*

1.2 Scope

The standards in this part apply to power circuit devices covered in all other parts in ICS 2 pertaining to power circuit devices unless otherwise specified.

1.3 Normative References

The definitions and standards of NEMA Standards Publication ICS 1 also apply to this part unless otherwise stated.

2 DEFINITIONS

For the purposes of this standard, the following definitions apply:

short-time operating capability: The ability of a motor controller with its contacts closed, to withstand the thermal stresses due to starting and accelerating a motor to normal speed and those due to an operating overload.

short-time surge capability: The ability of a motor controller with its contacts closed, to withstand the thermal and mechanical stresses due to current surges, such as might result from restoration of power to the load following a momentary loss of power.

3 CLASSIFICATION OF MANUAL AND MAGNETIC CONTROLLERS

Controllers shall be designated as Class A, B, or V in accordance with the interrupting medium and their ability to interrupt currents.

These controllers are designed for interrupting operating overloads only. For definition of operating overload, see NEMA Standards Publication ICS 1.

In general, manual controllers are limited to 600 volts or less. A controller may be a combination of manually and magnetically operated components.

3.1 Class A Controllers

Class A controllers are alternating current air-break, vacuum-break or oil-immersed manual or magnetic controllers for service on 600 volts or less. They are capable of interrupting operating overloads but not short circuits or faults beyond operating overloads. For standards applying to these controllers, see Parts 2, 3 and 6.

3.2 Class B Controllers

Class B controllers are direct current air-break manual or magnetic controllers for service on 600 volts or less. They are capable of interrupting operating overloads but not short circuits or faults beyond operating overloads. For standards applying to these controllers, see Part 5.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

3.3 Class V Controllers

Class V controllers are alternating current vacuum-break magnetic controllers for service on 1500 volts or less, and capable of interrupting operating overloads but not short circuits or faults beyond operating overloads.

4 CHARACTERISTICS AND RATINGS

See product parts of this publication for characteristics and ratings.

5 PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION

5.1 Maintenance

See NEMA Standards Publication ICS 1.3 for preventive maintenance instructions.

5.2 Marking

Where the mark NEMA is shown on a magnetic or manual contactor or controller, or appears on any supportive material supplied with that device, the product shall comply with all of the ratings for that device as defined in the standard for that device.

Where a device is marked with a NEMA size designation, a marking shall include, at a minimum, all of the 60 hertz horsepower ratings for that device as given in the single-phase or three-phase, nonplugging and nonjogging duty rating table.

The manufacturer shall be permitted to mark additional ratings for that size provided that only those ratings specified in the appropriate NEMA product standard for that size are used.

References to standards other than NEMA, on products carrying the “NEMA” mark are permitted, provided that all ratings referencing such standards are identical to those marked as the NEMA ratings and provided that the product complies with all ratings for that device, as defined in the NEMA standard for that device.

6 SERVICE AND STORAGE CONDITIONS

See ICS 1, Part 6.

7 CONSTRUCTION

7.1 Sizes of Terminals for External Power Connections

Manual and magnetic controllers shall have terminals suitable for connection to external copper conductors, shown in Table 1-7-1, the insulation of which is rated either 60° or 75°C.

NOTE: The maximum wire size shown is for a 40° C ambient based on the ampacity required for service -limit current corresponding to the controller size. The minimum wire size shown is for 75° C insulation in a 30 ° C ambient and minimum motor full-load current corresponding to horsepower.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

7.2 Mechanical Interlocking of Manual and Magnetic Contactors

Contactors which would cause a line-to-line fault if they are in the closed position at the same time shall be mechanically interlocked to prevent this condition.

7.3 Electrical Interlocking of Magnetic Contactors

Two or more magnetic contactors which would cause a line-to-line fault if they were in the closed position at the same time shall be electrically interlocked by means of normally-closed auxiliary contacts connected in series with their coils.

8 PERFORMANCE REQUIREMENTS AND TESTS

8.1 Make and Break Design Test

The make and break design test for Class A manual and magnetic motor controllers shall be 10 times the rated motor full-load current (MFLC) for 10 operations in a single continuous test, without intervening maintenance or servicing, at a maximum rate of one operation per minute with a minimum ON time of 0.1 second. Ten times MFLC is not a rating.

In performing the above test, a new motor controller shall be used with a motor or a simulated motor load consisting of resistors in series with air-core reactor(s) for each phase. The air-core reactors shall not be connected in parallel with any other resistors or reactors, except that the reactor(s) in each phase may be shunted by a resistor having a power loss of approximately one percent of the total power consumption of the phase. This test shall be made at rated voltage and a power factor of 40 to 50 percent.

8.2 Range of Coil Operating Voltage

8.2.1 Contactors with DC Coils

Contactors with DC coils shall withstand 110 percent of their rated voltage continuously without injury to the operating coils and shall close successfully at 80 percent of their rated voltage.

8.2.2 Contactors with AC Coils

Contactors with AC coils shall withstand 110 percent of their rated voltage continuously without injury to the operating coils and shall close successfully at 85 percent of their rated voltage.

Where the coil of a controller is operated from the secondary of a control-circuit transformer having its primary connected to the supply circuit of the controller, the controller shall withstand 110 percent of its rated voltage without injury to the operating coil and shall operate successfully at 90 percent of the rated voltage of the supply circuit. See ICS 1, Clause 8.

8.3 Short-Time Capability Tests

Separate tests shall be conducted to establish short-time operating capability and short-time surge capability. The test current shall be passed through the closed contacts for the specified period of time, and must be supplied at a voltage sufficient to maintain the current. At the end of the tests:

a. The motor controller must be capable of withstanding the dielectric tests described in ICS 1, Clause 8.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

b. The contacts must be capable of being opened by normal operation.

A separate source of power may be supplied to the coils of magnetically operated devices.

8.4 Temperature Rise Test of Coils and Current-Carrying Parts

The temperature rise of the coils and current-carrying parts of contactors and controllers shall be measured simultaneously when tested in accordance with their ratings. The values shall not exceed those given in ICS 1, Clause 8.

9 APPLICATION

9.1 Estimated short-circuit performance

The I^2t value (Joule Integral) calculated from the surge capability test cannot be used to estimate the performance of the contactor under short-circuit conditions.

9.2 Control-Circuit Transformers

Transformers used to provide control-circuit voltage to magnetic controllers are known as machine-tool transformers in NEMA Standards Publications.

9.2.1 Transformers used with magnetic controllers shall meet the following requirements:

a. The rated primary voltage of the transformer shall be equal to the system voltage.

Exception: Transformers with a higher voltage rating than the system voltage shall be permitted to be used, but only if the following calculation results in a value of control voltage equal to the rated control voltage of the controller.

$$\text{System Voltage X } \frac{\text{Rated Transformer Secondary Voltage}}{\text{Rated Transformer Primary Voltage}} = \text{Rated Control Circuit}$$

b. The rated secondary voltage of the transformer shall be equal to the rated control-circuit voltage of the controller.

9.2.2 The size and design of the transformer shall be such as to limit the amount the secondary voltage variations above and below the rated control-circuit voltage, under conditions of minimum and maximum currents, as defined below.

a. At Minimum Current

With rated primary voltage and frequency applied to the transformer, and with the sealed current of a single load, or the sealed or continuous current of the lightest load that may occur with a multiplicity of loads, the secondary voltage shall not be greater than 105 percent of the rated control-circuit voltage.

--`,,`,,`,,`,,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

This condition is satisfied if the open-circuit secondary voltage does not exceed 105 percent of rated secondary voltage, with rated primary voltage and frequency applied to the transformer.

b. At Maximum Current (Peak Inrush)

The effective impedance of the transformer shall be such that, with rated voltage and frequency applied to the transformer and with a load impedance corresponding to the power factor and maximum value of the load current connected to the secondary, the voltage at the secondary terminals shall not be less than 95 percent of the rated voltage of the operating coils.

This condition assures compliance with this part where individual contactors which close successfully at 85 percent of rated voltage applied directly to the contactor coil will, when operated from the secondary of a transformer, close successfully at 90 percent of rated transformer primary voltage.

Table 1-7-1
TERMINALS FOR NEMA RATED MOTOR CONTROLLERS

Size of Controller	Minimum Range of Conductor Sizes* (One Conductor per Terminal Unless Otherwise Stated) For Conductor Insulation Rated 60°C	For Conductor Insulation Rated 75°C
00	14	14
0	14-10	14-10
1	14-8	14-8
1P	8-6	10-8
2	10-4	10-6
3	8-1/0	8-1
4		4-3/0
5		2/0 AWG - 500 kcmil
6		Two 2/0 AWG - 500 kcmil
7		Three 2/0 AWG - 500 kcmil
8**		
9**		

*For controller Size 5 and larger, a combination of parallel conductors that provide the ampacity equivalent to the wire sizes shown shall be permitted.
** Busbar or cable-connected, as specified between control manufacturer and user.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Part 2
AC NONCOMBINATION MAGNETIC MOTOR CONTROLLERS RATED 600 VOLTS

1 GENERAL

1.1 Scope

The standards in this part apply to Class A noncombination magnetic controllers for squirrel cage and wound-rotor induction motors rated in horsepower and in full-load and locked-rotor currents for application at 600 volts and less, 50 and 60 hertz. The contactor portion of these controllers may also be used to control nonmotor loads.

1.2 Normative References

The definitions and standards of NEMA Standards Publications No. 250, ICS 1 and ICS 2, Part 1 apply to this part unless otherwise stated.

2 DEFINITIONS

There are no definitions unique to this part.

3 CLASSIFICATION

3.1 Classification by Starting Methods

Motor controllers are classified as either full-voltage or reduced-voltage starting. Typical methods of controlling motors are shown in Figures 2-3-1 through 2-3-7. An "X" in the contactor sequence chart indicates closed contacts. The starting current values for the various methods of motor starting may be determined as shown below.

3.2 Full-Voltage Controllers

The starting current for full-voltage controllers is equal to the locked-rotor current at full voltage; see Figure 2-3-1.

3.3 Part-Winding Controllers

Part-winding controllers first connect a part of the motor winding to the supply lines as the first starting step and then connect the remaining portion of the winding to the supply lines as the second step. Part-winding controllers are classified as either full-voltage or reduced-voltage type, the reduced voltage being obtained by the use of a resistor or reactor connected in series with the first-mentioned portion of the winding.

3.3.1 Full-Voltage Part-Winding Controllers

Enclosed, limited plugging and jogging-duty, full-voltage controllers for motors suitable for part-winding starting, shall consist of:

a. A magnetic contactor used to connect one part of the motor winding to the supply lines.

b. A magnetic contactor used to connect a second part of the motor winding to the supply lines.

c. Means to delay the closing of the second contactor.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

d. Running overcurrent protection for each motor winding unless equivalent protection is otherwise provided for the motor, the motor control apparatus and the branch-circuit conductors against excessive heating due to motor overloads.

e. Provision for separately mounted control pushbuttons.

With full-voltage part-winding starting (Figure 2-3-2), the starting current is the locked-rotor current of the first winding connected for starting.

3.3.2 Pole Arrangements for Part-Winding Controllers

For one-half winding starting of motors having equal windings that are wye connected with either six or nine leads brought out and for motors that are delta connected with six leads brought out, the controller shall have either a three-pole contactor for the first part of the winding and another three-pole contactor for the second part, or a four-pole contactor for the first part of the winding and a two-pole contactor for the second part.

For two-thirds winding starting of motors having equal windings that are wye connected with either six or nine leads brought out and for motors that are delta connected with either six or nine leads brought out, the controller shall have a four-pole contactor for the first part of the winding and a two-pole contactor for the second part.

3.4 Full-Voltage Two-Speed Motor Controllers

A single-winding two-speed motor carries current in various configurations of wye and delta to provide either constant torque, variable torque, or constant horsepower at each speed. A two-winding two-speed motor carries current in only one of its windings at each speed. Each winding may be either a wye or delta configuration. To preclude short-circuit current being induced in an unused delta winding, motor controllers used with two-winding motors having one or more delta connections are constructed to open one corner of each delta winding not in the circuit.

NOTE: When controllers are to be supplied for more than two speeds, NEMA Standards Publication MG 1 should be consulted.

Motor connections for two-speed motor controllers shall be in accordance with Figures 2-3-3 and 2-3-4 for two-winding and single-winding motors, respectively.

3.5 Reduced-Voltage Controllers

Typical forms of reduced-voltage controllers are:

a. reactor or resistor

b. wye-delta

c. part-winding

d. autotransformer

3.5.1 Reactor or Resistor Reduced-Voltage Starting

With reactor or resistor starting (Figure 2-3-5), the starting current is determined from the phasor sum of the impedances of the starting reactor or resistor and of the motor under locked-rotor conditions.

--`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

3.5.2 Wye-Delta Controllers

Wye-delta controllers connect the phase windings first in wye relationship for the effect of reduced-voltage starting and, subsequently, reconnect these phase windings in delta relationship for running. The types of wye-delta controllers for induction motors shall be: open-circuit transition or closed-circuit transition.

With wye-delta starting (Figure 2-3-6), the starting current on the wye connection is equal to 0.33 times the locked-rotor current on the delta connection.

3.5.2.1 Open-Circuit Transition

These are enclosed, nonplugging, nonjogging controllers for the effect of reduced-voltage starting of motors by the open-circuit-transition method, consisting of:

a. Two three-pole magnetic contactors, 1M and 2M, for the line connections to the motor

b. One two-pole magnetic contactor, S, where the S contactor is the same size as the 1M and 2M contactors, or a three-pole contactor where the S contactor is one size smaller than the 1M and 2M contactors for the wye neutral connection

c. One means (timing) for maintaining the wye (starting) connection for a predetermined accelerating time

d. One set of mechanical and electrical interlocks to prevent closing 2M before S opens

e. Three overload units,* one in each phase winding, unless equivalent protection is otherwise provided for the motor, the motor control apparatus and the branch-circuit conductors against excessive heating due to motor overloads

f. Provision for separately mounted control pushbuttons

* Phase current is 0.577 times the line current.

3.5.2.2 Closed-Circuit Transition

These are enclosed, nonplugging and nonjogging controllers for the effect of reduced-voltage starting of motors by the closed-circuit-transition method, consisting of:

a. Two three-pole magnetic contactors, 1M and 2M, for the line connections to the motor

b. One two-pole magnetic contactor, 1S, where the 1S contactor is the same size as the 1M and 2M contactors, or a three-pole contactor where the 1S contactor is one size smaller than the 1M and 2M contactors for the wye neutral connection

c. One three-pole magnetic contactor, 2S, for the transition resistor connections

d. One transition resistor for each phase

e. One means (timing) for maintaining the wye (starting) connection for a predetermined accelerating time

f. One set of mechanical and electrical interlocks to prevent closing 2M before 1S opens

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

g. Three overload units,* one in each phase winding, unless equivalent protection is otherwise provided for the motor, the motor control apparatus and the branch-circuit conductors against excessive heating due to motor overloads

h. Provision for separately mounted control pushbuttons

* Phase current is 0.577 times the line current.

3.5.3 Reduced-Voltage Part-Winding Controllers

These are enclosed, limited plugging and jogging, reduced-voltage controllers for motors suitable for part-winding starting, consisting of:

a. A magnetic contactor used to connect one part of the motor winding to the supply lines

b. A resistor or reactor connected into the circuit of this motor winding

c. A magnetic contactor used to short-circuit the resistor or reactor

d. A magnetic contactor used to connect a second part of the motor winding to the supply lines

e. Means to delay the closing of the contactors covered in items c. and d. above

f. Running overcurrent (overload) protection for each motor winding, unless equivalent protection is otherwise provided for protecting the motor, the motor control apparatus and the branch-circuit conductors against excessive heating due to motor overloads

g. Provision for separately mounted control pushbuttons

3.5.4 Reduced-Voltage Autotransformer Controllers

These are enclosed, nonplugging nonjogging reduced-voltage controllers, where the reduced voltage is provided by a three-coil or two-coil autotransformer. The autotransformer controllers shall be open-circuit transition or closed-circuit transition.

With reduced-voltage autotransformer starting (Figure 2-3-7), the starting current is determined as follows:

a. The starting current drawn from line = $I \times p^2 + 0.25\ I_{m.}$

b. The starting current taken by the motor = $I \times p$.

c. The autotransformer neutral current = $I \times p - (I \times p^2 + 0.25\ I_m)$

Where:

I = Locked-rotor amperes at full voltage

p = Transformer tap used (fraction of full voltage)

I_m = Rated full-load current of motor. The term “0.25 Im” is introduced to allow for transformer magnetizing current

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

4 CHARACTERISTICS AND RATINGS

4.1 Horsepower and Current Ratings

4.1.1 Continuous Current Ratings

Continuous current ratings represent the maximum rms current, in amperes, which the controller shall be permitted to carry continuously without exceeding the temperature rises permitted by ICS 1, Clause 8.

4.1.2 Service-Limit Current Ratings

The service-limit current ratings represent the maximum rms current, in amperes, which the controller shall be permitted to carry for protracted periods in normal service. At service-limit current ratings, temperature rises shall be permitted to exceed those obtained by testing the controller at its continuous current rating. The current rating of overload relays or trip current of other motor protective devices used shall not exceed the service-limit current rating of the controller.

4.1.3 Basis of Horsepower and Current Ratings

The horsepower and current ratings of AC general-purpose controllers are based on the use of three-pole primary contactors for two- and three-phase motors and of two-pole primary contactors for single-phase motors.

4.1.4 Ratings of Full-Voltage Single-Speed Magnetic Controllers for Limited Plugging and Jogging Duty

The ratings of full-voltage magnetic controllers for limited plugging and jogging, reversing and nonreversing, duty shall be:

a. In accordance with Table 2-4-1 for three-phase controllers.

b. In accordance with Table 2-4-2 for single-phase controllers.

These ratings shall be permitted to be used for occasional jogging or plugging for limited time periods, such as machine set-ups. During such limited time periods, the rate of operation shall not exceed five openings or closings per minute and shall be not more than ten in a 10-minute period.

For duties exceeding the foregoing, see 4.1.5.

These controllers shall not be used with motors whose full-load current, locked-rotor current, or horsepower rating exceeds the values given in Tables 2-4-1 and 2-4-2. The current rating of overload relays or the trip current of other motor protective devices used shall not exceed the service-limit current rating of the controller.

The full-load current, locked-rotor current or horsepower ratings of two-phase four-wire and two-phase three-wire controllers shall be the same as those shown in Table 2-4-1 for three-phase controllers. Controllers used in two-phase three-wire circuits shall be applied on the basis of the average of the currents in the three legs of the two-phase circuit.

4.1.5 Ratings of Full-Voltage Single-Speed Magnetic Controllers for Plug-Stop, Plug-Reverse or Jogging Duty

The rating of full-voltage magnetic controllers for plug-stop, plug-reverse, and jogging duty requiring repeated interruption of stalled motor current or repeated closing of high transient currents encountered in rapid motor reversal beyond that described in 4.1.4 shall be in accordance with:

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

a. Table 2-4-3 for three-phase controllers

b. Table 2-4-4 for single-phase controllers

These controllers shall not be used with motors whose full-load current, locked-rotor current, or horsepower rating exceeds the values given in Tables 2-4-3 and 2-4-4. The current rating of overload relays or the trip current of other motor protective devices used shall not exceed the service-limit current rating of the controller.

The full-load current, locked-rotor current or horsepower ratings of two-phase four-wire and two-phase three-wire controllers shall be the same as those shown in Table 2-4-3 for three-phase controllers. Controllers used on two-phase three-wire circuits shall be applied on the basis of the average of the currents in the three legs of the two-phase circuit.

4.1.6 Ratings of Reduced-Voltage General-Purpose Controllers

Reduced-voltage general-purpose controllers include primary resistor controllers, autotransformer controllers, and reactor controllers.

The ratings of reduced-voltage general-purpose reversing or nonreversing controllers, when mounted in any type of enclosure and whether or not provided with running overcurrent (overload) protection or other auxiliary devices, shall be in accordance with:

a. Table 2-4-5 for three-phase controllers

b. Table 2-4-6 for single-phase controllers

These controllers shall not be used with motors whose full-load current, locked-rotor current, or horsepower rating exceeds the values given in Tables 2-4-5 and 2-4-6. The current rating of overload relays or the trip current of other motor protective devices used shall not exceed the service-limit current rating of the controller.

The horsepower ratings of two-phase four-wire and two-phase three-wire controllers shall be the same as those shown in Table 2-4-5 for three-phase controllers. Controllers used on two-phase three-wire circuits shall be applied on the basis of the average of the currents in the three legs of the two-phase circuit.

The accelerating contactor of single-step two-point controllers shall be of the same size as the line contactor when the line contactor is Size 4 or smaller. When the line contactor is Size 5 or larger, an accelerating contactor of the next smaller size shall be permitted to be used.

Accelerating contactors for multistep controllers and for increment (network) controllers shall be selected so that the rating for each resistor step will be not less than one-sixth times the maximum rms current for that step.

Resistors for controllers with automatic acceleration shall be Class Number 116 except where the application requires the use of other duty resistors. See ICS 9, Part 2.
For refrigeration and air-conditioning applications, the controller shall be suitable for a duty cycle of:

a. For Primary Resistor- and Reactor-type Controllers—One start per hour not to exceed 30 seconds.

b. For Autotransformer-type Controllers:

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Tap Percent	Start After 5 Hours or Longer Shutdown, Not to Exceed	One Start per Hour, Not to Exceed
50 to 65	90 seconds	60 seconds
80	45 seconds	30 seconds

4.1.7 Ratings of Wye-Delta Magnetic Controllers

The full-load current, locked-rotor current, or horsepower ratings of wye-delta magnetic controllers shall be in accordance with Table 2-4-7.

4.1.8 Ratings of Part-Winding Controllers

The horsepower ratings for full-voltage, part-winding controllers shall be in accordance with Table 2-4-8.

The current ratings for full-voltage, part-winding controllers shall be in accordance with Table 2-4-9.

The horsepower ratings for reduced-voltage, part-winding controllers shall be in accordance with Table 2-4-10.

The current ratings for reduced-voltage, part-winding controllers shall be in accordance with Table 2-4-11.

4.1.9 Ratings of Three-Phase Multispeed Controllers for Limited Plugging and Jogging Duty

4.1.9.1 For Constant-Torque and Variable-Torque Motors (Two, Three and Four Speeds)

For limited plugging and jogging duty the ratings of these controllers shall be in accordance with Table 2-4-12. These controllers shall not be used with motors whose full-load current or horsepower ratings exceed the continuous current or horsepower ratings given in Table 2-4-12. The current rating of overcurrent overload relays or the trip current of other motor protective devices used shall not exceed the service-limit current rating of the controller.

4.1.9.2 For Constant-Horsepower Motors (Two, Three and Four Speeds)

The ratings of these controllers for limited plugging and jogging, reversing and nonreversing duty, requiring five or less openings per minute, when mounted in any type of enclosure and whether or not provided with running overcurrent (overload) protection or other auxiliary devices, shall be in accordance with Table 2-4-13.

4.1.10 Ratings of Three-Phase Controllers for Plug-Stop, Plug-Reverse or Jogging Duty

The ratings of controllers for constant-torque, variable-torque and constant-horsepower motors for plug-stop, plug-reverse or jogging duty shall be in accordance with 4.1.5 and Table 2-4-3.

4.1.11 Ratings of Primary Contactors of Magnetic Wound-Rotor Motor Controllers for Reversing and Nonreversing Duty

The ratings of primary contactors of wound-rotor motor controllers for reversing and nonreversing duty, when mounted in any type of enclosure and whether or not provided with running overcurrent (overload) protection or other auxiliary devices, shall be as shown in Table 2-4-14.

These controllers shall not be used with motors whose full-load current or horsepower rating exceeds the continuous current or horsepower rating given in Table 2-4-14. The current rating of overload relays or the

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

trip current of other motor protective devices used shall not exceed the service-limit current rating of the controller.

The horsepower ratings of two-phase four-wire and two-phase three-wire controllers shall be the same as those shown in Table 2-4-14.

Controllers used on two-phase three-wire circuits shall be applied on the basis of the average of the currents in the three legs of the two-phase circuit.

4.1.12 Service Classification of Resistors for Wound-Rotor Motor Secondary Circuits

Resistors for controllers with automatic acceleration shall be Class No. 135 or 136 except where the application requires the use of other duty resistors. See ICS 9, Part 2.

4.1.13 Accelerating (Secondary) Contactors of Magnetic Wound-Rotor Motor Controllers for Reversing and Nonreversing Duty

For nonplugging reversing and nonreversing service, wound-rotor motor controllers shall be provided with the minimum number of accelerating contactors shown in Table 2-4-15.
Where a controller is used for reversing plugging service, one plugging contactor shall be added to the number of contactors required for acceleration.

The intermediate accelerating contactors and plugging contactors, where required for automatically accelerating contactors, shall be so selected that the rating will be not less than one-sixth times the maximum rms accelerating current for that step.

The final accelerating contactor shall be so selected that the continuous rating will be not less than the motor rated secondary current.

Where a three-pole accelerating contactor is connected in closed delta, its current rating shall be 150 percent of the current rating of the corresponding two-pole contactor connected in open delta.

4.2 Short-Circuit Current Ratings

Class A controllers (with a specified short circuit protective device) shall have one or more short-circuit current ratings expressed in maximum available fault current (rms symmetrical amperes) at the rated system voltage. The power factor (X/R ratio) shall be as given in UL 508. Standard short-circuit current ratings are shown in Table 2-4-16.

4.3 Nonmotor Load Applications—Ratings of the Contactor Portion of the Controllers

4.3.1 For Applications Other Than Capacitor Switching

For nonmotor loads other than capacitors the ratings shall be in accordance with Table 2-4-17.

These ratings are based on the use of two poles to control the load for single phase (Figure 2-4-1) or three poles to control the load for three phase (Figure 2-4-2) up to 600 volts maximum.

One pole may be used for single-pole control of a single-phase load where one line is grounded (Figure 2-4-3), and the maximum voltage rating is 300 volts.

4.3.2 For Capacitor Switching

Contactors are used to switch capacitors under three general conditions:

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

a. In association with a motor for individual motor power factor correction

b. To switch a single capacitor or single capacitor bank into and out of an electrical distribution system

c. To switch a single capacitor or single capacitor bank into and out of an electrical distribution system which has other capacitor banks already operating in the system

The kilovar ratings of enclosed, three-phase, AC, low-voltage contactors employed as magnetic switches for power capacitor loads, where only one such load appears on the secondary of a distribution system, shall be as shown in Tables 2-4-18 through 2-4-20. See 9.3 for application information.

Where more than one capacitor load appears on the secondary of a distribution system, contactors may be applied in accordance with Tables 2-4-18 through 2-4-20 provided the capacitor surge current does not exceed the maximum shown in Table 2-4-17 for the contactor size.

Contactors used in capacitor circuits where there is a high available fault current should be protected by suitable short-circuit protective means.

5 PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION

5.1 General Maintenance

A maintenance program and schedule should be established to meet the needs of each particular installation to assure minimum down time. The program should include, for example, tightening connections, inspecting for evidence of overheating, removing dust and dirt, and replacing contacts when worn or when the contact follow-up and pressure have been reduced to a level which might impair the operation of the equipment.

See ICS 1.3 for preventive maintenance instructions.

5.2 Maintenance After a Fault

Annex A of this publication covers the procedures to be followed in order to return to service a motor controller which has been subjected to a short circuit or a ground fault.

6 SERVICE AND STORAGE CONDITIONS

See ICS 1, Clause 6.

7 CONSTRUCTION

7.1 Control Transformer Overcurrent Protection

Where a stepdown transformer is provided in an AC controller to supply power to the control circuit, it shall be protected in accordance with the National Electrical Code, Section 430-72, or other applicable codes. Where overcurrent protection is provided in the secondary, it shall be located as shown in Figure 2-7-1.

7.2 Terminals and Connections

7.2.1 Terminal Markings for Full-Voltage Single-Speed Magnetic Controllers

All controllers shall be marked and wired in accordance with Table 2-7-1, where applicable.

--`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

The sequence of line and load terminal markings shall be L1, L2, L3, L4 and T1, T2, T3, T4, reading from left to right when looking at the front of the controller. If the leads come in to the left or right of the controller, then the sequence of lead numbering shall be the same as if the controller were rotated to these positions.

Where a STOP button is assembled with the controller, it may actuate the contacts of the overload relays.

Where a three-phase three-pole nonreversing full-voltage controller is used on a two-phase three-wire or two-phase four-wire application, Figure 2-7-2 or a suitable note, or a combination of both, should be used as a guide in making connections.

Control circuit contacts, such as those of pushbuttons, master switches, relays and interlocks, should be connected between L1 and associated coils. Exceptions include circuits controlled by double-pole contacts opening both sides of a circuit, motor running overcurrent device contacts, and electrical interlocks whose circuit wiring between coils and L2 does not extend beyond the controller enclosure.

Where terminals are provided for external START-STOP pushbutton switches for nonreversing controllers, the controller terminals shall be marked 1, 2 and 3 as indicated in Figure 2-7-3.

Control circuit markings for reversing controllers shall be 1, 2, 3, 4, 5, 6 and 7 and in accordance with Figure 2-7-4.

7.2.2 Terminal Markings for Part-Winding Magnetic Controllers

7.2.2.1 Controllers with Three-Pole Contactors

For controllers having three-pole contactors, the controller terminal markings shall be as follows:

a. For the section of the motor winding first connected to the supply lines: T1, T2, T3

b. For the other section of the motor winding: T7, T8, T9

7.2.2.2 Controllers with a Four-Pole and Two-Pole Contactor

For controllers having a four-pole contactor and a two-pole contactor, the controller terminal markings shall be as follows:

a. For the section of the motor winding first connected to the supply lines: A, B, C, D

b. For the other section of the motor winding: E, F

7.2.3 Control Circuit Terminal Markings for Two-Speed Magnetic Controllers

Magnetic controllers for two-speed motors shall have control circuit terminals marked in accordance with Figure 2-7-5.

7.3 Location of Overload Relay Contacts in Circuit

The contacts of overload relays are located as shown in Figures 2-7-3 and 2-7-4 so as to minimize the exposure of these contacts to fault currents which might weld them closed. Since these contacts are normally closed, a welded condition may remain undetected and result in the loss of running overcurrent protection. In the case of reversing and some other multiple contactor controllers, a single overload relay should be used to sense the state of the motor, regardless of the direction of rotation or the duty cycle.

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Analysis of Figure 2-7-4 reveals that the overload relay contacts can perform their function for both directions of rotation only if they are located as shown or connected on either side of the STOP button. However, if the overload relay contacts are located on either side of the STOP button, they may be exposed to a ground fault current in the remote control station wiring.

The foregoing applies to the control circuit shown in Figure 2-7-3 except that another location, to the left of the coil, is available. In this location, the risk of welding contacts is present when L2 is grounded, as it often is, and a short circuit occurs between the coil winding and grounded parts of the controller, which may be the case when a coil burns out.

8 PERFORMANCE REQUIREMENTS AND TESTS

8.1 General

Class A controllers shall meet the applicable test and performance requirements of Part 1 clause 8.

8.2 Performance Tests

Motor controllers shall be in accordance with Underwriters Laboratories Inc. Publication No. UL 508.

8.3 Short-Time Operating Capability

8.3.1 With Overload Relay

A new Class A controller with overload relay(s) shall be capable of meeting the requirements of Clause 8 of ICS 1 at 6.4 times the current rating of its highest rated overload relay for the time necessary for its overload relay to trip.

The factor 6.4 times current rating corresponds to eight times motor full load current for a service factor 1.15 motor protected at 125 percent.

8.3.2 Without Overload Relay

A new Class A Controller without overload relays shall be capable of meeting the requirements of Clause 8 of ICS 1 at 8 times the current corresponding to the horsepower rating of the contactor for 20 seconds.

8.4 Short-Time Surge Capability

8.4.1 With Overload Relay

A new Class A controller with overload relay(s) shall be capable of meeting the requirements of Clause 8 of ICS 1 at 12 times the current rating of its highest rated overload relay for 1 second or for the time necessary for its overload relay to trip, whichever is shorter.

The factor 12 times current rating corresponds to 15 times motor full-load current for a service factor 1.15 motor, protected at 125 percent.

For convenience of testing, the duration of the surge capability test shall be permitted to be shortened (to not less than 0.9 seconds) in order to suit the available test current provided that the value of the I^2t (Joule Integral) is maintained.

8.4.2 Without Overload Relay

A new Class A controller without overload relays shall be capable of meeting the requirements of Clause 8 of ICS 1 at 15 times rated continuous current for 1 second.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

For convenience of testing, the duration of the surge capability shall be permitted to be shortened (to not less than 0.9 seconds) in order to suit the available value of the test current provided that the value of the I^2t (Joule Integral) is maintained.

8.5 Design Test for Short-Circuit Current Ratings for Noncombination Controllers

Selected noncombination motor controllers and combination motor controllers which do not include short-circuit protection shall be tested to verify their ability to withstand short circuits. The short-circuit protective devices shall be selected in accordance with the National Electrical Code or the limitations marked on the controller by the manufacturer. Noncombination motor controllers shall be evaluated and marked in accordance with UL 508.
A manufacturer may determine that his designs meet the standard performance criteria by test or by a combination of test and calculation or interpolation.

9 APPLICATION

9.1 Selection of Pushbuttons for Use with Magnetic Controllers

See ICS 5, Part 5.

9.2 Nonmotor Load Applications

The following load characteristics should be considered when selecting contactors for nonmotor loads:

a. Maximum circuit-closing inrush current and duration

b. Maximum circuit-interrupting current, voltage, power factor and wave form

c. Frequency of operation and ON time

d. RMS current based on averaging time of duty cycle if other than continuous duty

Because of the endless variety of application conditions in terms of electrical loads, duty cycles, voltage fluctuations, mechanical vibration, environmental conditions, etc., contact life is not specified in these NEMA Standards. Manufacturers' recommendations should be obtained regarding specific applications.

9.3 Capacitor Applications

9.3.1 Motors with Power Factor Correction Capacitors

Capacitors used for power factor correction should be selected using the capacitor manufacturer's application data. The rating of such capacitors shall not exceed the value required to raise the no-load power factor of the motor to unity. Capacitors of these maximum ratings usually result in a full-load power factor of 0.95 to 0.98. Methods of connecting power factor correction capacitors are shown in Figure 2-9-1.

Where the capacitor is connected ahead of the overload relay (as shown in Figure 2-9-1, circuit a, c, or d), the overload relay current elements should be selected using the full-load motor current and service factor values specified on the nameplate of the motor. Where the capacitor is connected behind the overload relay (as shown in circuit b of Figure 2- 9-1), the overload relay manufacturer's instructions should be followed in selecting current elements, since the overload relay in this case will respond to the phasor sum of the motor and capacitor currents.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Power factor correction capacitors should be switched by a separate contactor (Figure 2- 9-1, circuit d) under any of the following conditions:

a. High-inertia load

b. Open-circuit transition reduced-voltage starting

c. Wye-delta motor

d. Reversing or frequently jogged motor

e. Multispeed motors

Also see MG 2.

9.3.2 Capacitor Bank Switching

When discharged, a capacitor has essentially zero impedance. For repetitive switching by contactors, sufficient impedance should be connected in series with the capacitor bank to limit the inrush current to not more than the maximum circuit closing inrush current from Table 2-4-17. In many installations, the impedance of connecting conductors may be sufficient for this purpose.

When switching to connect an additional bank, the banks already on the line may be charged and can supply additional available short-circuit current which should be considered when selecting impedance to limit the current.

9.3.3 Limiting Capacitor Surge Current

One method of limiting the surge current is to add inductance in the capacitor conductors. A simple air-core reactor may be made by forming a coil approximately 6 inches in diameter (ID), in each of the capacitor conductors, properly sized for the application. For systems voltages up to 250 volts, six turns have been found to be adequate; and for voltages up to 600 volts, eight turns have been found to be adequate.

9.3.4 Effects of Capacitors on Controller Applications

Where capacitors are connected directly across the terminals of an AC motor, on the load side of the motor overcurrent device, the controllers shall be applied in accordance with this standard. See Part 1.

Because of the resulting reductions in the current passing through the controller, the rating of the motor overcurrent device must be reduced to provide motor overload protection.

The motor manufacturer should be consulted as to the maximum permissible size of the capacitor and the proper rating of the motor overcurrent protective device.

9.4 Controller Comparisons

NEMA Standards Publication No. ICS 2.4 is a comparison of traditional NEMA Class A motor controllers and similar devices built to IEC standards.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-1

HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR THREE-PHASE, SINGLE-SPEED FULL-VOLTAGE MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY

Size of Controller	Continuous Current Rating (Amperes)	At 200V 60 Hz		At 230V 60 Hz		At 380 V 50 Hz		At 460V– 60Hz		At 575 V 60Hz		Service-Limit Current rating* (Amperes)
		Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	
00	9	1.5	46	1.5	40	1.5	30	2	25	2	20	11
0	18	3	74	3	70	5	64	5	53	5	42	21
1	27	7.5	151	7.5	140	10	107	10	88	10	70	32
2	45	10	255	15	255	25	255	25	210	25	168	52
3	90	25	500	30	500	50	500	50	418	50	334	104
4	135	40	835	50	835	75	835	100	835	100	668	156
5	270	75	1670	100	1670	150	1670	200	1670	200	1334	311
6	540	150	3340	200	3340	300	3340	400	3340	400	2670	621
7	810	…	…	300	5000	…	…	600	5000	600	4000	932
8	1215	…	…	450	7500	…	…	900	7500	900	6000	1400
9	2250	…	…	800	13400	…	…	1600	13400	1600	10700	2590

* See clause 4.1.2

Table 2-4-2

HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR SINGLE-PHASE FULL-VOLTAGE MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING DUTY, 50 OR 60 HZ

Size of Controller	Continuous Current rating (Amperes)	115 Volts		230 Volts		Service Limit Current Rating* (Amperes)
		Hp	LRA	Hp	LRA	
00	9	1/3	50	1	45	11
0	18	1	80	2	65	21
1	27	2	130	3	90	32
1P	36	3	140	5	135	42
2	45	3	250	7.5	250	52
3	90	7.5	500	15	500	104

* See clause 4.1.2.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-3

HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR THREE-PHASE, SINGLE-SPEED, FULL-VOLTAGE MAGNETIC CONTROLLERS FOR PLUG-STOP, PLUG-REVERSE OR JOGGING-DUTY

Size of Controller	Continuous Current Rating	200 V - 60 Hz		230 V - 60 Hz		380 V - 50 Hz		460 V - 60 Hz		575 V 60 Hz		Service Limit Current Rating*
	Amperes	Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	Amperes
0	18	1.5	46	1.5	40	1.5	30	2	25	2	20	21
1	27	3	74	3	70	5	63	5	52	5	42	32
2	45	7.5	175	10	175	15	154	15	127	15	102	52
3	90	15	335	20	335	30	300	30	250	30	200	104
4	135	25	500	30	500	50	500	60	500	60	400	156
5	270	60	1250	75	1250	125	1250	150	1250	150	1000	311
6	540	125	2500	150	2500	250	2500	300	2500	300	2000	621

* See clause 4.1.2.

Table 2-4-4

HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR SINGLE-PHASE FULL-VOLTAGE MAGNETIC CONTROLLERS FOR PLUG-STOP, PLUG REVERSE, OR JOGGING DUTY 50 OR 60 HERTZ

Size of Controller	Continuous Current Rating	at 115 Volt		at 230 Volt		Service Limit Current rating*
	Amperes	Hp	LRA	Hp	LRA	Amperes
0	18	1/2	53	1	43	21
1	27	1	87	2	60	32
1P	36	1-1/2	93	3	90	42
2	45	2	150	5	150	52
3	90	5	300	10	300	104

* See clause 4.1.2.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-5

HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR THREE-PHASE, REDUCED-VOLTAGE MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY

Size of Controller	Continuous Current Rating Amperes	At 200V-60HZ		At 230V-60HZ		At 380V-50HZ		At 460V-60HZ		At 575V-60HZ		Service Limit Current Rating*
		Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	Amperes
1	27	7.5	152	7.5	140	10	107	10	88	10	70	32
2	45	10	255	15	255	25	255	25	210	25	163	52
3	90	25	500	30	500	50	500	50	418	50	334	104
4	135	40	835	50	835	75	835	100	835	100	668	156
5	270	75	1670	100	1670	150	1670	200	1670	200	1334	311
6	540	150	3340	200	3340	300	3340	400	3340	400	2670	621
7	810	---	---	300	5000	---	---	600	5000	600	4000	932
8	1215	---	---	450	7500	---	---	900	7500	900	6000	1400
9	2250	---	---	800	13400	---	---	1600	13400	1600	10700	2590

*See clause 4.1.2.

Table 2-4-6

HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR SINGLE-PHASE, REDUCED-VOLTAGE MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY 50 OR 60 HZ

Size of Controller	Continuous Current Rating (Amperes)	At 115V		At 230V		Service Limit Current Rating* (Amperes)
		Hp	LRA	Hp	LRA	
1	27	2	130	3	90	32
1P	36	3	140	5	135	42
3	45	3	250	7.5	250	52
4	90	7.5	500	15	500	104

*See clause 4.1.2.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-7
HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR WYE-DELTA MAGNETIC CONTROLLERS FOR EITHER OPEN OR CLOSED TRANSITION

Size of Controller	Continuous current rating (Amperes)	Contactor Size			At 200V -- 60HZ		At 230V -- 60HZ		At 380V -- 50HZ		At 460V -- 60HZ		At 575V -- 60HZ		Service Limit Current Rating*
		1M & 2M†	2 & 1S	2S	Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	
1YD	47	1	1	‡	10	263	10	242	15	185	15	152	15	121	55
2YD	78	2	2	‡	20	441	25	441	40	441	40	363	40	291	90
3YD	156	3	3	‡	40	866	50	866	75	866	75	725	75	578	179
4YD	135	4	4	‡	60	1445	75	1445	150	1445	150	1445	150	1155	270
5YD	270	5	5	‡	150	2510	150	2510	250	2510	300	2510	300	2000	538
6YD	540	6	6	‡	300	5020	350	5020	500	5020	700	5020	700	4000	1075
7YD	810	7	7	‡	500	8660	500	8660	800	8660	1000	8660	1000	6930	1610
8YD	1215	8	8	‡	750	13000	800	13000	1000	13000	1500	13000	1500	10400	2420
9YD	2250	9	9	‡	1500	23200	1500	23200	2000	23200	3000	23200	3000	18500	4480

*See clause 4.1.2.
†Each contactor 1M and 2M carriers only 0.577 times the motor line current when the motor is switched to the delta (running) connections. See clause 3.5.2 and Figure 2-3-6
‡Contactor 2S shall be capable of interrupting the current in the transition resistor circuit.

Table 2-4-8
HORSEPOWER (HP) RATINGS FOR THREE-PHASE FULL VOLTAGE PART-WINDING CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY 50 OR 60 HERTZ

Size of Controller	Continuous Current Rating Amperes	Contactor Size† 1M & 2M	Three-Phase Horsepower at ** 60 Hertz 200V	60 Hertz 230V	50 Hertz 380V	60 Hertz 460 or 575 V	Service Limit Current Rating* Amperes
1PW	54	1	10	15	15	15	64
2PW	90	2	20	25	40	40	104
3PW	180	3	40	50	75	75	208
4PW	270	4	75	75	150	150	312
5PW	540	5	150	150	250	350	622
6PW	1080	6	---	300	500	600	1242
7PW	1620	7	---	450	800	900	1867
8PW	2430	8	---	450	---	1400	2800
9PW	4500	9	---	1300	---	2600	5180

* See clause 4.1.2.
† Contactors 1M and 2M are each intended to carry one-half of the motor running line current. See clause 2.3.1. and figure 2-3-2.
** The horsepower ratings are based on locked-rotor currents corresponding to 65 percent of the full-winding values.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-9

CURRENT RATINGS FOR LIMITED PLUGGING AND JOGGING FULL-VOLTAGE POLYPHASE MAGNETIC CONTROLLERS FOR MOTORS SUITABLE FOR PART-WINDING STARTING

Size of Controller	Continuous Current Rating per Winding* Amperes	Contactor Size† 1M & 2M	Locked-Rotor Rating per Winding Amperes at					Service Limit Current Rating per winding, Amperes*
			60 Hertz 200 Volts	60 Hertz 230 Volts	50 Hertz 380 Volts	60 Hertz 460 Volts	60 hertz 575 Volts	
1PW	27	1	152	140	107	88	70	32
2PW	45	2	255	255	255	210	168	52
3PW	90	3	500	500	500	418	334	104
4PW	135	4	835	835	835	835	668	156
5PW	270	5	1670	1670	1670	1670	1334	311
6PW	540	6	---	3340	3340	3340	2670	621
7PW	810	7	---	5000	5000	5000	4000	932
8PW	1215	8	---	7500	---	7500	6000	1400
9PW	2250	9	---	13400	---	13400	10700	2590

*See clause 4.1.2

† Contactors 1M and 2M are each intended to carry one half of the motor running line current. See clause 3.3.1 and Figure 2-3-2.

NOTE – These ratings are established on a per-winding basis because, on part-winding starting, the locked-rotor current is considerably in excess of 50 percent of the total locked-rotor rating of the motor. The percentage varies over a wide range, depending on motor design.

Table 2-4-10

HORSEPOWER (HP) RATINGS FOR THREE-PHASE REDUCED-VOLTAGE PART-WINDING CONTROLLERS FOR LIMITED PLUGGING AND JOGGING DUTY

Size of Controller	Continuous Current Rating,*	Contactor Size		Three-Phase Horsepower at**				Service Limit Current Rating*
	Amperes	Line† (1M and 2M)	Accelerating	60 Hertz 200 Volts	60 Hertz 230 Volts	50 Hertz 380 Volts	60 Hertz 460 or 575 Volts	Amperes
1PW	54	1	1	10	10	15	15	64
2PW	90	2	2	20	25	40	40	104
3PW	180	3	3	40	50	75	75	208
4PW	270	4	4	75	75	150	150	312
5PW	540	5	4‡	150	150	250	350	622
6PW	1080	6	5‡	---	300	500	600	1242
7PW	1620	7	6‡	---	450	800	900	1864
8PW	2430	8	7‡	---	700	---	1400	2800
9PW	4500	9	8‡	---	1300	---	2600	5180

*See clause 4.1.2

†Contactors 1M and 2M are each intended to carry one half of the motor running line current. See clause 3.3.1 and Figure 2-3-2

‡The use of one size smaller accelerating contactor on sizes 5PW and larger is suitable when the contactor is shunted by its associated line contactor.

** The horsepower ratings are based on locked-rotor currents corresponding to 65 percent of the full-winding values.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-11

CURRENT RATINGS FOR LIMITED PLUGGING AND JOGGING REDUCED-VOLTAGE POLYPHASE MAGNETIC CONTROLLERS FOR MOTORS SUITABLE FOR PART-WINDING STARTING

Size of Controller	Continuous Current Rating, per Winding*	Contactor Size		Locked-Rotor Rating per Winding Amperes at					Service Limit Current Rating per Winding*
	Amperes	Line† (1M and 2M)	Accelerating	60 Hertz 200 Volts	60 Hertz 230 Volts	50 Hertz 380 Volts	60 Hertz 460 Volts	60 Hertz 575 Volts	Amperes
1PW	27	1	1	152	140	107	88	70	32
2PW	45	2	2	255	255	255	210	168	52
3PW	90	3	3	500	500	500	418	334	104
4PW	135	4	4	835	835	835	835	668	156
5PW	270	5	4‡	1670	1670	1670	1670	1334	311
6PW	540	6	5‡	---	3340	3340	3340	2670	621
7PW	810	7	6‡	---	5000	5000	5000	4000	932
8PW	1215	8	7‡	---	7500	---	7500	6000	1400
9PW	2250	9	8‡	---	13400	---	13400	10700	2590

*See clause 4.1.2

† Contactors 1M and 2M are each intended to carry one half of the motor running line current. See clause 3.3.1 and Figure 2-3-2.

‡The use of one size smaller accelerating contactor on sizes 5PW and larger is suitable when the contactor is shunted by its associated line contactor.

NOTE: These ratings are established on a per-winding basis because, on part-winding starting, the locked-rotor current is considerably in excess of 50 percent of the total locked-rotor current rating of the motor. The percentage varies over a wide range, depending on motor design.

Table 2-4-12

HORSEPOWER RATINGS FOR THREE-PHASE MULTISPEED MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY FOR CONSTANT-TORQUE AND VARIABLE-TORQUE MOTORS (TWO, THREE AND FOUR SPEED) 50 OR 60 HERTZ

		Horsepower†				
Size of Controller	Continuous Current Rating Amperes	60 Hertz 200V	60 Hertz 230V	50 Hertz 380V	60 Hertz 460 or 575V	Service Limit Current Rating, Amperes*
0	18	3	3	5	5	21
1	27	7.5	7.5	10	10	32
2	45	10	15	25	25	52
3	90	25	30	50	50	104
4	135	40	50	75	100	156
5	270	75	100	150	200	311
6	540	150	200	300	400	621
7	810	---	300	---	600	932
8	1215	---	450	---	900	1400
9	2250	---	800	---	1600	2590

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

*See clause 4.1.2.

†These horsepower ratings are based on the locked-rotor current ratings given in Table 2-4-1. For motors having higher locked-rotor currents, a larger controller should be used so that its locked-rotor current rating is not exceeded.

Table 2-4-13

HORSEPOWER RATINGS FOR THREE-PHASE MULTISPEED MAGNETIC CONTROLLERS FOR LIMITED PLUGGING AND JOGGING-DUTY FOR CONSTANT-HORSEPOWER MOTORS (TWO, THREE, AND FOUR SPEED)

		Horsepower†				
Size of Controller	Continuous Current Rating (Amperes)	60 Hertz 200V	60 Hertz 230V	50 Hertz 380V	60 Hertz 460 or 575V	Service Limit Current Rating Amperes *
0	18	2	2	2	3	21
1	27	5	5	7.5	7.5	32
2	45	7.5	10	20	20	52
3	90	20	25	40	40	104
4	135	30	40	60	75	156
5	270	60	75	100	150	311
6	540	100	150	200	300	621
7	810	---	225	---	450	932
8	1215	---	350	---	700	1400
9	2250	---	600	---	1200	2590

*See clause 4.1.2.

†These horsepower ratings are based on the locked-rotor current ratings given in Table 2-4-1. For motors having higher locked-rotor currents, a larger controller should be used so that its locked-rotor current rating is not exceeded.

Table 2-4-14

HORSEPOWER RATINGS FOR THREE-PHASE PRIMARY CONTACTORS OF MAGNETIC WOUND-ROTOR MOTOR CONTROLLERS FOR REVERSING AND NONREVERSING DUTY 50 OR 60 HERTZ

Size of Controller	Continuous Current Rating (Amperes)	Three-Phase Horsepower			Service Limit Current Rating* (Amperes)
		115V	230V	460 or 575V	
1	27	3	7.5	10	32
2	45	---	15	25	52
3	90	---	30	50	104
4	135	---	50	100	156
5	270	---	100	200	311
6	540	---	200	400	621
7	810	---	300	600	932
8	1215	---	450	900	1400
9	2250	---	800	1600	2590

*See clause 4.1.2

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-15
ACCELERATING CONTACTORS
FOR WOUND ROTOR MOTOR CONTROLLERS

Horsepower Rating	Minimum Number of Accelerating Contactors
15	1
75	2
150	3
300	4
600	5
1200	6

Table 2-4-16
NEMA SHORT CIRCUIT CURRENT RATINGS
(RMS SYMMETRICAL AMPERES)

1,000	22,000	65,000
5,000	25,000	85,000
7,500	30,000	100,000
10,000	35,000	125,000
14,000	42,000	150,000
18,000	50,000	200,000

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-17
GENERAL-PURPOSE CONTACTOR RATINGS

Size of Contactor	Continuous Carrying Current, RMS Amperes		Direct Load Switching RMS Ampere Rating				Transformer Primary Switching kVA Open or Enclosed													
			Maximum Circuit-Closing (Amps Peak Including Offset)	Tungsten Lamp Loads, 300 Volts Maximum†	Resistive Loads and Electric Discharge Lamp Loads**		Transformers Having Inrush Current (Worst Case Peak) of Not More than 20 times Peak of Continuous-Current Rating								Transformers Having Inrush Currents (Worst Case Peak) of Over 20 Through 40 Times Peak of Continuous-Current Rating							
							Single Phase volts				Three Phase volts				Single Phase Volts				Three Phase volts			
	Enclosed	Open	Open or Enclosed	Open or Enclosed	Enclosed	Open	120	240	480	600	208	240	480	600	120	240	480	600	208	240	480	600
00	9	10	87	5	9	10																
0	18	20	140	10	18	20	0.6	1.2	2.4	3.0	1.8	2.1	4.2	5.2	0.3	0.6	1.2	1.5	0.9	1.0	2.1	2.6
1	27	30	288	15	27	30	1.2	2.4	4.9	6.2	3.6	4.3	8.5	11.0	0.6	1.2	2.5	3.1	1.8	2.1	4.3	5.3
2	45	50	483	30	45	50	2.1	4.1	8.3	10.0	6.3	7.2	14.0	18.0	1.0	2.1	4.2	5.2	3.1	3.6	7.2	8.9
3	90	100	947	60	90	100	4.1	8.1	16.0	20.0	12.0	14.0	28.0	35.0	2.0	4.1	8.1	10.0	6.1	7.0	14.0	18.0
4	135	150	1581	120	135	150	6.8	14.0	27.0	34.0	20.0	23.0	47.0	59.0	3.4	6.8	14.0	17.0	10.0	12.0	23.0	29.0
5	270	300	3163	240	270	300	14.0	27.0	54.0	68.0	41.0	47.0	94.0	117.0	6.8	14.0	27.0	34.0	20.0	24.0	47.0	59.0
6	540	600	6326	480	540	600	27.0	54.0	108.0	135.0	81.0	94.0	188.0	234.0	14.0	27.0	54.0	68.0	41.0	47.0	94.0	117.0
7	810	900	9470		810	900																
8	1215	1350	14205		1215	1350																
9	2250	2500	25380		2250	2500																

* Enclosed ratings apply in any type of enclosure.
† Tungsten lamp loads include infra-red lamps having tungsten filaments.
**Electric discharge lamps are those such as fluorescent, mercury vapor, etc.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-18

CONTACTOR RATINGS FOR SINGLE CAPACITOR OR CAPACITOR BANK SWITCHING AT 230 VOLTS 60 HZ

Size of Controller	Continuous Ratings RMS Amperes	Three-Phase Rating of Capacitor					
		Maximum Size of Three-Phase Capacitor in kVar for Available Current* in Amperes RMS Sym.					
		3000	5000	10,000	14,000	18,000	22,000
2	45	12	8	4	3	2	2
3	90	27	27	15	11	9	7
4	135	40	40	40	30	24	20
5	270	80	80	80	80	80	75
6	540	160	160	160	160	160	160
7	810	240	240	240	240	240	240
8	1215	360	360	360	360	360	360
9	2250	665	665	665	665	665	665

*Available at capacitor terminals.

Table 2-4-19

CONTACTOR RATINGS FOR SINGLE CAPACITOR OR CAPACITOR BANK SWITCHING AT 460 VOLTS 60HZ

Size of Controller	Continuous Ratings RMS Amperes	Three-Phase Rating of Capacitor					
		Maximum Size of Three-Phase Capacitor in kVar for Available Current* in Amperes RMS Sym.					
		3000	5000	10,000	14,000	18,000	22,000
2	45	25	16	8	6	4	4
3	90	53	53	31	23	18	15
4	135	80	80	80	61	49	41
5	270	160	160	160	160	160	149
6	540	320	320	320	320	320	320
7	810	480	480	480	480	480	480
8	1215	720	720	720	720	720	720
9	2250	1325	1325	1325	1325	1325	1325

*Available at capacitor terminals.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 2-4-20

CONTACTOR RATINGS FOR SINGLE CAPACITOR OR CAPACITOR BANK SWITCHING AT 575 VOLTS 60 HZ

Size of Controller	Continuous Ratings RMS Amperes	Three-Phase Rating of Capacitor					
		Maximum Size of Three-Phase Capacitor in kVar for Available Current* in Amperes RMS Sym.					
		3000	5000	10,000	14,000	18,000	22,000
2	45	31	20	10	7	6	5
3	90	67	67	39	29	23	19
4	135	100	100	100	77	61	51
5	270	200	200	200	200	200	189
6	540	400	400	400	400	400	400
7	810	600	600	600	600	600	600
8	1215	900	900	900	900	900	900
9	2250	1670	1670	1670	1670	1670	1670

*Available at capacitor terminals.


Table 2-7-1

CONTROL AND POWER CONNECTIONS

		One Phase	Two Phase Four Wire	Three Phase
Line terminal markings on controller		L1, L2	Phase 1 L1, L3 Phase 2 L2, L4	L1, L2, L3
Ground when used		L2		L2
For reversing, interchange line			L1, L3	L1, L3
Motor running overcurrent units in	1 element devices 2 element devices 3 element devices	L1	... ...* ...	... ... L1,L2,L3
Control circuit		L1, L2	L1, L3	L1, L2

* Three pole contactors used, refer to Figure 2-7-2

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale



CONTACTOR SEQUENCE	
CONTACTOR	START AND RUN
M	X

Figure 2-3-1
FULL VOLTAGE CONTROLLER




Figure 2-3-2
FULL VOLTAGE PART WINDING CONTROLLERS

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale




Figure 2-3-3
CONTROLLERS FOR TWO-WINDING TWO-SPEED MOTORS

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale





Figure 2-3-4
CONTROLLERS FOR SINGLE-WINDING TWO-SPEED MOTORS



CONTACTOR SEQUENCE		
CONTACTOR	START	RUN
M	X	X
RUN		X


CONTACTOR SEQUENCE		
CONTACTOR	START	RUN
M	X	X
RUN		X

CONTACTOR SEQUENCE			
CONTACTOR	START	TRANSITION	RUN
S	X	X	X*
RUN		X	X


* OPEN OR CLOSED

Figure 2-3-5
REDUCED VOLTAGE CONTROLLER - REACTOR OR RESISTOR

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale



CONTACTOR SEQUENCE				
CONTACTOR	START	TRANSITION		RUN
1M		X	X	X
2M				X
S	X			



CONTACTOR SEQUENCE					
CONTACTOR	START	TRANSITION			RUN
		1	2	3	
1M	X	X	X	X	X
2M				X	X
1S	X		X		
2S			X	X	X

Figure 2-3-6
WYE-DELTA CONTROLLERS

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale




Figure 2-3-7
REDUCED VOLTAGE AUTOTRANSFORMER CONTROLLERS

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale




Figure 2-4-1
SINGLE-PHASE LOAD




Figure 2-4-2
THREE-PHASE LOAD




Figure 2-4-3
SINGLE-PHASE LOAD – ONE LINE GROUNDED

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale




Figure 2-7-1
CONTROL CIRCUIT OVERCURRENT PROTECTION




Figure 2-7-2
THREE-PHASE CONTROLLERS FOR TWO-PHASE APPLICATIONS

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale



Figure 2-7-3
CONTROL CIRCUIT TERMINAL MARKINGS FOR NONREVERSING CONTROLLERS




Figure 2-7-4
CONTROL CIRCUIT TERMINAL MARKINGS FOR REVERSING CONTROLLERS

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale




Figure 2-7-5
CONTROL CIRCUIT TERMINAL MARKINGS FOR TWO-SPEED CONTROLLERS




Figure 2-9-1
METHODS OF CONNECTING POWER FACTOR CORRECTION CAPACITORS

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS

Not for Resale

Part 3
NONMAGNETIC MOTOR CONTROLLERS

1 GENERAL

1.1 Scope

The standards in this part apply to nonmagnetic controllers and switches rated 600 volts and less, 50 and 60 hertz such as:

a. Class A manually-operated and motor-operated controllers for squirrel-cage and wound-rotor induction motors

b. Pressure switches (specifically includes domestic water pump, air compressor pressure switches)

c. Temperature switches for cooling fans and resistive loads

d. Liquid level or float switches for pump control

e. Drum controllers

1.2 Normative References

The definitions and standards of NEMA Standards Publications No. 250, ICS 1 and ICS 2, Part 1 apply to this part unless otherwise stated.

See ICS 5, Part 3 for additional definitions and construction requirements for the actuators of pressure, temperature and liquid level switches.

2 DEFINITIONS

For the purposes of this part, the following definitions apply:

drum controller: An electric controller that utilizes a drum switch as the main switching element.
A drum controller usually consists of a drum switch and a resistor.
drum switch: A switch in which the electric contacts are made on segments or surfaces on the periphery of a rotating cylinder or sector, or by the operation of a rotating cam.

float switch: A liquid level switch which is operated by a buoyant constituent part.

liquid level switch: A switch which is responsive to the level of a liquid.

pressure switch: A switch which is operated by a constituent part and is responsive to fluid (gas or liquid) pressure.
A vacuum switch is a pressure switch which operates primarily at pressure less than atmospheric.

temperature switch: A two-state (ON-OFF) controller which is responsive to the temperature of a sensed medium.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

3 CLASSIFICATION

This part contains no classifications.

4 CHARACTERISTICS AND RATINGS

4.1 Horsepower and Current Ratings of Manually Operated and Motor-Operated Controllers

4.1.1 Ratings of Manually-Operated and Motor-Operated Controllers for Integral-Horsepower Induction Motors

The ratings of nonreversing and reversing full-voltage single-speed controllers, with or without motor running overcurrent protection or other auxiliary devices and when mounted in any type of enclosure, shall be:

a. In accordance with Table 3-4-1 for three-phase controllers

b. In accordance with Table 3-4-2 for single-phase controllers

4.1.2 Ratings of Manually-Operated or Motor-Operated Controllers for Fractional-Horsepower Motors

The rating of full-voltage manually-operated controllers, single or double pole, provided with or without running overcurrent protection and enclosed in any type of enclosure for use with fractional-horsepower single-phase motors, shall be 1 horsepower at AC voltages of 115 and 230 volts.

4.2 Ratings of Drum Controllers

4.2.1 Ratings of Drum Controllers for Single-Speed and Multispeed Motors

The ratings of drum controllers for full-voltage single-speed and multispeed induction motors (other than wound rotor) shall be as shown in Table 3-4-3.

4.2.2 Ratings of Manually-Operated Drum Controllers for Wound-Rotor Motors

The horsepower ratings and the number of control points of enclosed alternating-current drum controllers for wound-rotor motors shall be as shown in Tables 3- 4-4 and 3-4-5. Continuous ratings apply in all cases where any point on the drum switch will be used for any period exceeding 5 minutes. Intermittent ratings shall be used for crane, hoist or other duty where the running time is not more than 50 percent of the total time and the maximum running time is not more than five minutes.

For starting duty only, the number of control points shall be permitted to be from 8 to 10, and the ampere and horsepower ratings for the 100-ampere to 300-ampere sizes shall be permitted to be doubled provided a contactor of the proper rating is used to shunt the controller on the final point. Under similar conditions for the 600-ampere size, the rating shall be permitted to be increased to 1000 amperes and 1250 horsepower.

4.2.3 Ratings of Motor-Operated Drum Controllers for Wound-Rotor Motors

The ratings of alternating-current motor-operated drum controllers for use in the secondary circuits of wound-rotor motors shall be as shown in Table 3-4-6, all speed points being balanced.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

4.3 Contact Ratings of Pressure, Temperature and Liquid-Level Motor Controllers

The ratings of these switches where intended for use as motor controllers shall be in terms of horsepower and continuous current for one or more utilization voltages.

The ratings of these switches where used as an integral part of engineered motor and controller combinations shall be in terms of horsepower and continuous current or motor full-load and locked-rotor current for one or more utilization voltages.

The ratings may be on the basis for two poles controlling a three-phase motor or one pole controlling a single-phase motor.

4.4 Ratings of Resistors for Motor Secondary Circuits

Resistors for the secondary circuits of wound-rotor motors used with manually-operated controllers, shall be rated as follows:

a. 50 Horsepower and Less—Class No. 114 or 115
b. More than 50 Horsepower—Class No. 132, 133, 134 or 135

See ICS 9, Part 2 for resistor classes.

5 PRODUCT MARKING, INSTALLATION AND MAINTENANCE INFORMATION

See ICS 1.3 for preventive maintenance instructions.

6 SERVICE AND STORAGE CONDITIONS

See ICS 1, Clause 6.

7 CONSTRUCTION

7.1 Current Carrying Capacity of Resistors

See ICS 9, Part 2.

7.2 Face-Plate Type Controllers

Face-plate type controllers shall be enclosed.

7.3 Drum Controller Conduit Connections

Drum switches shall include a provision for conduit connections.

8 PERFORMANCE REQUIREMENTS AND TESTS

See Clause 8 of ICS 1 and Clause 8 of Part 1.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

9 APPLICATION

Pressure, temperature and liquid level switches which are rated for motor applications should be used with motors having integral thermal protectors or an equivalent means for providing running overcurrent protection for the motor branch circuit. It should be noted that when two pole switches are used to control three-phase motors only two lines are disconnected when the switch is open and the motor terminal box contains live parts unless the branch circuit disconnect device is also open.

--`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 3-4-1

HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR THREE-PHASE, SINGLE SPEED, FULL-VOLTAGE MANUALLY OR MOTOR-OPERATED CONTROLLERS

Size of Controller	Continuous Current Rating (Amperes)	At 200V-60 Hz		At 230V-60 Hz		At 380V-50 Hz		At 460V-60 Hz		At 475V-60 Hz		Service-Limit Current Rating* Amperes
		Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	Hp	LRA	
M-0	18	3	74	3	70	5	64	5	53	5	42	21
M-1	27	7-1/2	152	7-1/2	140	10	107	10	88	10	70	32

* See Clause 4.1.2.

Table 3-4-2

HORSEPOWER (HP) AND LOCKED-ROTOR CURRENT (LRA) RATINGS FOR SINGLE-PHASE, SINGLE SPEED, FULL-VOLTAGE MANUALLY OR MOTOR-OPERATED CONTROLLERS

Size of Controller	Continuous Current Rating (Amperes)	At 115V 50 - 60 Hz		At 230V 50 - 60 Hz		Service-Limit Current Rating* Amperes
		Hp	LRA	Hp	LRA	
M-0	18	1	80	2	65	21
M-1	27	2	130	3	90	32
M-1P	36	3	140	5	135	42

* See Clause 4.1.2.

Table 3-4-3

RATINGS OF DRUM CONTROLLERS

Size of Controller	Three Phase*		Single Phase	
	200 or 230 Volts	460 or 575 Volts	115 Volts	230 Volts
D-0	2	2	1	1-1/2
D-1	5	7-1/2	1-1/2	3

*Does not include three-phase constant-horsepower multispeed motors. For these motors, use the ratings given in the single-phase column.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 3-4-4
RATINGS OF MANUALLY-OPERATED DRUM CONTROLLERS FOR WOUND-ROTOR MOTOR PRIMARY AND SECONDARY CONTROL*

8-hour Rating, Amperes	Number of Control Points	Horsepower Rating Continuous Duty		Horsepower Rating Intermittent Duty		Service-Limit Current Rating Amperes**
		230 Volts	460 or 575 Volts	230 Volts	460 or 575 Volts	
50	5 or 6	15	25	15	25	58
100	6 or 7	30	50	40	75	115
150	7 or 8	50	100	60	125	173
300	9 or 10	100	200	150	300	345

* Drum Controllers shall open all ungrounded lines of a three-phase primary circuit.

** See Clause 4.1.2.

Table 3-4-5
RATINGS OF MANUALLY-OPERATED DRUM CONTROLLERS FOR WOUND-ROTOR MOTOR, SECONDARY CONTROL ONLY*

8-hour Rating, Amperes	Number of Control Points	Horsepower Ratings at 230,460 or 575 Volts	Service-Limit Current Rating** Amperes
100	11	50	115
150	11	100	173
300	11	300	345
600	11	750	690

* Drum Controllers for starting duty only.

** See Clause 4.1.2.

Table 3-4-6
RATINGS OF MOTOR-OPERATED DRUM CONTROLLERS FOR SECONDARY CIRCUITS OF WOUND ROTOR MOTORS

8-hour Rating, Amperes	Number of Speed-Regulating Points	Service-Limit Current Rating Amperes*
300	13	345
300	20	345
600	13	690
600	20	690

* See clause 4.1.2.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Part 4
OVERLOAD RELAYS

1 GENERAL

1.1 Scope

The standards in this part apply to overload relays that monitor motor current. They may be mounted separately or combined with contactors (motor controllers) used in industrial control pplications.

1.2 Normative References

The definitions and standards of ICS 1, and ICS 5, Part 1 apply to this part unless otherwise stated.

2 DEFINITIONS

For the purposes of this part, the following definitions apply:
(* indicates definition from ANSI/IEEE Standard 100.)

algorithm:* A prescribed set of well-defined rules or processes for the solution of a problem in a finite number of steps, for example, a full statement of an arithmetic procedure for evaluating sine x to a stated precision.

ambient temperature compensated (overload relay): A qualifying term applied to an overload relay to indicate that its ultimate current remains essentially unchanged over a designated range of ambient temperatures.

ambient temperature sensitivity (overload relay): An expression of performance which defines the variations in its ultimate current over a designated range of ambient temperature.

automatic reset (overload relay): A term used to describe an overload relay having an integral function that independently causes the overload relay to be reset.

current element (overload relay): The part of an overload relay that determines the value of current which causes the relay to operate (trip). Current elements of thermal overload relays are referred to as heater elements.

current rating (overload relay): The minimum value of continuously applied current which is expected to cause all like relays to operate (trip) under designated conditions. This value, for an individual relay, may be equal to or exceed its ultimate current under these conditions.

heater element (thermal overload relay): The part of a thermal overload relay that is intended to produce heat when conducting current. Heater elements are sometimes referred to as heaters, thermal units, current elements, or heating elements.

induction-disc relay: A protective device that includes a rotating disc in which currents are induced by permanent magnets and electromagnets in such a manner that the rotation of the disc to operate contacts is related to a selected inverse time function.

instantaneous trip (overload relay): A qualifying term indicating that no delay is purposely introduced in the tripping action of the relay.

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

integrated motor monitor: A single solid-state device that provides a multiplicity of motor monitoring functions, one of which is overload protection, by sensing current components and using an algorithm to determine when it should provide a signal to alarm or trip, or both.

inverse time (overload relay): A qualifying term indicating that a delay is purposely introduced in the tripping action of the relay. The delay decreases as the magnitude of the current increases.

limit of self protection (overload relay): The maximum current value that an overload relay can respond to without sustaining damage that will impair its function.

manual reset (overload relay): A term used to describe an overload relay that requires deliberate human actuation in order to be reset.

operating memory: A characteristic of an overload relay that considers the cumulative heating effect in the motor circuit resulting from motor operation or overload, and the cooling effect after the motor circuit is deenergized.

operating memory, nonvolatile: An operating memory that is not lost if power to the relay is interrupted for a short period of time (See 8.8, Operating Memory Test for an Inverse-Time Overload Relay).

overcurrent: Any current in excess of the rated continuous current of equipment or the ampacity of a conductor. It may result from motor starting, overload, short circuit or ground fault.

overload: Operation of equipment in an electrically undamaged circuit in excess or normal, full-load rating, or of a conductor in excess of rated ampacity which, if persisting for a sufficient length of time, would cause damage or overheating. A fault, such as a short circuit or ground fault or a loss of phase, is not an overload.

overload relay: An overcurrent relay which operates (trips) at a predetermined value of over-current to provide a signal or to cause disconnection of the load from the power supply, or both.
An overload relay is intended to protect the motor branch circuit conductors, the motor control apparatus and the motor(s) against overcurrent. It may not necessarily protect itself.

overload relay class: A classification of an overload relay time-current characteristic by means of a number which designates the maximum time in seconds at which it will operate (trip) when carrying a current equal to 600 percent of its current rating.

solid-state overload relay: An overload relay which senses overcurrent and performs a control function by means of a semiconductor circuit. A solid-state overload relay may have a semiconductor or a contact output.

thermal overload relay: An overload relay that operates (trips) by means of a thermally responsive system.

time-current characteristic (overload relay): An expression of performance which defines the operating time of an overload relay at various multiples of its current rating.

trip free (overload relay): A qualifying term applied to an overload relay to indicate that its operation is independent of and nonvoidable by the manual reset means.

ultimate current: The minimum value of continuously applied current that will cause an overload relay to operate (trip).

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

3 CLASSIFICATION

3.1 Inverse-Time Overload Relays

3.1.1 Overload Relay Class Designations

When an inverse-time overload relay is described by time-current characteristics, it shall be designated by a class number indicating the maximum time in seconds at which it will operate (trip) when carrying a current equal to 600% of its current rating. The class number applies with balanced overcurrent in all active phases. A Class 20 relay will operate (trip) in 20 seconds or less, a Class 30 relay will operate in 30 seconds or less, and a Class 10 relay will operate (trip) in 10 seconds or less.

3.1.2 Inverse-Time Overload Relay Categories

Inverse-time overload relays are categorized by their ability to consider the cumulative heating effect in the motor circuit as a result of motor operation or overload. This characteristic, called operating memory, may be either volatile or nonvolatile.

Category	Capability
A	nonvolatile operating memory
B	volatile operating memory
C	no operating memory

3.2 Instantaneous Overload Relays

Instantaneous overcurrent relays ("jam" relays) are used in applications in which the overcurrent represents a load condition requiring instant removal of the motor from the line. The time or current, or both to operate the relay must be such that normal overcurrents, such as during normal motor starting, do not cause nuisance tripping. This function may also be accomplished by disabling the "jam" relay during start-up.

4 CHARACTERISTICS AND RATINGS

4.1 Overload Relay Types

4.1.1 Overload Relays That Respond to Current Heating Effect

Overload protection devices that respond to the heating effect of the motor line current include thermal and certain solid-state overload relays. Thermal overload relays use the motor line current to produce heat within themselves at a designed rate to simulate load and conductor heating. Solid-state overload relays of this type monitor motor line currents and determine with semiconductor circuits the heating effect of these currents on the load and conductors.

All thermal overload relays have an operating memory, i.e., they respond as if they remember that the load they are protecting has been operating at some rate and may not be cold when returned to service after an overload. Solid-state overload relays may have an equivalent operating memory. The operating function can be provided in various ways, such as by charging a capacitor or altering the count in a register of a microprocessor.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

4.1.2 Overload Relays That Respond to Current Magnitude

Protection devices that respond to the magnitude of the line current include magnetic, induction-disc, and certain solid-state relays. Such overload relays may be instantaneous-trip or inverse-time.

4.1.2.1 Magnetic Type

Magnetic overload relays may be instantaneous-trip or inverse-time. In inverse-time overload relays the movement of the plunger, attracted by a magnetic field, is slowed by dashpot action.

4.1.2.2 Induction-Disc Type

Induction-disc relays provide adjustable inverse-time functions by varying the position or effect of the permanent magnets or electromagnets, or both on the induction disc which must rotate to cause the relay to trip.

4.1.2.3 Solid-State Type

Solid-state overload relays may be instantaneous-trip or inverse-time. Inverse-time overload relays may have circuitry or a program to obtain the inverse-time function.

4.2 Overload Relay Current Rating

The current rating of an overload relay shall be expressed in amperes at an ambient temperature of 40°C.

An overload relay may have different current ratings where used as an open-type device, or where mounted in an enclosure, or where used in combination with other equipment within a similar enclosure. The ambient temperature of 40°C for current rating assignment of enclosed devices shall refer to the measured temperature of the air which surrounds the enclosure.

4.3 Overload Relay Time-Current Characteristics

The time-current characteristics of inverse-time overload relays in a 40°C ambient temperature are preferably expressed as the maximum operating times in seconds under the designated conditions associated with the current rating, at current values corresponding to multiples of the current rating. Curves such as minimum operating times may also be shown. All curves shall be identified. The time-current curve shall not be shown beyond the limit of self protection.

The preferred method for displaying these performance curves shall be time in seconds as ordinate and multiples of current rating as abscissa, plotted on a full logarithmic coordinate format as shown in the example in Figure 4-4-1.

Where the current setting is adjustable, these performance curves should be given for each end of the adjustment range. If the time characteristics are adjustable, they should also be given for each end of the adjustment range.

4.4 Overload Relay Limit of Self Protection

The limit of self protection of an overload relay at a 40°C ambient temperature shall be expressed by the assigned whole-number multiple of its current rating.

An overload relay should not be subjected to these current levels frequently.

--`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

4.5 Overload Relay Ambient Temperature Sensitivity

The ambient temperature sensitivity of an overload relay shall be expressed as the percent change in ultimate current per 10°C change of ambient temperature, between 25°C and 50°C.

The range of ambient temperature qualifying the percent change may be outside the application limits for continuous-duty operation and is only intended to provide the information necessary to predict the performance that can be expected under intermittent or abnormal operating conditions.

The ambient temperature sensitivity value may be applied to the current rating to determine the approximate ultimate current at other ambient temperatures.

4.6 Control-Circuit Contact Ratings

The rating of the contacts of an overload relay which operate in a control circuit shall be in accordance with ICS 5, Table 1-4-1, for the AC ratings and ICS 5, Table 1-4-2, for DC ratings.

4.7 Solid-State Control Circuit Ratings

Overload relays with semiconductor switching elements which operate in a control circuit shall be rated in accordance with ICS 5, Table 1-4-4 for the AC applications and ICS 5, Table 1-4-5 of for DC ratings.

4.8 Solid-State Overload Relays with External Control Power Source

Where an overload relay uses an external control power source, the relay shall open the normally-closed contacts or switching element when control power is removed.

4.9 Line Current Relationship in Polyphase Circuits

Instantaneous-trip and inverse-time overload relays may respond to the relationship of line currents in each phase. This relationship may include phase-loss, phase-unbalance and phase-angle functions. The response characteristics of overload relays to this relationship are not included in this standard.

5 PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION

5.1 Identification of Interchangeable Current Elements and Product Information

Interchangeable current elements shall bear identification which is visible after the apparatus is installed and wired. Information relating the identification to the complete device shall be furnished and shall include:

a. The current rating or the assigned motor full-load current or range of currents and frequency, when applicable

b. Instructions for converting assigned motor full-load current to the relay current rating

c. Maximum available fault current and recommendations for fault-current protection where such protection is not included with the equipment and where the requirements are more restrictive than those of the National Electrical Code

d. Overload relay class if other than Class 20

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

e. Overload relay category if other than Category A

f. Range of adjustment if adjustment is provided

g. Control circuit ratings

h. Power supply requirements (volts, amperes, hertz) when applicable

i. Power conductor size and insulation temperature rating, expressed in one of two methods:

1. By minimum insulation temperature rating (e.g., 75°C) and conductor size for each current element

2. By minimum insulation temperature rating and instructions permitting the use of conductors with a higher temperature rating, provided that the conductor size is selected on the basis of the ampacity of conductors with the minimum insulation temperature rating. For example, if 75°C is the minimum conductor insulation rating specified, 90°C conductors may be used, provided that the conductor size is selected from the 75°C column of Table 310-16 of the National Electrical Code (NFPA 70, "NEC")

j. Tightening torque for user connections

5.2 Identification of Overload Relays Using Fixed or Noninterchangeable Current Elements

An overload relay with fixed or noninterchangeable current elements shall meet the requirements of 5.1 except that the identification of the current element may be marked on the overload relay.

5.3 Preventive Maintenance Guide

See ICS 1.3 for preventive maintenance instructions.

6 SERVICE AND STORAGE CONDITIONS

See ICS 1, Clause 6.

7 CONSTRUCTION

7.1 Selectable Functions and Settings

Where an overload relay provides functions or settings to be selected or adjusted by the user (e.g., overload relay class, phase unbalance, motor current, reset mode, etc.), these functions or settings shall be visible from the front when the overload relay or integrated motor monitor is mounted in its normal operating position.

7.2 Trip Indication

An overload relay may include a means to show that it is tripped.

7.3 Resetting

An overload relay shall be capable of being reset. Resetting may be accomplished automatically or manually. Overload relays shall be of the trip-free type. If an overload relay is constructed so that it can be reset by the momentary removal and reapplication of power, instructions for power application should be included.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

8 PERFORMANCE REQUIREMENTS AND TESTS

8.1 Verification Test for Overload Relay Current Rating and Time-Current Characteristics

8.1.1 Test Conditions

a. Tests shall be conducted in an ambient temperature of 40°C–1°C. The overload relay shall be allowed to reach thermal equilibrium with the specified ambient temperature before proceeding with each test.

b. Tests shall be conducted in a manner which simulates the intended service conditions: this includes the designated conditions for the assignment of the current rating, that is, whether the relay is a separate device or a part of a motor controller, and whether it is open or enclosed.

c. Relays designated as "ambient temperature compensated" shall be tested in ambient temperatures of 25°C and 50°C, as well as 40°C.

d. The power source shall be single phase, 60 hertz with means for maintaining a sine-wave current of an essentially constant rms value, unless the relay must be tested using another power system.

e. Current measurements shall be accurate within one percent of the measured value.

8.1.2 Test Connections

8.1.2.1 Conductors for Relays Marked for Full-load Current

Conductors for the external wiring to the overload relay (or associated equipment), considered to be user connections, shall have a minimum length of 4 feet (1.2 meters) per terminal. The wire shall be of the smallest size having an ampacity of at least 125 percent of the maximum motor full-load current listing for the overload relay, the overload relay setting, or the overload relay current element. The wire shall be selected from the 75°C column of Table 310-16 of National Electrical Code, unless otherwise specified by the manufacturer.

8.1.2.2 Conductors for Relays Marked with Current Rating

Conductors for the external wiring to the overload relay (or associated equipment), considered to be user connections, shall have a minimum length of 4 feet per terminal. The wire shall be the smallest size having an ampacity at least equal to the current rating of the relay, the overload relay setting, or the overload relay current element. The wire shall be selected from the 75°C column of Table 310-16 of National Electrical Code, unless otherwise specified by the manufacturer.

8.1.2.3 Schematic Diagram

The wiring for three-phase devices shall be in accordance with the typical schematic diagram shown in Figure 4-8-1 for single-phase and DC sources and as shown in Figure 4-8-2 for three-phase test sources. The wiring for single-phase devices shall be in accordance with the manufacturer's instructions.

8.1.2.4 Control Circuit

To avoid possible damage to the relay, it is recommended that the test circuit be arranged so as to assure the disconnection of the current source when the overload relay operates (trips).

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

8.1.3 Test Procedure

a. A single-pole relay or a three-pole relay connected as a single-pole relay shall be tested at 100, 200 and 600 percent of the relay current rating.

b. Three single-pole relays, each with its own current element and trip mechanism, or a three-pole relay with three current elements and a single trip mechanism, intended for three-phase circuits, shall be tested at:

1. 100 percent of the relay's current rating with three current elements connected

2. 200 percent of the relay's current rating with two current elements connected

3. 600 percent of the relay's current rating with two current elements connected

4. 600 percent of the relay's current rating with three current elements connected

c. An adjustable relay with interchangeable current elements and means for adjustment in percent of its current rating shall be set at the 100 percent mark on the adjustment scale and subjected to the test described in a) or b), depending on the intended application and number of relays involved. In addition, an adjustable relay shall be tested at its high and low adjustment points, such as the 120 and 80 percent marks, at 200 percent of its current rating to determine that the time of operation will be longer and shorter, respectively, than the operating time when the relay is subjected to the same test with the adjustment set at the 100 percent mark on the adjustment scale.

d. An adjustable relay arranged to cover several current ratings (trip currents) shall be tested at 100, 200 and 600 percent at its minimum, midpoint and maximum current ratings.

8.1.4 Performance

When tested as described above, an overload relay shall perform as shown in Table 4-8-1.

8.2 Verification Test for Limit of Self-Protection

8.2.1 Test Conditions

The test conditions shall be the same as those specified in 8.1.1 except that “ambient temperature compensated” relays may be tested at 40°C only.

8.2.2 Test Procedure

A single test shall be conducted for the limit of self protection assigned to an overload relay.

The magnitude of the test current (self-protection limit current) is determined by multiplying the current rating of the overload relay by the multiplier assigned as its limit of self protection.

8.2.3 Test Connections

Test connections shall be the same as those specified in 8.1.2.
The test circuit shall be arranged to assure that tripping of the overload relay will immediately cause the overload relay to be disconnected from the current source.

--`,,`-`-`,,`,,`,`,,`---
Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

8.2.4 Performance

When tested at its self-protection limit current, an overload relay shall operate (trip) without sustaining damage that will impair its performance. An overload relay which has been subjected to this test shall be considered to conform to the requirements of this standard if it can subsequently be shown that it meets the requirements of the design test for current rating described in 8.1.

8.3 Verification Test for Overload Relay Ambient Temperature Sensitivity

8.3.1 Test Conditions

Test conditions shall be the same as those specified in 8.1.1, except that tests shall be conducted at 40°C and other specified ambient temperatures.

8.3.2 Test Connections

Test connections shall be the same as those specified in 8.1.2.

8.3.3 Test Procedure

The ultimate currents shall be determined at the ambient temperatures under consideration.

8.3.4 Performance

When the ultimate currents are determined in this manner, the ambient temperature sensitivity of the overload relay shall not exceed the designated value.

8.4 Overload Relay Short-Time Capability

A new overload relay shall be capable of meeting the short-time operating and short-time surge capability requirements for controllers shown in Clause 8 of Part 2.

8.5 Control-Circuit Output

The contacts or solid-state switching element of an overload relay shall perform in accordance with ICS 5, Part 1.

8.6 Electrical Noise Test for Solid-State Devices

Solid-state overload relays and integrated motor monitors for sensing or switching shall not malfunction when subjected to the electrical noise test procedures of ICS 1.

8.7 Impulse Withstand Test for Solid-State Devices

Solid-state overload relays and integrated motor monitors using semiconductor elements shall not malfunction during and after being subjected to the impulse withstand test procedures of ICS 1, Annex A of ICS 1 for installation (overvoltage) category III applied to the power circuit, and for installation (overvoltage) category II or I applied to the control circuit and power supply terminals. Energy levels for the impulse test are under consideration.

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

8.8 Operating Memory Test for an Inverse-Time Overload Relay

An inverse-time overload relay that includes an operating memory shall be tested to verify the existence of a memory by applying 600 percent of rated current through all active phases, as shown in Figure 4-8-2 until it operates (trips). Reset as soon as possible. The time to trip and time to reset shall be recorded. The 600 percent current shall be reapplied and the time to trip recorded. The control power (if so equipped) shall be removed for 1.5 minutes after tripping, reapplied, and then the relay reset as soon as possible. The 600 percent current control power shall be applied for the third time and the time to trip recorded.

If, in Test No. 2, the trip time T2 is not greater than 85 percent of the trip time T1 of Test No. 1, the relay is considered to have an operating memory.

If, in Test No. 3, the trip time T3 is not greater than 85 percent of the trip time T1 in Test No. 1, the relay is considered to have a nonvolatile operating memory.

OPERATING TEST PROCEDURE

Test No.	Percent Rated Current	Trip Time (Seconds)	Procedure Following Trip
1	600	T1	Reset as soon as possible
2	600	T2	Remove control power for 1½ minutes. Reapply control power. Reset as soon as possible
3	600	T3	End of Test

9 APPLICATION

9.1 Current Rating and Time-Current Characteristics

The current rating and time-current characteristics of an overload relay should be coordinated with the components of a branch circuit selected in accordance with the National Electrical Code.

9.2 Limit of Self Protection

The current corresponding to the limit of self protection of an overload relay should be greater than the locked-rotor current of the motor it is intended to protect.

9.3 Ambient Temperature Sensitivity

The ambient temperature sensitivity provides the means to modify the selection of overload relays to accommodate a difference in ambient temperatures between the overload relay and motor that may exist on some applications.

9.4 Cautions on the Use of Automatic Reset

Automatic reset of overload relays is a convenience in many installations and a necessity in some. However, the use of automatic reset should be considered only if: a) the motor circuit will remain open when the overload relay contacts reclose, or b) automatic restarting will not create a hazard.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

An automatic-reset overload relay does not necessarily provide protection against overheating of a motor and its branch-circuit components from a persisting overload condition that causes repetitive tripping and resetting of the relay. It may be necessary to provide means for delaying motor restarting or limiting the number of trip-reset cycles.

9.5 Polyphase Motors Under Single-Phase Operating Conditions

Overload protection which is provided by overcurrent units having current elements in each phase of a polyphase motor and which provides protection under polyphase operating overloads may not provide the same degree of protection when the same motor is operating under single-phase conditions.

9.6 Coordination with Fault-Current Protection

9.6.1 Fault-Current Protection

An overload relay should be protected against fault currents by a device of a type and rating in accordance with Clause 5.1 item c.

9.6.2 Limit of Self Protection

At the current value corresponding to the self-protection limit of the overload relay, the fault-clearing time of the branch-circuit protective device should not exceed the operating (trip) time of the overload relay. When this comparison is based on mean values, a margin for safety should be allowed to account for possible variations in operating (trip) times.

9.6.3 Operating Overloads

Under operating overload conditions it is desirable for the overload relay to operate (trip) before the branch-circuit protective device can open the circuit. It may not be possible to obtain this degree of coordination with all types of branch-circuit overcurrent devices.

9.7 Application with Current Transformers

The current rating and the performance characteristics of an interconnected current transformer and overload relay will not necessarily be the same as those of the overload relay alone and shall be determined by the primary current of the current transformer.

9.8 Control-Circuit Contact Rating

The control-circuit contact rating of an overload relay should be adequate for the connected load in the particular control-circuit arrangement.

9.9 Short-Duration Overcurrent Effect

Overcurrents of short duration, such as those that occur during motor starting, are expected and do not cause excessive heating or damage to the motor, motor branch-circuit conductors, or motor control equipment if they do not occur frequently.

9.10 Overload Relay Limitations

Most devices offered to protect motors from overheating are designed to monitor currents from a fixed-frequency supply. Motors operating on a variable-frequency supply voltage can be overheated by internal currents and loss of cooling at low speeds without appearing to be drawing excessive current.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Conventional overload relays should not be used in variable-frequency motor branch-circuits unless appropriate compensating steps are taken.

Table 4-8-1

OVERLOAD RELAY PERFORMANCE

Test Current as Percent of Overload Relay Rating	Quantity of Poles Connected		Maximum Trip times			
	3 Pole Relays	1 Pole Relay	Class 10	Class 15	Class 20	Class 30
100%	3	1	---------- Ultimately* ----------			
200%	2 and 3	1	---------- 8 Minutes ----------			
600%	2 and 3	1	10 seconds	15 seconds	20 seconds	30 seconds

*Experience indicates that two to four hours is generally sufficient to verify this value. Systems which have large masses may require additional time.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale




Figure 4-4-1
OVERLOAD RELAY TIME-CURRENT CHARACTERISTICS - EXAMPLE

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale




Figure 4-8-1
SCHEMATIC DIAGRAM OF THREE-PHASE OVERLOAD RELAY TEST CONNECTIONS FOR SINGLE PHASE AND DC TEST SOURCES




Figure 4-8-2
SCHEMATIC DIAGRAM OF THREE-PHASE OVERLOAD RELAY TEST CONNECTIONS FOR THREE PHASE SOURCE

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Part 5
DC GENERAL-PURPOSE CONSTANT-VOLTAGE CONTROLLERS

1 GENERAL

1.1 Scope

The standards in this Part apply to Class B manual and magnetic controllers used with direct-current motors rated 600 volts or less.

1.2 Normative References

The definitions and standards of ICS 1 and ICS 2, Part 1 apply to this Part unless otherwise stated.

2 DEFINITIONS

For purposes of this Part the following definition applies:

Class B controllers: DC air-break manual or magnetic controllers for service at 600 volts or less.

They are capable of interrupting operating overloads but not short circuits or faults beyond operating overloads.

3 CLASSIFICATION

3.1 Types of Full-Voltage Class B Magnetic Controllers

The types of full-voltage Class B magnetic controllers shall be:

a. An enclosed nonreversing controller consisting of a two-pole line contactor and an overload relay and with provision for separate mounting of the pushbutton.

b. An enclosed nonreversing controller consisting of a two-pole line contactor and an overload relay and with the pushbutton mounted in the cover.

c. An enclosed reversing controller consisting of a two-pole line contactor and an overload relay and with provision for separate mounting of the pushbutton.

d. An enclosed reversing controller consisting of a two-pole line contactor and with provision for separate mounting of the pushbutton.

3.2 Reduced-Voltage Class B Magnetic Controllers for General-Purpose Applications

An enclosed nonjogging nonreversing Class B controller for motors having a 2 to 1, or less, speed range by field control and having a maximum rating of 5 horsepower at 115 volts and 10 horsepower at 230 volts shall include:

a. A single-pole line contactor

b. Necessary accelerating means

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

c. A single-element overload relay

d. A starting resistor (Class 115 or 116)

e. Provision for a separately mounted pushbutton

3.3 For Motors Having a 2 to 1 or Less Speed Range by Field Control

An enclosed jogging-duty controller, Sizes 1 through 9 (see 4.4) for motors having a 2 to 1 or less speed range by field control shall include:

a. For Nonreversing Controllers without Dynamic Braking:

1. A single-pole line contactor

2. One to seven accelerating contactors with accelerating means

3. A single-element overload relay

4. A starting resistor (Class 135 or 136)

5. Provision for a separately mounted pushbutton

b. For Nonreversing Controllers with Dynamic Braking:

1. The same equipment as the controller described in par. a

2. A dynamic-braking contactor or the equivalent

3. A dynamic-braking resistor

c. For Reversing Controllers with Dynamic Braking:
The same equipment as the controller described in par. b, but with a set of reversing contactors instead of the line contactor.

3.4 For Motors Having a Speed Range in Excess of 2 to 1 by Field Control

An enclosed jogging-duty controller, Sizes 1 through 9 (see 4.4) for motors having a speed range in excess of 2 to 1 by field control shall include:

a. For Nonreversing Controllers without Dynamic Braking:

1. A single-pole line contactor

2. One to seven accelerating contactors with accelerating means

3. A single-element overload relay

4. A starting resistor (Class 135 or 136)

5. Means for full-field starting

6. Field acceleration means

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

7. Provision for a separately mounted pushbutton

b. For Nonreversing Controllers with Dynamic Braking:

1. The same equipment as the controller described in par. a

2. A dynamic-braking contactor or the equivalent

3. A dynamic-braking resistor

c. For Reversing Controllers with Dynamic Braking:
The same equipment as the controller described in par. b, but with a set of reversing contactors instead of the line contactor.

4 CHARACTERISTICS AND RATINGS

4.1 Horsepower Ratings of DC Drum Switches

The ratings of reversing and nonreversing drum switches shall be in accordance with Table 5-4-1.

Eight-hour ratings shall be used in all cases where any point on the drum switch is in the circuit for any period exceeding 5 minutes. Intermittent ratings shall be used for crane, hoist or other duty where the running time does not exceed 50 percent of the total time and the maximum running time does not exceed 5 minutes.

4.2 Horsepower Ratings of Full-Voltage Manually Operated DC Controllers

The horsepower ratings of full-voltage manually operated controllers (including reversing starter controllers), with or without overload relay or other auxiliary devices and enclosed in any type enclosure, shall be in accordance with Table 5-4-2.

4.3 Horsepower Ratings of Full-Voltage DC Magnetic Controllers

The horsepower ratings of full-voltage magnetic controllers shall be in accordance with Table 5-4-3.

4.4 Horsepower Ratings of Reduced-Voltage DC Magnetic Controllers

The horsepower ratings and the number of accelerating contactors of the controllers described in 3.3 shall be in accordance with Table 5-4-4.

5 PRODUCT INFORMATION, INSTALLATION AND MAINTENANCE

See ICS 1.3 for preventive maintenance instructions.

6 SERVICE AND INSTALLATION CONDITIONS

See ICS 1, Clause 6.

--`,,`-`-`,,`,,`,`,,`---
Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

7 CONSTRUCTION

7.1 Manual Controllers

Face-plate-type manual controllers shall be enclosed.

7.2 Manual Speed Regulators

Face-plate-type manual speed regulators shall have enclosed face plates.

7.3 Resistor Classification for Manual Controllers

Resistor classifications for DC manual controllers shall be:

a. For Controllers Rated 50 Horsepower and Less—Class No. 114 or 115

b. For Controllers Rated More than 50 Horsepower—Class No. 132, 133, 134 or 135

See ICS 9, Part 2 for resistor class.

8 PERFORMANCE REQUIREMENTS AND TESTS

8.1 Short-Time Surge Capability for Class B Controllers

A new Class B controller shall be capable of meeting the requirements of Clause 8 of Part 1 at 15 times the current corresponding to the horsepower rating for 1 second.

For convenience of testing, the duration of the surge capability test shall be permitted to be shortened (to not less than 0.9 seconds) in order to suit the available test current provided that the value of the I^2t (Joule Integral) is maintained.

8.2 Circuit Opening Test

Class B controllers and direct-current manual starting rheostats shall be capable of opening the circuit on the first point with the motor at rest.

9 APPLICATION

Some motor fields may not be able to withstand continuous excitation at full voltage with the motor at rest. In this case, a field protective (economizer) relay is recommended.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 5-4-1
DC DRUM SWITCH RATINGS

8-hour Rating Amperes	8-hour Ratings Horsepower Rating at		Intermittent-duty Ratings Horsepower Rating at	
	115 Volts	230 Volts	115 Volts	230 Volts
50	5	10	7-1/2	15
100	10	25	15	30
150	20	40	25	50
300	40	75	50	100

Table 5-4-2
MANUALLY OPERATED DC CONTROLLER RATINGS

Size of Controller	8-hour Open Rating, Amperes	Horsepower Rating at	
		115 Volts	230 Volts
0	15	1	1
1	25	1 1/2	2

Table 5-4-3
FULL-VOLTAGE MAGNETIC DC CONTROLLER RATINGS

Size of Controller	8-hour Open Rating, Amperes	Horsepower at	
		115 Volts	230 Volts
0	15	1	1
1	25	1 1/2	2

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 5-4-4
REDUCED VOLTAGE MAGNETIC DC CONTROLLER RATINGS

Size of Controller and Contactor	8-hour Open Rating, Amperes	115 Volts		230 Volts		550 Volts	
		Horsepower Rating	Number of Accelerating Contactors	Horsepower Rating	Number of Accelerating Contactors	Horsepower Rating	Number of Accelerating Contactors
1	25	3	1	5	1	...	...
2	50	5	2	10	2	20	2
3	100	10	2	25	2	50	2
4	150	20	2	40	2	75	3
5	300	40	3	75	3	150	4
6	600	75	3	150	4	300	5
7	900	110	4	225	5	450	6
8	1350	175	4	350	5	700	6
9	2500	300	5	600	6	1200	7

NOTE: When a motor has different horsepower ratings at different speeds, the controller rating shall apply to the maximum rating of the motor. Line, reversing and final-accelerating direct-current contactors shall be selected in accordance with the above table.

Intermediate accelerating contactors shall be selected so that the 8-hour open rating will not be less than 0.25 x the accelerating peak.

These controllers may be used at their rating with motors of comparable rating provided that the motor is operated within its nameplate rating or within a service factor rating not greater than 1.15 times it nameplate rating. If the motor is to be operated at service factor rating in access of 1.5 but within standard NEMA service factors, it is recommended that a controller having the next higher horsepower rating be used.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Part 6
AC COMBINATION MOTOR CONTROLLERS

1 GENERAL

1.1 Scope

The standards in this part apply to AC combination motor controllers rated 600 volts or less, rated in horsepower or kilowatts or motor full-load current (FLC) and locked-rotor current (LRA). They also apply to:

a. Specific-purpose magnetic controllers and related control equipment to meet the specific requirements of that portion of the petroleum industry concerned with automatic oil field operation

b. Specific-purpose magnetic controllers and related control equipment to meet the specific requirements for automatic irrigation pump controllers

1.2 Normative References

The definitions and standards of NEMA Standards Publication No. 250, ICS 1, ICS 6 and ICS 2, Part 1 apply to this part unless otherwise stated.

2 DEFINITIONS

combination controller (600 volts or less): A magnetic controller with additional externally operable disconnecting means contained in a common enclosure. The disconnecting means may be a circuit breaker or a disconnect switch.

Combination starters are specific forms of combination controllers.

3 CLASSIFICATION

Types of combination motor controllers

This standard applies to combination motor controllers of the following types:

a. Full voltage, nonreversing

b. Full voltage, reversing

c. Full voltage, two speed, two winding

d. Full voltage, two speed, one winding

e. Part winding, nonreversing

f. Wye delta, single step, nonreversing

g. Reduced voltage, single step, nonreversing

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

4 CHARACTERISTICS AND RATINGS

4.1 Ratings of Combination Motor Controllers

4.1.1 Voltage Rating

The voltage ratings of combination motor controllers shall be in accordance with ICS 1, Clause 4.

4.1.2 Range of Operating Voltage

The range of operating voltage of combination motor controllers shall be in accordance with Clause 8 of Part 1.

4.1.3 Magnetic Motor Controllers

The ratings of magnetic motor controllers used in combination motor controllers shall be in accordance with Part 2.

4.2 Oil Field Pump Controllers

The ratings of combination oil field controllers shall be the same as those shown in Part 2 for Sizes 00 through 5, for 600 volts or less, three-phase.

4.3 Irrigation Pump Controllers

The ratings of combination irrigation pump controllers shall be the same as those shown in Part 2 for motors rated in horsepower or rated only in full-load and locked-rotor current for Sizes 1 through 5, for 600 volts or less.

4.4 Short-Circuit Current Ratings of Class A Combination Motor Controllers

Class A combination controllers (with a specified short circuit protection device) shall have one or more short-circuit current ratings expressed in maximum available fault current (rms symmetrical amperes) at the rated system voltage. The power factor (X/R ratio) shall be as specified in UL 508. Standard short-circuit current ratings are shown in Table 2-4-16.

5 PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION

5.1 Preventive Maintenance Guide

See NEMA Standards Publication ICS 1.3 for preventive maintenance instructions.

5.2 Specific Maintenance Instructions

Where lightning arresters are used, manufacturer's instructions should be followed.

5.3 Maintenance of Combination Motor Controllers After a Fault Condition

See Annex A.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

6 SERVICE AND STORAGE CONDITIONS

See ICS 1, Clause 6.

7 CONSTRUCTION

7.1 Components of Combination Motor Controllers

7.1.1 General

A combination motor controller shall consist of an externally operable circuit-disconnecting means and a magnetic motor controller mounted in a single enclosure. The motor controller shall include motor and branch-circuit overload protection unless equivalent protection is otherwise provided. Where required by the particular application, a circuit breaker (serving also as an externally operable disconnecting means) or provision for fuses shall be included for protection against overcurrent due to short circuits or ground faults.

7.1.2 Manually Operated Disconnect Switches in Combination Motor Controllers

For a combination motor controller rated 100 horsepower or less, the switch shall be a motor-circuit switch having a horsepower rating as great as the horsepower rating of the combination motor controller at the rated voltage.

For a combination motor controller rated more than 100 horsepower, the switch need not be a motor-circuit switch, but it shall be capable of interrupting the maximum operating overload current of a motor of the same horsepower rating as that of the combination motor controller at the rated voltage.

7.1.3 Circuit Breakers in Combination Motor Controllers

Circuit breakers in combination motor controllers shall be either of the inverse-time or the instantaneous-trip magnetic type.
The combination motor controller which includes an instantaneous-trip circuit breaker, is considered an integral unit and is assigned an interrupting rating by the controller manufacturer.

7.1.4 Clearance and Creepage Distances for Disconnecting Means Suitable for Service Equipment

Clearance and creepage distances for disconnecting means and the line side of short-circuit protective devices of combination controllers, where such disconnecting means or short-circuit protective devices, or both, are used as service entrance equipment, shall be in accordance with Table 6-7-1.

These clearances do not apply to the internal spacings of circuit breakers and interrupters which are designed to the applicable standards of Underwriters Laboratories Inc.

7.2 Enclosures

7.2.1 Combinations of Units

The types of combination motor controllers listed in Clause 3 shall be permitted to exist in single enclosures or as combination units in motor control centers, switchboards, busway plug-in devices and panelboards.

7.2.2 Interlocking of Combination Motor Controller Doors

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Enclosures of combination motor controllers shall be equipped with a hinged door which is firmly held in place and interlocked with its associated disconnecting means so that the door cannot be opened without first opening the disconnecting means.

Means shall be provided for locking the disconnecting means in the open position when the door is closed.

Where required by the particular application, a deactivating means (defeater) shall be provided to permit entry into the enclosure when the disconnecting means is closed.

7.3 AC Automatic Combination Oil Field Controllers

7.3.1 Disconnecting Means

Each controller shall be provided with a motor-circuit switch* or circuit breaker which can be opened under load to isolate the circuit.

*Where required by the particular application, the switch should meet the requirements for service entrance equipment. See 7.1.4.

7.3.2 Wiring Diagrams

Wiring diagrams shall be attached to or placed in a pocket of the controller enclosure.

7.3.3 Short-Circuit Protection

Each controller shall be provided with a circuit breaker or provision for fuses of appropriate size to protect the motor branch circuit against overcurrent due to short circuits or ground faults.

7.3.4 Lightning Arresters

Lightning arresters connected to the line side of the disconnecting means shall be provided for all phases in each controller.

7.3.5 Contactors

Each controller shall be provided with a three-pole magnetic contactor.

7.3.6 Undervoltage Release

Each controller shall be provided with undervoltage release.

7.3.7 Starting Open-Phase Protection

Each controller shall be provided with starting open-phase protection.

7.3.8 Overload Protection

Each controller shall be provided with three overload relays, unless equivalent protection of the motor is otherwise provided. The overload relays, or equivalent protection, if located in the controller or operating through the controller, shall be manually reset.

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

7.3.9 Program Timer

Where required by the particular application, a program time switch shall be provided with a 24-hour dial, having a minimum ON interval of not more than 15 minutes and minimum OFF interval of not more than 30 minutes. A day omission feature shall be provided where required by the particular application.

7.3.10 Sequence Starting Provision

Where required by the particular application, the controller shall be provided with a means of delaying starting after power restoration, following a power failure. This feature is intended to prevent multiple simultaneous starting and permits normal voltage recovery before starting the motor.

7.3.11 Selector Switch

Each controller shall include a three-position selector switch marked HAND-OFF-AUTO to permit a choice of manually controlled operation or automatic operation.

7.3.12 Grounding Provision

A grounding stud, 1/4 inch (6 mm) diameter or larger, or lug shall be provided on each enclosure.

7.3.13 Enclosure

Each controller shall be enclosed in an enclosure that is suitable for outdoor applications and equipped with a threaded conduit hub at the top and knockouts at the bottom. See ICS 6. Where ventilating louvers are provided, the openings shall be protected by a mesh screen having a wire gauge in the range of 14 to 18 AWG, or the equivalent.

Each controller shall have provision for mounting either on a flat surface or on a pole.

7.3.14 Overload Relay Current Element Table

Where overload relays are provided, an overload relay current element selection table shall be attached to the enclosure. This table shall be based on operation in the sun at an ambient temperature of 40°C, as measured by a shaded thermometer.

7.4 AC Automatic Combination Irrigation Pump Controllers

7.4.1 Disconnecting Means

Each controller shall be provided with an externally operable motor-circuit switch* or circuit breaker which may be opened under load to disconnect the motor and control from the power source.

*Where required by the particular application, the switch should meet the requirements for service entrance equipment. See 7.1.4.

7.4.2 Wiring Diagrams

Wiring diagrams shall be attached to or placed in a pocket of the controller enclosure.

7.4.3 Short-Circuit and Ground-Fault Protection

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Each controller shall be provided with a circuit breaker or provisions for fuses of appropriate size to protect the motor branch circuit against overcurrent due to short circuits or ground faults.

7.4.4 Overload Protection

Each controller shall be provided with three overload relays unless equivalent protection of the motor is otherwise provided.

7.4.5 Overload Relay Current Element Table

Where overload relays using interchangeable current elements are provided, an element selection table shall be attached to the enclosure.

7.4.6 Control Circuit

The control circuit shall provide the necessary connections for either three-wire or two-wire control. There shall be mounted on the enclosure a three-position selector switch to provide for manual or automatic operation, and an OFF position.

7.4.7 Grounding Provision

A grounding stud, 1/4 inch (6 mm) diameter or larger, or lug shall be provided on each enclosure.

7.4.8 Enclosure

Each controller shall be enclosed in an enclosure which is suitable for outdoor applications and equipped with a threaded conduit hub at the top and knockouts at the bottom. See ICS 6. Where ventilation is required, the openings shall be so protected as not to permit rain to reach live parts.

The enclosure shall be provided with a hinged door, interlocked with the disconnecting means. There shall be provision for locking this door. Where required by the particular application, space shall be provided in the enclosure for essential optional equipment, such as pressure switch, back-spin timer, and lightning arresters.

Each controller shall have provision for mounting either on a flat surface or on a pole.

8 PERFORMANCE REQUIREMENTS AND TESTS

8.1 Design Test for Short-Circuit Current Ratings for Combination Controllers

Selected combination motor controllers which include short-circuit protection shall be tested to verify the ability of the overcurrent devices and other components which may be involved, such as disconnect devices (including operating mechanisms), starters, wiring and enclosures, to withstand short circuits.

Combination motor controllers shall be evaluated and marked in accordance with UL 508.

Manufacturers may determine that their designs meet the standard performance criteria by test or by a combination of test and calculation or interpolation.

9 APPLICATION

See Clause 9.4 of Part 2 and Annex B.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 6-7-1

CLEARANCE AND CREEPAGE DISTANCES OF DISCONNECTING MEANS SUITABLE FOR SERVICE EQUIPMENT

Voltage between parts involved, volts	Minimum spacing, mm (inch)			
	Between Uninsulated live metal parts of opposite polarity		Between Uninsulated live metal parts and any grounded metal	
	Over Surface	Through Air	Over Surface	Through Air
0-125	19 (3/4)	12.7 (1/2)	12.7 (1/2)	12.7 (1/2)
126-250	31.8 (1-1/4)	19 (3/4)	12.7 (1/2)	12.7 (1/2)
251-600	50.8 (2)	25.4 (1)	25.4 (1)	12.7 (1/2)

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Part 7
MAGNETIC LIGHTING CONTACTORS

1 GENERAL

1.1 Scope

The standards in this part apply to alternating-current contactors, rated 600 volts or less, designed for the control of tungsten lamp and electric discharge lighting loads.

1.2 Normative References

NEMA Standards Publication No. 250, ICS 1 and ICS 2, Parts 1 and 2 apply to this part unless otherwise stated.

2 DEFINITIONS

See ICS 1, Clause 2.

3 CLASSIFICATION

This part contains no classifications.

4 CHARACTERISTICS AND RATINGS

The maximum continuous current rating, open or enclosed, when the load is connected directly to the load terminals of the contactor, shall be 30, 60, 75, 100, 150, 200, 225, 300, 400 or 600 amperes.
Where magnetic lighting contactors are used as switching elements to control the primaries of transformers supplying lighting loads, the continuous current rating shall be reduced as follows:

a. For transformers having inrush currents (worst case peak) not more than 20 times the peak continuous current rating—derate to 50 percent

b. For transformers having inrush currents (worst case peak) over 20 but not more than 40 times the peak continuous current rating—derate to 25 percent

5 PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION

See ICS 1.3 for preventive maintenance instructions.

6 SERVICE AND STORAGE CONDITIONS

See ICS 1, Clause 6.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

7 CONSTRUCTION

See ICS 1, Clause 7.

8 PERFORMANCE REQUIREMENTS AND TESTS

8.1 Design Tests

All of the test and performance requirements of Parts 1 and 2, except the make and break design test, shall apply to magnetic lighting contactors.

Magnetic lighting contactors shall be capable of meeting the requirements for the overload and endurance tests as given in UL 508.

8.2 Short-Time Capability

The short-time capability of a new (unused) magnetic lighting contactor shall be 15 times its continuous current rating for 1/2 second. See Part 1, Clause 8 for test procedure.

9 APPLICATIONS

There is no application information in this part.

--`,,`-`-`,,`,,`,`,,`---
Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Part 8
DISCONNECT DEVICES FOR USE IN INDUSTRIAL CONTROL EQUIPMENT

1 GENERAL

1.1 Scope

The standards in this part cover AC motor-circuit switches rated 600 volts used in industrial control equipment. Also included are separable or accessory operating mechanisms and handles for the external operation of motor-circuit switches, circuit breakers, and molded-case switches. The devices covered by this standard are for application in combination starters, motor control centers and industrial control panels. See Figure 8-1-1. Excluded are the operating mechanisms that are an internal or integral part of motor-circuit switches, circuit breakers, or molded-case switches.

Horsepower-rated switches mounted separately in their own enclosures, commonly called "safety" or "enclosed switches" or "miscellaneous "switches", are not included in the scope of this standard. Although ANSI/NFPA 70 (NEC) permits devices not rated in horsepower, such as circuit breakers, molded-case switches, general-use switches, and snap switches to serve as the disconnecting means in industrial control equipment under specified circumstances, such disconnecting means are not covered by this standard. Also excluded are manual motor controllers, pullout switches, and wiring devices rated in horsepower.

This standard does not address the suitability of manual motor controllers intended for use as disconnecting means.

1.2 Application Basis

Disconnect devices should be applied by qualified persons in accordance with ANSI/NFPA 70 (NEC) and properly operated and maintained in accordance with the safety practices of ANSI/NFPA 70E (Electrical Safety Requirements for Employee Workplaces), and 29 CFR Part 1910.147 (OSHA lockout/tagout rules).

1.3 Normative References

The definitions and standards of NEMA Standards Publications ICS 1, ICS 6, KS 1 and AB 1 also apply to this part.

2 DEFINITIONS

For the purposes of this part, the following definitions apply:

available fault current: The maximum current that the power system can deliver through a given circuit point to any negligible-impedance short circuit applied at that point. Available fault current is also known as prospective current.

circuit breaker: A device designed to open and close a circuit by nonautomatic means, and to open the circuit automatically on a predetermined overcurrent, without injury to itself when properly applied within its rating. (NEMA AB 1)

circuit breaker, instantaneous-trip: (Also called a motor circuit interrupter or motor circuit protector) - A circuit breaker intended to provide short circuit protection with no overload protection. Although acting instantaneously under short circuit conditions, instantaneous breakers are permitted to include a transient damping action to ride through initial motor transients.(NEMA AB1)

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

circuit breaker, inverse-time: A circuit breaker that operates instantaneously in response to a high fault current, and in a time period that is inversely proportional to current for overcurrents less than the instantaneous-trip current. (NEMA AB 1)

fuse: A protective device which opens by the melting of a current-sensitive element during specified overcurrent conditions. A fuse comprises all the parts that form a unit capable of performing the prescribed functions. It may or may not be the complete device necessary to connect it into an electrical circuit. Fuses may be of the time-delay or nontime-delay type. (NEMA FU 1)

fuse, nontime-delay: A fuse that operates in a time period that is inversely proportional to the overcurrent it is carrying, without intentional time delay.

fuse, time-delay: A fuse that operates in a time period that is inversely proportional to the overcurrent it is carrying, with an intentional time delay to permit motor acceleration.

independent manual operation: A stored energy operation of a mechanical switching device where the energy originates from manual power, stored and released in one continuous operation, such that the speed and force of the operation are independent of the action of the operator.

molded-case switch: A switch that is assembled as an integral unit in a supporting and enclosing housing of insulating materials. A molded-case switch is generally constructed in a manner similar to a molded-case circuit breaker, but is marked to show that it does not provide overcurrent protection. See NEMA AB 3 and UL 1087.

motor-circuit switch: A switch, rated in horsepower, capable of interrupting the maximum operating overload current of a motor of the same horsepower rating as the switch at the rated voltage. (NEC)

rated insulation voltage: The voltage rating that determines the clearance and creepage distance required for the device and to which dielectric tests are referred.

short-circuit withstand rating: The maximum potential fault conditions under which a device that does not have a short-circuit interrupting rating may be installed in accordance with Sections 110-9 and 110-10 of ANSI/NFPA 70 (NEC). For a device that is not designed to interrupt short-circuit currents, the short-circuit withstand rating is expressed as maximum available fault current, maximum nominal application voltage, and the designation of an associated short-circuit protective device (SCPD) required for the rating. This designation includes the type or class of SCPD and its maximum current rating.

short-circuit interrupting rating: A rating based on the highest rms AC current that the short-circuit protective device (SCPD) is required to interrupt under conditions specified. For a SCPD, such as a circuit breaker, the short-circuit interrupting rating is expressed as maximum available fault current in rms symmetrical amperes and maximum nominal application voltage.

switch: A device, manually operated, unless otherwise designated, for opening or closing or for changing the connection of a circuit. (NEMA KS 1)

3 CLASSIFICATION

A disconnect device for use in industrial control equipment and its external operating handle may be classified by its:

a. type (motor-circuit switch, circuit breaker or molded-case switch)
b. number of poles
c. ratings
d. suitability for service entrance
e. suitability for specified enclosure types in accordance with ICS 6.

--`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

4 CHARACTERISTICS AND RATINGS

4.1 Circuit Breaker Ratings

Voltage, current, and interrupting ratings of circuit breakers are established by NEMA AB 1.

4.2 Molded-Case Switch Ratings

Voltage, current, and withstand ratings of molded-case switches are established by NEMA AB 1.

4.3 Motor-circuit Switch Ratings

4.3.1 Horsepower Ratings

Motor-circuit switches shall have ratings as specified in Table 8-4-1 and Table 8-4-2. These switches may be used with or without fuse holders.

These ratings are equivalent to the enclosed switch maximum horsepower ratings specified in KS 1. The continuous current rating of each switch is equal to, or greater than, 115 percent of the nominal motor full-load currents corresponding to its horsepower ratings. See Annex B.

4.3.2 Short-Circuit Withstand Rating

Each motor-circuit switch shall have a minimum short-circuit withstand rating of 10,000 amperes, rms symmetrical, at 600 volts AC. In addition, switches may have greater short-circuit withstand ratings.

For each short-circuit withstand rating, the type or class, and the voltage and current rating of the short-circuit protective device (SCPD) must be specified. The short-circuit withstand rating of a motor-circuit switch shall not be greater than the interrupting rating of the fuse used to establish the rating.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 8-4-1
THREE-PHASE RATINGS OF MOTOR-CIRCUIT SWITCHES

Continuous Current Rating, Amperes	Fuseholder Sizes*, Amperes	Horsepower at 60 Hz				Associated NEMA Class A Controller Size
		200 V	230 V	460 V	575 V	
30	30 and 60	7.5	7.5	15	20	00 - 1
60	30, 60 and 100	15	15	30	50	2
100	100 and 200	25	30	60	75	3
200	200 and 400	50	60	125	150	4
400	400 and 800	100	125	250	350	5
400	600, 800, and 1200	150	200	400	500	6

* Switches with fuse holders having an ampere rating greater than the ampere rating of the switch are suitable for use only in motor branch circuits that include overload relays to protect the branch circuit conductors against overcurrent in accordance with their ampacity. The larger fuse sizes may be necessary to permit motors to accelerate to their rated speed.

Table 8-4-2
SINGLE-PHASE RATINGS OF MOTOR-CIRCUIT SWITCHES

Continuous Current Rating (Amperes)	Fuseholder Sizes*, (Amperes)	Horsepower at 60 Hz		Associated NEMA Class A Controller Size
		115 V	230 V	
30	30 and 60	2	3	00 - 1
60	30, 60 and 100	3	10	1P - 2
100	100 and 200	7.5	15	3
200	200 and 400	10	25	4

* Switches with fuse holders having an ampere rating greater than the ampere rating of the switch are suitable for use only in motor branch circuits that include overload relays to protect the branch circuit conductors against overcurrent in accordance with their ampacity. The larger fuse sizes may be necessary to permit motors to accelerate to their rated speed.

4.4 Rated Insulation Voltage

The rated insulation voltage of motor-circuit switches shall be 600 volts. The voltage rating of circuit breakers and molded-case switches shall be in accordance with NEMA AB 1.

5 PRODUCT MARKING, INSTALLATION, AND MAINTENANCE INFORMATION

5.1 Marking

The complete open disconnect device for installation in industrial control equipment shall include the information from 5.1.1.

5.1.1 Shown on Device Nameplate, or Label Attached to the Motor-Circuit Switch:

a. the manufacturer's name or trademark
b. catalog or type designation
c. horsepower rating
d. rated operational voltage
e. rated continuous current
f. rated frequency
g. wire limitations, e.g., "for use with 75°C wire"

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

h. ON-OFF position on the external operating handle assembly
i. ON-OFF status indication on the switch unit if switch unit does not incorporate a visible contact gap
j. terminal identification
k. When applied as service entrance equipment must be marked in accordance with the NEC.

5.1.2 Shown on Nameplate of, Label Attached to, or Instruction Material Packaged with, the Motor-Circuit Switch

l. the mark "NEMA" or the NEMA logo and the words "motor-circuit switch" if the manufacturer claims compliance with this standard
m. short-circuit withstand rating(s)
n. conductor sizes, where applicable
o. tightening torque
p. suitable enclosure types, where applicable

5.2 Exception

Where a motor-circuit switch is incorporated into other equipment (e.g. a combination starter) the marking requirements for that equipment shall apply.

5.3 Other Disconnect Devices for Motor Service

The marking of circuit breakers and molded-case switches shall comply with NEMA AB 1.

5.4 Marking Limitations

No ratings or characteristics that conflict with this standard shall be shown.

5.5 Operating Handles Sold Separately

Each operating handle sold separately shall be marked to show the disconnect device and enclosure type(s) for which the handle is suitable for use.

6 SERVICE AND STORAGE CONDITIONS

See ICS 1, Clause 6.

7 CONSTRUCTION

7.1 Clearances and Creepage Distances

Motor-circuit switches shall have the clearances and creepage distances specified in Table 8-7-1. Circuit breakers and molded-case switches shall comply with AB 1.

--`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Table 8-7-1
MOTOR-CIRCUIT SWITCH SPACINGS
MINIMUM SPACINGS IN INCHES* (mm)

	Between Uninsulated Live Parts of Opposite Polarity†		Between Uninsulated Parts and Any Grounded Dead Metal	
Voltage Between Parts Involved	Clearance (Through Air)	Creepage Distance (Over Surface)	Clearance (Through Air)	Creepage Distance (Over surface)
0 - 600	1.000 (25.4)	2.000 (50.8)	0.500 (12.7)	1.000 (25.4)

* Adopted from NEMA KS 1-1990, "Enclosed and Miscellaneous Distribution Equipment Switches (600 Volts Maximum)."
† Also applies between live parts of the power circuit and live parts of the control circuit.

7.2 Minimum Air Gap in Open Position

Motor-circuit switches shall have an open contact air gap of not less than 0.375 inch (9.5 mm) between the line and load terminals.

7.4 Mechanical Design of Operating Handle and Mechanism

The design and construction of disconnecting devices including the operating handle and operating mechanism shall be such as to assure ample strength and rigidity. Screws and nuts serving to attach operating parts to cross bars or other movable members shall be upset or otherwise locked to prevent loosening under the jarring of continued use. Stops shall be provided if required to remove undue strain from switch parts. Materials shall be suitable for the particular application.

All metal parts, unless of corrosion resistant material, shall be galvanized, plated, enameled, painted or otherwise treated to prevent corrosion.

7.4 External Operating Handles for Disconnect Devices

A suitable operating handle shall be provided for safe and convenient operation of the disconnect device when mounted in an industrial control enclosure.

All parts of a conducting material accessible to the operator with the enclosure closed shall be electrically connected to the enclosure or insulated from energized parts in such a manner so as to reasonably preclude any opportunity of their becoming energized.

A metal shaft within a bearing which in turn is electrically connected to the enclosure or a metal shaft using the wall of the enclosure as a bearing shall be considered to be in electrical connection with the enclosure.

7.5 Status Indication

Under normal operating conditions, the position of the contacts of an enclosed disconnect device shall be indicated by the position of the external operating handle. There shall be definite indication of the ON and OFF positions of the handle, and the design of the operating mechanism shall be such that the handle cannot be left readily at or near the OFF position when the switch blades or contacts are in the closed position.

With the enclosure door open, unless constructed with a visible contact gap, a disconnect device shall be plainly marked to indicate the ON and OFF positions, in addition to the ON and OFF markings on the handle.

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

Where handle movement is in a vertical plane, the upper position shall be ON. An operating handle which moves in a horizontal plane or a rotary actuator must clearly indicate the ON and OFF positions.

When the contacts of an enclosed disconnect device are welded or blocked in the closed position and the external handle can be forced to the OFF position, the handle must return to a position other than OFF when released, or the closed position of the contacts must be reliably indicated by separate means.

In the case of a circuit breaker, a tripped position location of the handle or an indicator may be provided at the option of the manufacturer.

7.6 Operating Mechanism for Disconnect Devices

Means other than friction or gravity shall be provided to hold an installed disconnect device in the ON or OFF position.

Disconnect devices shall be designed for independent manual operation, as defined in Clause 3.

The design of the operating mechanism in conjunction with the contact structure shall be such that, in normal operation, the person operating the device cannot restrain the operation of the contacts after they have initially touched or parted when closing or opening the device.

7.7 Mechanical Interlock with Door(s)

The operating mechanism of a disconnect device shall provide mechanical interlocking with the main door of the enclosure (and, where provided, an auxiliary door giving access to the main fuses) which (1) normally prevents the door being opened when the device contacts are closed, and (2) normally prevents the disconnect device contacts from being closed when the door (and auxiliary cover) of the enclosure is open.

The mechanical interlock for the operating mechanism shall be provided with an interlock release (defeater) by which a qualified person (1) using a tool can open the door to inspect the device in the ON position, and (2) can close the contacts with the door open only by operating the interlock release.

The interlocking shall be reactivated automatically when the enclosure door(s) is closed.

The operating handle or other member which indicates the position of the disconnect device blades or contacts (closed or open) shall be designed so that the door, front, or cover cannot be closed and secured in place in the intended manner with the handle or member indicating OFF when the disconnect device blades or contacts are in the closed position.

7.8 Padlocking Provisions

Provisions for padlocking shall be provided on the external operating handle to positively lock each enclosed disconnect device when its contacts are in the open position (OFF).

Such means shall accommodate at least three padlocks with shackle diameters within the range of 3/16 inch (4.8 mm) through 5/16 inch (7.9 mm). Any single padlock shall provide locking.

7.9 Additional Construction Requirements for Disconnect Devices

Provision for padlocking the external operating handle in the ON position shall require a conscious modification by the user, such as the drilling of the hole for the shackle.

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

7.10 Fuse Mounting

Motor-circuit switches may be without fuse mounting provisions or with fuseholders. Where provided as fusible devices, motor-circuit switches shall include fuse clips or fuse mounting means for cartridge fuses which comply with KS-1. See Table 8-4-1 and Table 8-4-2.

8 PERFORMANCE REQUIREMENTS AND TESTS

8.1 Circuit-Breaker and Molded-Case Switch Type Tests

The testing of circuit breakers and molded-case switches as components (without external operating mechanisms) shall be in accordance with AB 1. In addition, the external operating handle and mechanism strength test of 8.3 applies.

8.2 Motor-Circuit Switch Type Tests

The testing of motor-circuit switches shall be in accordance with KS1. In addition, the external operating handle and mechanism strength test of 8.3 applies.

8.3 Verification of the Strength of External Operating Handle, Mechanism, and Position Indicating Device

The minimum strength requirement of an external operating handle and its associated mechanism shall be verified from the full ON position by the following procedure:

a. Mechanically (e.g. by welding or bolting) connect the movable blade (movable contact part) to the stationary part (contact) of that pole of a disconnect device farthest from the external operating handle center.

b. Apply a 45 pound force (200 newtons) normal (90 degrees) to the external operating handle at the point of maximum leverage for one minute, or apply sufficient force to move the handle to the full OFF (lockable) position for one minute, whichever is less.

c. After the test, when the test force is no longer applied, the operating handle being left free, the OFF position shall not be wrongly indicated by the device, by the separate indicator where applicable, or by the operating handle where the handle is the only means of indication.

d. After the test, the equipment shall not show damage such as to impair proper operation.

9 APPLICATIONS

9.1 Application of Circuit Breakers

An inverse-time circuit breaker (thermal-magnetic) or an instantaneous-trip circuit breaker (magnetic-trip-only) may be used as the disconnecting means in a motor branch circuit. An instantaneous-trip circuit breaker must have adjustable trip provisions and be used with overload relays, and be part of a listed combination controller. Circuit breakers are constructed and tested in accordance with NEMA AB 1. See NEMA AB 3 for additional application information for circuit breakers.

9.2 Protection of Nonfused Motor-Circuit Switches

Nonfused motor-circuit switches in combination starters and industrial control panels are often mounted on or adjacent to machines under circumstances where the short-circuit protective device (SCPD) is located in a remote switchboard, panelboard, or motor control center. Such nonfused equipment will include a listing of one or more short-circuit withstand ratings based on a variety of SCPD's identified by

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

class, type and rating. The short-circuit protection must be provided by fuses or a Inverse-time circuit breaker rated in accordance with ANSI/NFPA 70 (NEC) and must be one of the SCPD's listed for use with the switch.

9.3 Safety Procedure for Verifying Deenergized Condition

Disconnect devices for motor service are subject to the safety requirements of ANSI/NFPA 70E "Electrical Safety Requirements for Employee Workplaces", which includes lockout-tagout procedures. This safety standard, in addition to meeting the lockout-tagout provisions, requires that reliance not be placed on the disconnect device position indication but rather on the following two acts to verify deenergization of the circuit.

9.3.1 Verify that Equipment Cannot be Restarted

Operate the equipment operating controls such as push buttons, selector switches, and electrical interlocks, or otherwise verify that the equipment cannot be restarted.

9.3.2 Verify that Circuit and Equipment are Deenergized

Test the circuits and equipment by use of appropriate test equipment to verify that the circuits and equipment are de-energized. Check the test equipment used for proper operation immediately before and immediately after this test.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale




Figure 8-1-1
DISCONNECT DEVICES FOR MOTOR SERVICE

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

--```-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS

Not for Resale

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS

Not for Resale

Annex A
(Informative)

MAINTENANCE OF MOTOR CONTROLLERS AFTER A FAULT CONDITION

A.1 INTRODUCTION

In a motor branch circuit which has been properly installed, coordinated and in service prior to the fault, opening of the branch-circuit short-circuit protective device (fuse, circuit breaker, motor short-circuit protector, etc.) indicates a fault condition in excess of operating overload. This fault condition should be corrected and the necessary repairs or replacements made before reenergizing the branch circuit.

It is recommended that the following general procedures be observed by qualified personnel in the inspection and repair of the motor controller involved in the fault. Manufacturers' service instructions should also be consulted for additional details.

The following are procedures to be followed in order to return to service a motor controller which has been subjected to a short circuit or a ground fault. These procedures are not intended to cover other elements of the branch circuit, such as wiring and motors, which may also require attention.

A.2 PROCEDURES

DANGER—all inspections and tests are to be made on controllers and equipment which are deenergized, disconnected, locked out and tagged so that accidental contact cannot be made with live parts and so that all plant safety procedures will be observed.

A.2.1 Enclosure

Where substantial damage to the enclosure, such as deformation, displacement of parts or burning has occurred, replace the entire controller.

A.2.2 Disconnect Devices

A.2.2.1 Circuit Breakers

Examine the enclosure interior and the circuit breaker for evidence of possible damage. If evidence of damage is not apparent, the circuit breaker may be reset. If there is any indication that the circuit breaker has opened several short-circuit faults, or if signs of possible deterioration appear either within the enclosure or on the circuit breakers, for example, surface discoloration, insulation cracking, or unusual toggle operation, replace the circuit breaker.

A.2.2.2 Disconnect Switch

Verify that the external operating handle is capable of opening the switch. If the handle fails to open the switch or if visual inspection after opening indicates deterioration beyond normal wear and tear, such as overheating, contact blade or jaw pitting, insulation breakage or charring, replace the switch.

A.2.2.3 Fuse Holders

Where deterioration of fuse holders or their insulating mounts has occurred replace them.

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale

A.2.3 Terminals and Internal Conductors

Where there are indications of arcing damage or overheating, or both, such as discoloration and melting of insulation, replace the damaged parts.

A.2.4 Motor Starter

A.2.4.1 Contactor

Replace contacts showing heat damage, displacement of metal, or loss of adequate wear allowance of the contacts, and also replace the contact springs where applicable. If deterioration extends beyond the contacts, such as binding in the guides or evidence of insulation damage, replace the damaged parts or the entire contactor.

A.2.4.2 Overload Relays

a. If burnout of the current element of an overload relay has occurred, replace the complete overload relay. Any indication that an arc has struck or any indication of burning of the insulation of the overload relay, or both, also requires replacement of the overload relay.

b. If there is no visual indication of damage that would require replacement of the overload relay, trip the relay electrically or mechanically to verify the proper functioning of the overload relay contact(s).

c. If there is no visual indication of damage that would require replacement of an overload relay with solid-state output, check the overload relay output to verify performance within the minimum and maximum current ratings.

A.2.5 Return to Service

Before returning the controller to service, check for the tightness of electrical connections and for the absence of short circuits, ground faults and leakage current.

Close and secure all equipment enclosures before the branch circuit is energized.

--`,,`,,`-`-`,,`,,`,`,,`---

Copyright National Electrical Manufacturers Association
Provided by IHS under license with NEMA
No reproduction or networking permitted without license from IHS
Not for Resale