Errata

NFPA 10

Standard for Portable Fire Extinguishers

2007 Edition

Reference: 7.1.2.1
Errata No.: 10-07-2

The Committee on Portable Fire Extinguishers notes the following error in the 2007 edition of NFPA 10, *Standard for Portable Fire Extinguishers*. The first two sentences of this section were inadvertently omitted from the printing.

1. *Revise 7.1.2.1 to read as follows:*

7.1.2.1 The procedure for inspection and maintenance of fire extinguishers varies considerably. Minimal knowledge is necessary to perform a monthly "quick check" or inspection in order to follow the inspection procedure as outlined in Section 7.2. A trained and certified person who has undergone the instructions necessary to reliably perform maintenance and has the manufacturer's service manual shall service the fire extinguishers not more than 1 year apart, as outlined in Section 7.3.

Issue Date: May 23, 2008

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/codelist)

Copyright © 2008 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION

Copyright National Fire Protection Association
Provided by IHS under license with NFPA
No reproduction or networking permitted without license from IHS
Not for Resale