Errata

NFPA 30

Flammable and Combustible Liquids Code

2008 Edition

Reference: Various
Errata No.: 30-08-1

The Committee on Flammable and Combustible Liquids notes the following errors in the 2008 of NFPA 30, *Flammable and Combustible Liquids Code***.**

1. In 3.3.26, delete the phrase "or greater" at the end of the sentence.

2. In 9.14, 10.14, 12.14, and 13.14: change the reference to "Chapter 18" to "Section 18.5".

3. In 11.3, change the reference to "Section 18.3" to "Section 18.4".

4. In 12.3.1 and 12.3.2, change the three references to "Section 12.6" to "Section 12.8".

5. In 12.16 and 13.16, delete the parenthetical "(See 9.16.1.)".

6. In 14.4.7 change the reference to "Section 9.14" to "Section 18.5".

7. In Figure 16.8.1, in the first decision diamond, change the text to read: "Is liquid excluded by 9.1.4?"

8. Delete the asterisk on 18.4.4.1(2)(d).

9. Add an asterisk to 18.4.6(3).

10. Revise 19.5.6.2 to read: "Overfill protection of tank vehicles shall be in accordance with applicable provisions of Subsection 28.11.1."

11. Revise 19.5.7.1 to read: "**Vapor Release.** Tank or equipment openings provided for purposes of vapor recovery shall be protected against possible vapor release in accordance with 23.13.7 and 28.11.1.8.1."

12. In 21.3.1, change "riveted, and caulked," to "riveted and caulked,"; i.e., delete the comma after the word "riveted".

13. Revise 21.7.4.3.2.1 to read: "Tanks remaining temporarily out of service for more than 1 year shall be permanently closed in place or removed in accordance with 21.7.4.3.3 or 21.7.4.3.4, as applicable."

Copyright National Fire Protection Association
Provided by IHS under license with NFPA
No reproduction or networking permitted without license from IHS
Not for Resale

14. In 22.7.3.2, revise the start of the sentence to read: "Except as provided for in 22.7.3.5, 22.7.3.6, and 22.7.3.7, . . .".

15. In 22.7.3.5, revise the start of the sentence to read: "Except as provided for in 22.7.3.6 and 22.7.3.7, for tanks containing stable liquids, the required emergency relief venting capacity determined by 22.7.3.2, 22.7.3.3, or 22.7.3.4, ...".

15. In the Exception to 22.11.1.2, change the reference from "22.11.3" to "22.11.2".

16. Renumber Annex Item "A.18.4.4.1(2)(d)" to "A.18.4.6(3)".

17. In Section F.2, Item (8), methane is listed three times. This is not correct and the list should read:

83% methane (molecular weight = 16)
13% ethane (molecular weight = 30)
4% butane (molecular weight = 58)

18. In H.1.2.1, replace "345 East 47th Street, New York, NY 10017" with "3 Park Avenue, New York, NY 10016".

Issue Date: March 13, 2008

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/codelist)

Copyright © 2008 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION

--`,,```,,,,````-`-`,,`,,`,`,,`---

Copyright National Fire Protection Association
Provided by IHS under license with NFPA
No reproduction or networking permitted without license from IHS
Not for Resale