Errata

NFPA 34

Standard for Dipping and Coating Processes Using Flammable or Combustible Liquids

2007 Edition

Reference: 9.7.2
Errata No.: 34-07-01

The Committee on Finishing Processes notes the following error in the 2007 edition of NFPA 34, *Standard for Dipping and Coating Processes Using Flammable or Combustible Liquids:*

1. Subsection 9.7.2 should be corrected to read:

9.7.2 The extinguishing system shall be designed to simultaneously discharge into the entire protected area, as described in 9.7.1(1) through 9.7.1(4).

Issue Date: September 11, 2007

Copyright © 2007 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION

--`,,```,,,,````-`-`,,`,,`,`,,`---

Copyright National Fire Protection Association
Provided by IHS under license with NFPA
No reproduction or networking permitted without license from IHS

Not for Resale