Errata

NFPA 45
Standard on Fire Protection for Laboratories Using Chemicals

2004 Edition

Errata No.: 45-04-1

The Technical Committee on Laboratories Using Chemicals notes the following errors in the 2004 edition of NFPA 45, *Standard on Fire Protection for Laboratories Using Chemicals.*

1. The ROP contained a row for PLDC that was inadvertently added to the ROC row for PLDC in the final printing. Revise table 10.1.4 to eliminate this additional ROP PLDC row to read as follows:

	Flammable Liquids[a]			Combustible Liquids[a]	
Container Type	**IA**	**IB**	**IC**	**II**	**IIIA**
Glass	500 ml (1 pt)[b]	1 L (1 qt)[b]	4 L (1 gal)	4 L (1 gal)	20 L (5 gal)
Metal (other than DOT drums) or approved plastic	4 L (1 gal)	20 L (5 gal)[c]	20 L (5 gal)[c]	20 L (5 gal)[c]	20 L (5 gal)
Safety cans	10 L (2.6 gal)[c]	20 L (5 gal)[c]	20 L (5 gal)[c]	20 L (5 gal)[c]	20 L (5 gal)
Metal container (DOT spec.)	4 L (1 gal)	20 L (5 gal)[c]	20 L (5 gal)[c]	227 L (60 gal)[c]	227 L (60 gal)
Polyethylene (DOT Spec. 34, UN 1H1, or as authorized by DOT exemption)	4 L (1 gal)	20 L (5 gal)[c]	20 L (5 gal)[c]	227 L (60 gal)[c]	227 L (60 gal)
Pressurized liquid dispensing container	20 L (5 gal) [c]	227 L (60 gal) [c]	227 L (60 gal) [c]	227 L (60 gal) [c]	227 L (60 gal)

Issue Date: January 19, 2005

Copyright © 2005 all Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION

Copyright National Fire Protection Association
Provided by IHS under license with NFPA
No reproduction or networking permitted without license from IHS
Not for Resale