Errata

NFPA 55

Standard for the Storage, Use, and Handling of Compressed Gases and Cryogenic Fluids in Portable and Stationary Containers, Cylinders, and Tanks

2005 Edition

Reference: Table 6.3.1, 6.12.2.2
Errata No.: 55-05-1

The Technical Committee on Industrial and Medical Gases notes the following conversions errors in the printing of the 2005 edition of NFPA 55, *Standard for the Storage, Use, and Handling of Compressed Gases and Cryogenic Fluids in Portable and Stationary Containers, Cylinders, and Tanks.*

1. In Table 6.3.1 revise the conversion for m^3 under Flammable Gas, Nonliquefied as follows:

Flammable Gas				
Liquefied	114 L (30 gal)	227 L (60 gal)	227 L (60 gal)	454 L (120 gal)
Nonliquefied	28 m^3 (1000 ft^3)	56 m^3 (2000 ft^3)	56 m^3 (2000 ft^3)	112 m^3 (4000 ft^3)

2. Revise 6.12.2.2 to read as follows:

6.12.2.2 No Smoking. Signs prohibiting smoking or open flames within 7.6 m (25 ft) of area perimeters shall be provided in areas where toxic, highly toxic, corrosive, unstable reactive, flammable, oxidizing, or pyrophoric gases are produced, stored, or used.

Issue Date: March 7, 2006

Copyright © 2006 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION

Copyright National Fire Protection Association
Provided by IHS under license with NFPA
No reproduction or networking permitted without license from IHS
Not for Resale