Errata

NFPA 72®

National Fire Alarm Code®

2007 Edition

Reference: 9.5.1.7
Errata No.: 72-07-2

The Committee on Signaling Systems for the Protection of Life and Property notes the following error in the 2007 edition of NFPA *72*®, *National Fire Alarm Code*®.

1. Change 9.5.1.7 to read as follows:

9.5.1.7 Engine-Driven Generators. The installation of engine-driven generator sets shall conform to the provisions of NFPA 37, *Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines*; NFPA 110, *Standard for Emergency and Standby Power Systems*; ~~NFPA 11, Standard for Low-, Medium-, and High-Expansion Foam~~; and NFPA 1221, *Standard for the Installation, Maintenance, and Use of Emergency Services Communications Systems*.

Issue Date: March 25, 2009

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/codelist)

Copyright © 2009 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION

Copyright National Fire Protection Association
Provided by IHS under license with NFPA
No reproduction or networking permitted without license from IHS
Not for Resale